

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.58	13.21	60.29	2.18	18.16	11.39	1.18	80028.13
1	7.51	13.98	56.98	1.78	18.08	11.92	1.18	76015.65
2	11.47	12.56	41.80	2.50	20.43	10.18	1.18	87920.85
3	7.70	13.66	46.94	3.29	20.07	10.12	1.18	88721.01
4	6.70	13.46	55.77	2.19	19.06	11.37	1.18	79544.55
5	10.34	12.98	54.10	2.91	20.54	10.24	1.22	77582.48
6	7.48	12.59	49.34	2.94	19.17	10.86	1.23	83066.48
7	9.26	12.64	45.38	2.59	19.59	10.51	1.23	85742.54
8	8.30	11.14	51.18	1.48	20.16	10.27	1.23	87251.33
9	1.30	10.92	51.44	1.22	18.66	10.46	1.22	87347.75
10	1.00	11.40	57.19	1.39	17.57	11.05	1.22	83591.12
11	7.85	11.24	59.67	1.31	19.02	10.83	1.22	83752.50
12	11.16	11.54	54.14	2.03	16.62	11.26	1.21	82711.97
13	1.77	11.98	51.96	1.22	17.59	11.34	1.22	80868.71
14	9.38	11.23	50.92	1.46	17.94	10.93	1.21	83893.82
15	12.41	11.80	47.38	2.27	16.36	11.40	1.21	82353.53
16	5.39	11.70	52.31	1.60	17.84	11.08	1.24	83641.09
17	10.56	12.26	52.45	1.87	19.36	10.36	1.22	87679.45
18	8.50	12.55	44.27	1.88	18.71	10.49	1.23	87304.06
19	9.73	12.82	49.86	1.85	16.53	11.31	1.24	83110.49
20	7.48	13.42	61.59	1.41	17.00	11.67	1.24	79016.00
21	7.89	12.75	54.11	1.37	18.26	10.90	1.23	84002.42
22	10.68	12.72	52.60	1.87	17.89	10.99	1.23	84308.52
23	8.91	12.52	47.14	3.00	17.26	10.94	1.23	85222.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.93	12.38	52.03	1.98	18.41	10.91	1.21	83528.19
最大值	12.41	13.98	61.59	3.29	20.54	11.92	1.25	88721.01
發生時間	15	1	20	3	5	1		3
最小值	1.00	10.92	41.80	1.22	16.36	10.12	1.17	76015.65
發生時間	10	9	2	9	15	3		1
零點偏移(率)	-0.05 %	0.00 %	-0.14 %	0.00 %		-0.01	-0.01	0.20 %
全幅偏移(率)	-0.97 %	-1.58 %	-0.04 %	-0.12 %		-0.20	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.25	12.00	46.27	1.12	18.88	10.32	0.94	81698.69
1	0.91	12.30	55.35	0.97	19.49	10.50	0.94	80969.48
2	1.64	12.31	58.01	0.90	20.19	10.49	0.94	83999.52
3	1.83	12.53	50.10	0.68	21.14	10.27	0.94	84505.14
4	1.10	12.66	41.58	1.29	19.52	10.32	0.94	85001.71
5	1.84	12.42	55.46	1.03	19.52	10.62	0.94	81537.92
6	3.25	13.27	47.14	0.86	19.44	10.30	0.94	86844.15
7	3.43	14.13	61.30	1.74	18.29	11.18	0.94	81301.29
8	5.49	12.57	51.70	2.26	18.34	10.95	0.98	84674.31
9	5.95	12.68	59.65	2.53	17.12	11.34	0.99	82808.41
10	8.06	12.48	58.22	2.55	17.60	11.13	0.98	83618.03
11	9.59	12.08	53.59	1.78	18.50	10.57	0.99	82644.85
12	12.17	12.02	59.03	1.20	19.36	10.34	0.99	81646.33
13	7.43	12.36	52.84	1.60	17.71	10.73	0.98	82984.25
14	11.57	11.97	55.47	1.87	17.67	10.66	0.98	84545.55
15	9.74	12.33	52.59	2.15	16.74	11.10	0.99	81807.71
16	3.90	12.25	59.12	1.43	17.82	10.90	1.00	82683.50
17	6.62	12.14	53.58	0.98	19.02	10.59	1.00	85117.68
18	7.90	12.06	48.31	1.05	18.91	10.51	0.99	85608.78
19	9.13	13.15	48.56	1.85	17.78	10.65	0.98	84339.47
20	8.33	11.88	48.07	1.61	17.37	10.74	0.98	79940.55
21	8.27	11.97	54.23	1.26	18.29	10.57	0.99	81491.35
22	9.00	12.44	50.78	1.09	17.72	11.01	0.99	81378.84
23	11.29	12.13	49.45	1.68	17.30	10.78	0.99	81374.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.32	12.42	52.93	1.48	18.49	10.69	0.97	83021.75
最大值	12.17	14.13	61.30	2.55	21.14	11.34	1.06	86844.15
發生時間	12	7	7	10	3	9		6
最小值	0.91	11.88	41.58	0.68	16.74	10.27	0.94	79940.55
發生時間	1	20	4	3	15	3		20
零點偏移(率)	-0.07 %	-0.00 %	-0.04 %	0.00 %		0.00	-0.01	-0.10 %
全幅偏移(率)	2.01 %	-1.15 %	0.04 %	-1.12 %		0.09	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.19	12.25	51.48	2.63	19.82	9.10	1.31	76338.68
1	9.88	12.40	45.47	2.75	20.15	9.08	1.31	76282.95
2	5.94	12.34	42.81	2.42	21.21	8.86	1.33	77330.50
3	7.44	12.76	43.17	2.73	20.75	9.04	1.33	75798.25
4	3.79	13.14	44.43	2.29	21.29	9.11	1.33	78140.18
5	4.03	12.39	50.95	2.27	21.42	9.27	1.34	77026.18
6	2.69	13.13	39.54	2.41	20.64	8.94	1.32	77063.45
7	2.96	10.44	43.58	2.42	20.03	8.65	1.30	75682.53
8	2.39	11.25	60.85	1.20	20.69	9.56	1.29	73673.27
9	2.57	10.72	52.04	1.09	21.39	8.80	1.29	78787.76
10	3.10	10.67	53.28	1.30	19.37	9.23	1.30	78380.77
11	5.49	10.79	51.79	1.31	20.08	9.15	1.31	78717.94
12	2.53	10.75	55.88	1.21	18.70	9.46	1.31	76675.77
13	4.08	10.70	54.38	1.26	18.69	9.39	1.31	77322.57
14	3.98	10.73	55.08	1.24	18.36	9.40	1.31	75969.94
15	7.56	10.73	52.12	2.15	18.06	9.42	1.31	75633.10
16	6.25	10.87	45.36	2.44	17.68	9.39	1.30	75197.14
17	4.50	11.67	43.20	2.28	19.55	8.77	1.31	75892.59
18	6.50	12.21	42.02	3.15	19.94	8.58	1.31	76799.61
19	5.25	13.52	39.94	3.38	19.69	8.46	1.31	71019.60
20	5.34	13.68	41.14	3.09	20.10	7.91	1.31	72285.24
21	5.29	12.59	51.95	3.14	19.83	8.20	1.31	72999.24
22	8.56	11.73	56.92	3.05	18.57	8.77	1.31	75227.74
23	10.06	11.80	48.12	3.32	19.51	8.78	1.31	74854.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.22	11.80	48.56	2.27	19.81	8.97	1.31	75962.50
最大值	10.06	13.68	60.85	3.38	21.42	9.56	1.34	78787.76
發生時間	23	20	8	19	5	8		9
最小值	2.39	10.44	39.54	1.09	17.68	7.91	1.29	71019.60
發生時間	8	7	6	9	16	20		19
零點偏移(率)	-0.06 %	0.00 %	-0.01 %	0.00 %		-0.03	-0.01	-0.10 %
全幅偏移(率)	0.83 %	-0.24 %	1.95 %	0.40 %		0.24	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								