

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月23日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.96	12.42	50.71	2.91	17.25	11.24	1.18	74138.01
1	13.53	13.63	41.31	2.71	18.01	11.23	1.20	73857.06
2	12.84	12.42	41.89	2.62	17.86	11.43	1.20	72703.00
3	10.58	12.01	41.65	2.68	17.05	11.43	1.20	73640.59
4	7.90	11.91	39.65	2.24	17.52	11.32	1.21	74969.33
5	9.15	12.79	43.85	2.12	18.09	10.99	1.18	75078.63
6	10.69	12.72	48.26	2.35	17.07	11.26	1.18	75028.41
7	10.60	12.94	59.14	2.24	17.47	11.29	1.18	73778.60
8	7.21	12.27	41.00	1.43	17.35	11.32	1.18	73578.07
9	6.62	11.71	52.27	0.92	17.99	11.24	1.18	74035.19
10	6.33	11.66	51.17	0.94	17.83	11.16	1.18	74477.28
11	9.98	11.67	49.93	1.62	16.28	11.50	1.18	73024.41
12	8.77	11.55	55.15	1.39	16.90	11.36	1.18	73211.82
13	3.44	11.68	58.14	1.31	16.66	11.50	1.17	72590.69
14	1.69	11.53	56.54	0.83	18.82	11.10	1.18	73741.99
15	6.85	11.61	50.91	1.12	18.22	11.21	1.18	73535.42
16	8.26	11.69	52.59	2.55	17.59	11.06	1.18	74727.67
17	7.03	12.19	54.87	3.40	15.48	11.65	1.17	73048.37
18	7.79	11.41	58.76	2.11	18.19	11.08	1.16	75646.29
19	10.48	11.86	51.31	2.42	18.32	10.86	1.18	76739.27
20	12.54	11.99	50.77	3.54	16.06	11.58	1.18	73106.09
21	10.54	11.68	54.03	2.82	17.04	11.42	1.18	73286.50
22	13.76	11.84	57.35	2.78	17.80	11.26	1.18	74518.53
23	6.22	11.81	57.92	1.83	18.50	11.36	1.18	73114.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.91	12.04	50.80	2.12	17.47	11.29	1.18	73982.31
最大值	13.76	13.63	59.14	3.54	18.82	11.65	1.22	76739.27
發生時間	22	1	7	20	14	17		19
最小值	1.69	11.41	39.65	0.83	15.48	10.86	1.15	72590.69
發生時間	14	18	4	14	17	19		13
零點偏移(率)	-0.07 %	0.00 %	-0.01 %	-0.00 %		-0.08	-0.01	0.20 %
全幅偏移(率)	1.45 %	1.45 %	0.01 %	0.31 %		-0.17	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月23日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.51	12.19	39.28	2.35	17.54	10.41	0.98	77051.69
1	11.46	12.10	58.63	2.25	17.68	10.63	0.99	78086.93
2	9.96	12.08	55.21	3.10	16.73	10.73	0.98	77839.31
3	13.19	12.15	55.93	2.97	16.25	10.78	0.98	77503.91
4	12.11	11.96	60.48	3.27	16.31	10.73	0.99	78462.10
5	5.15	12.20	43.62	2.58	16.34	10.70	0.99	77397.01
6	10.13	10.74	51.64	1.60	18.49	10.17	0.96	79251.47
7	11.31	11.12	54.08	1.93	17.37	10.45	0.95	79336.00
8	12.30	11.75	48.84	1.82	16.90	10.45	0.95	78668.33
9	6.51	11.73	48.16	0.99	17.40	10.46	0.96	74655.72
10	7.82	11.34	47.17	1.57	17.13	10.16	0.97	76326.72
11	9.81	11.38	59.28	1.46	17.35	10.08	0.98	78480.32
12	6.81	11.95	55.59	1.59	16.86	10.58	0.97	78639.11
13	10.46	13.02	56.77	2.79	16.33	10.99	0.96	78008.13
14	5.02	12.16	60.16	1.62	16.55	10.96	0.95	75922.00
15	7.88	12.37	56.48	2.71	16.41	11.08	0.97	77440.50
16	9.41	11.94	49.52	2.32	16.42	10.87	0.97	80949.54
17	7.63	11.74	46.52	2.77	16.33	10.51	0.94	79707.52
18	10.45	11.78	48.77	2.76	17.03	10.53	0.94	82487.07
19	11.27	12.00	57.14	1.86	17.45	10.78	0.94	82360.19
20	8.24	12.15	50.69	2.60	17.21	10.78	0.94	82845.71
21	9.93	11.89	55.71	3.27	17.32	10.65	0.94	79434.27
22	10.06	11.72	49.44	2.80	17.42	10.38	0.93	80120.28
23	9.32	11.79	49.83	1.69	17.77	10.44	0.91	80065.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.41	11.89	52.46	2.28	17.02	10.60	0.96	78793.33
最大值	13.19	13.02	60.48	3.27	18.49	11.08	1.04	82845.71
發生時間	3	13	4	4	6	15		20
最小值	5.02	10.74	39.28	0.99	16.25	10.08	0.91	74655.72
發生時間	14	6	0	9	3	11		9
零點偏移(率)	-0.04 %	-0.01 %	-0.04 %	-0.01 %		-0.11	-0.01	0.00 %
全幅偏移(率)	1.66 %	-0.49 %	0.96 %	0.12 %		-0.08	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月23日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.36	11.17	62.49	2.00	16.01	9.72	1.30	71972.30
1	7.02	11.31	65.17	1.55	17.94	10.05	1.29	71456.92
2	7.90	11.45	47.99	3.21	17.52	10.16	1.31	72956.15
3	6.51	11.47	53.31	3.30	17.90	10.06	1.34	73517.35
4	7.00	11.37	54.32	3.34	17.58	10.13	1.35	73757.20
5	6.70	11.55	55.20	3.06	17.67	10.15	1.34	73865.65
6	5.49	14.93	56.55	3.04	17.04	10.32	1.32	72981.46
7	5.44	10.01	40.59	3.37	17.72	9.36	1.31	77513.85
8	9.12	11.57	53.08	2.24	17.26	10.05	1.34	74051.54
9	9.64	11.41	60.13	1.85	17.08	10.31	1.31	73767.84
10	5.18	11.50	54.13	2.12	14.77	12.01	1.33	67130.33
11	6.08	13.10	42.85	2.29	14.21	12.28	1.33	67148.26
12	6.27	13.91	45.72	2.59	14.01	12.21	1.28	67570.67
13	2.74	13.04	45.72	1.98	14.40	12.35	1.30	63205.49
14	3.17	12.25	44.56	1.94	14.55	12.38	1.33	63896.70
15	8.42	13.28	40.66	2.25	14.81	12.44	1.31	63947.87
16	5.24	11.40	53.27	3.06	17.26	10.26	1.30	74918.29
17	6.50	11.07	57.87	3.05	18.28	9.82	1.29	77513.89
18	6.19	11.47	61.54	2.93	17.44	10.32	1.29	75042.34
19	5.65	11.55	59.71	2.86	16.69	10.48	1.30	74317.96
20	9.62	11.36	57.80	2.88	17.65	10.17	1.31	76310.37
21	8.90	11.27	50.94	2.76	17.44	9.99	1.31	72858.91
22	9.64	10.96	49.54	2.75	17.62	9.55	1.31	72614.25
23	5.18	11.19	55.60	2.93	18.99	9.38	1.32	76305.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.87	11.82	52.86	2.64	16.74	10.58	1.31	72025.89
最大值	11.36	14.93	65.17	3.37	18.99	12.44	1.36	77513.89
發生時間	0	6	1	7	23	15		17
最小值	2.74	10.01	40.59	1.55	14.01	9.36	1.27	63205.49
發生時間	13	7	7	1	12	7		13
零點偏移(率)	-0.09 %	0.00 %	-0.01 %	-0.02 %		-0.12	-0.01	-0.10 %
全幅偏移(率)	2.09 %	0.12 %	-0.07 %	0.04 %		0.06	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								