

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 114年05月10日

報表日期: 114年05月10日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.10	1.94	65.79	1.71	19.15	9.72	1.01	91065.21
1	4.08	6.70	56.39	3.55	16.42	10.89	1.01	84227.11
2	1.29	2.42	64.57	2.53	17.64	10.65	1.02	85398.31
3	1.65	1.94	60.71	2.35	17.45	10.63	1.02	85304.86
4	0.65	3.98	62.31	2.63	17.20	10.57	1.02	86378.08
5	6.48	1.93	66.36	3.11	16.45	10.68	1.02	85967.74
6	5.08	3.04	58.35	2.43	17.03	10.70	1.05	80340.40
7	7.34	3.45	63.39	2.94	16.55	10.80	1.05	84315.68
8	3.25	1.98	59.64	1.86	17.88	10.47	1.04	85915.31
9	5.48	4.67	53.80	2.14	17.01	10.26	1.02	86771.25
10	2.42	3.01	63.82	2.59	14.95	11.39	1.02	80150.13
11	2.15	1.27	67.27	2.40	15.80	11.33	1.02	81055.55
12	5.45	7.12	60.79	2.33	17.10	10.70	1.02	81912.41
13	12.96	12.05	59.00	4.18	15.37	10.39	1.03	84293.48
14	6.40	2.05	56.32	1.90	15.54	10.78	1.03	80833.09
15	8.83	7.26	54.20	3.28	16.14	10.60	1.02	82780.68
16	11.01	5.71	54.70	6.01	16.46	10.67	1.02	85477.35
17	6.10	4.12	55.36	3.40	17.32	10.29	1.03	88595.68
18	0.93	0.59	60.75	2.52	16.42	10.88	1.03	84745.20
19	1.77	3.23	58.98	2.32	17.14	10.49	1.02	86972.36
20	0.68	3.79	62.86	2.77	15.82	11.14	1.03	82892.73
21	0.10	2.67	57.83	2.47	16.75	10.47	1.02	87540.70
22	0.15	3.53	60.84	3.73	16.00	10.59	1.02	87199.72
23	0.66	2.95	61.82	2.83	16.48	10.85	1.02	84856.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.25	3.81	60.24	2.83	16.67	10.66	1.02	84791.21
最 大 值	12.96	12.05	67.27	6.01	19.15	11.39	1.06	91065.21
發生時間	13	13	11	16	0	10		0
最 小 值	0.10	0.59	53.80	1.71	14.95	9.72	1.00	80150.13
發生時間	21	18	9	0	10	0		10
零點偏移(率)	-0.09 %	-0.02 %	-0.02 %	-0.02 %		-0.08		-0.10 %
全幅偏移(率)	0.14 %	-0.45 %	0.00 %	0.25 %		-0.03		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月10日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.80	5.36	59.34	2.31	17.39	10.03	1.44	84678.15
1	8.28	9.46	56.19	2.46	19.08	9.15	1.47	81151.46
2	5.39	5.76	61.54	1.99	16.52	10.07	1.48	77969.33
3	8.15	4.47	56.42	2.25	18.61	9.37	1.48	76991.91
4	6.49	6.27	57.16	1.52	17.74	9.48	1.49	76137.11
5	8.51	4.02	62.07	2.42	15.81	10.00	1.47	77509.21
6	10.46	8.63	58.50	3.01	17.99	9.64	1.48	75573.79
7	12.07	6.13	59.66	4.10	15.66	10.18	1.47	80369.65
8	10.28	3.36	58.72	2.60	16.29	10.11	1.45	76932.38
9	4.73	1.42	64.08	2.00	15.57	10.59	1.43	74149.15
10	5.16	5.53	64.21	2.55	15.48	10.89	1.57	73413.33
11	3.23	4.58	65.89	2.07	16.42	10.47	1.44	74941.98
12	1.32	2.75	47.77	2.12	15.99	10.45	1.46	73563.68
13	6.78	2.79	53.64	2.24	16.51	10.29	1.46	77691.57
14	9.42	1.28	55.08	2.44	15.92	10.40	1.46	80591.69
15	8.11	1.52	53.13	2.48	15.88	10.68	1.47	77101.10
16	6.85	2.24	52.59	2.24	16.53	10.26	1.43	79332.44
17	7.81	2.04	49.50	2.50	18.00	9.79	1.43	82313.73
18	7.69	1.37	53.51	2.15	17.56	10.05	1.45	80939.72
19	4.12	2.31	52.77	2.01	18.12	9.95	1.46	82329.28
20	2.24	4.74	47.23	1.83	17.14	9.90	1.46	82884.76
21	4.07	3.38	58.13	2.32	16.03	10.67	1.46	83677.41
22	4.38	1.14	59.95	2.16	16.77	10.84	1.47	82231.45
23	5.17	1.44	56.62	2.36	16.77	10.59	1.48	84343.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.73	3.83	56.82	2.34	16.82	10.16	1.46	79034.07
最 大 值	12.07	9.46	65.89	4.10	19.08	10.89	1.81	84678.15
發生時間	7	1	11	7	1	10		0
最 小 值	1.32	1.14	47.23	1.52	15.48	9.15	1.41	73413.33
發生時間	12	22	20	4	10	1		10
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	0.00 %		-0.01		-0.10 %
全幅偏移(率)	0.02 %	-0.51 %	-0.17 %	0.18 %		-0.10		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								