

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.70	11.91	45.93	2.88	14.22	11.87	1.27	79212.79
1	9.55	12.39	59.75	2.64	15.48	12.07	1.27	75829.15
2	11.81	12.10	43.66	3.14	14.21	11.99	1.25	77187.04
3	9.59	12.36	57.51	2.39	15.28	12.10	1.25	76929.94
4	12.11	12.13	48.03	2.55	15.42	11.91	1.25	78159.45
5	11.62	11.78	48.32	3.93	16.99	11.38	1.24	74619.70
6	9.62	12.46	56.90	2.14	15.60	12.08	1.22	76829.96
7	9.91	12.43	53.88	1.87	16.24	11.99	1.21	76736.87
8	9.26	11.67	58.72	1.53	17.03	11.29	1.21	82090.10
9	11.99	11.29	62.41	3.18	16.13	10.99	1.22	85506.08
10	9.79	11.84	49.60	2.28	15.47	11.57	1.23	80593.81
11	9.39	12.00	51.58	2.29	14.86	11.80	1.25	78723.18
12	8.81	12.27	55.67	3.21	12.67	12.19	1.25	76188.40
13	12.36	12.49	56.24	2.67	14.38	12.21	1.25	75248.15
14	7.89	11.86	54.28	1.63	16.09	11.55	1.25	79939.95
15	10.35	11.77	46.03	2.20	15.03	11.58	1.25	79726.86
16	12.11	12.04	50.91	3.11	14.84	11.84	1.25	78518.24
17	8.77	12.53	58.63	2.86	15.15	12.16	1.24	75127.13
18	10.81	11.75	54.36	2.35	16.79	11.31	1.23	81588.09
19	8.37	11.70	52.34	2.23	16.20	11.41	1.23	80982.37
20	9.69	11.70	58.00	1.94	17.37	11.23	1.23	81609.33
21	10.05	11.69	66.50	1.76	17.68	11.21	1.22	81552.72
22	9.12	11.36	51.61	2.68	15.58	11.18	1.22	83200.41
23	9.42	11.96	52.20	2.41	16.20	11.54	1.22	79824.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.17	11.98	53.88	2.49	15.62	11.69	1.24	78996.83
最大值	12.36	12.53	66.50	3.93	17.68	12.21	1.27	85506.08
發生時間	13	17	21	5	21	13		9
最小值	7.89	11.29	43.66	1.53	12.67	10.99	1.20	74619.70
發生時間	14	9	2	8	12	9		5
零點偏移(率)	-0.05 %	0.01 %	-0.04 %	-0.02 %		-0.04	-0.01	0.40 %
全幅偏移(率)	-2.85 %	-2.57 %	-0.93 %	-1.39 %		0.11	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.95	12.43	44.67	2.02	16.30	10.24	1.05	78148.06
1	9.49	12.84	48.27	2.36	16.12	10.63	1.05	77364.18
2	12.80	12.63	49.58	2.52	15.56	10.52	1.06	77467.65
3	9.53	12.29	41.61	1.82	16.23	10.13	1.04	74813.30
4	10.36	12.14	44.05	1.99	16.75	9.90	1.04	76363.82
5	11.86	12.34	33.81	2.47	15.87	10.20	1.04	76343.30
6	10.36	11.31	36.91	2.07	16.25	10.30	1.02	76932.07
7	13.14	11.16	38.83	2.40	17.19	9.91	1.02	77452.06
8	9.09	11.82	49.85	1.66	16.01	10.67	1.02	78401.72
9	11.91	11.70	52.70	1.54	16.25	10.53	1.03	79925.05
10	11.61	11.85	54.52	1.93	15.50	10.76	1.04	77478.22
11	9.25	12.08	55.80	1.84	14.94	10.98	1.07	74885.44
12	9.03	11.90	52.57	2.29	14.06	10.91	1.08	75243.78
13	10.52	11.95	53.09	1.79	14.83	10.89	1.06	74951.74
14	10.02	11.60	48.24	1.87	15.59	10.51	1.06	78615.03
15	10.27	11.55	48.77	1.72	15.86	10.40	1.06	77889.74
16	9.21	11.52	46.65	1.96	15.63	10.40	1.05	78331.62
17	11.64	11.48	50.20	1.60	16.94	10.23	1.04	79036.96
18	11.19	11.60	59.84	1.69	16.46	10.37	1.04	80396.34
19	9.65	11.78	54.20	1.80	15.91	10.58	1.04	78892.20
20	9.53	11.45	49.22	1.52	15.53	10.41	1.04	78254.72
21	11.84	11.60	49.96	1.65	15.42	10.55	1.04	77207.05
22	10.14	11.55	57.40	1.70	16.30	10.39	1.02	78601.66
23	11.09	11.54	60.75	1.57	16.31	10.36	1.02	80069.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.65	11.84	49.23	1.91	15.91	10.45	1.04	77627.74
最大值	13.14	12.84	60.75	2.52	17.19	10.98	1.09	80396.34
發生時間	7	1	23	2	7	11		18
最小值	9.03	11.16	33.81	1.52	14.06	9.90	1.02	74813.30
發生時間	12	7	5	20	12	4		3
零點偏移(率)	-0.11 %	-0.14 %	-0.04 %	-0.01 %		-0.07	-0.01	0.10 %
全幅偏移(率)	-1.98 %	-0.47 %	-0.06 %	-0.22 %		0.04	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.17	11.27	52.17	2.12	14.14	10.20	1.44	69396.84
1	8.48	11.73	49.66	1.84	16.69	9.94	1.44	69553.37
2	9.72	11.09	47.81	2.15	15.43	9.66	1.43	71270.65
3	8.35	11.47	53.13	2.02	15.57	10.38	1.43	68004.96
4	9.36	11.24	50.71	1.95	15.97	10.01	1.43	70870.67
5	9.51	12.21	53.73	1.98	15.30	10.18	1.43	71449.78
6	9.13	12.85	55.36	2.12	14.76	10.46	1.43	70310.19
7	11.43	13.29	55.13	3.11	16.39	9.99	1.43	76404.98
8	7.96	11.60	49.32	2.63	15.71	10.00	1.44	72214.73
9	11.79	11.62	49.18	2.99	15.22	9.92	1.43	72272.61
10	8.61	11.63	54.04	2.59	15.61	10.30	1.46	70801.53
11	9.03	11.27	53.38	2.66	15.88	9.96	1.44	73923.04
12	7.49	11.84	56.16	2.77	14.91	10.57	1.45	69722.28
13	10.35	11.94	51.12	2.74	15.21	10.34	1.45	71135.02
14	9.12	11.99	54.24	2.69	16.06	10.07	1.45	73926.92
15	10.95	11.91	50.26	2.66	16.58	9.89	1.45	74079.07
16	9.11	11.29	48.72	2.40	16.77	9.83	1.43	71986.15
17	8.61	11.24	46.29	2.37	17.21	9.49	1.45	74141.15
18	10.06	11.00	49.37	2.46	16.91	9.56	1.46	76253.46
19	7.88	11.90	59.33	2.85	14.88	10.72	1.46	73571.27
20	9.76	11.88	59.68	2.99	14.54	10.74	1.46	74017.56
21	9.90	11.76	60.75	2.83	15.15	10.56	1.47	74752.70
22	9.02	11.80	59.95	2.91	14.55	10.66	1.47	73492.74
23	9.64	11.70	57.85	2.75	15.33	10.52	1.46	74972.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.35	11.73	53.22	2.52	15.62	10.16	1.45	72438.52
最大值	11.79	13.29	60.75	3.11	17.21	10.74	1.48	76404.98
發生時間	9	7	21	7	17	20		7
最小值	7.49	11.00	46.29	1.84	14.14	9.49	1.43	68004.96
發生時間	12	18	17	1	0	17		3
零點偏移(率)	-0.03 %	0.01 %	-0.06 %	-0.01 %		-0.08	-0.01	0.10 %
全幅偏移(率)	-1.22 %	2.09 %	0.42 %	0.29 %		0.07	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								