

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.78	10.41	59.34	0.85	18.12	12.05	1.04	69760.52
1	9.17	9.46	59.22	0.77	20.02	11.15	1.03	74957.55
2	8.65	7.55	48.15	1.01	18.36	10.96	1.02	77837.70
3	7.77	8.19	59.64	0.49	18.89	11.11	1.02	76224.07
4	8.94	8.73	56.62	0.50	19.30	11.15	1.03	75953.98
5	9.43	6.87	49.83	0.77	18.36	11.16	1.05	84368.66
6	5.30	5.97	64.98	0.47	19.83	11.37	1.05	73707.09
7	7.60	6.17	55.73	0.45	19.93	10.97	1.05	76359.14
8	6.96	5.82	43.70	0.55	19.93	10.71	1.04	78599.75
9	8.64	6.83	31.80	1.09	17.37	11.46	1.02	75148.49
10	0.83	6.44	41.46	0.79	17.65	11.85	1.06	71911.52
11	4.37	7.98	49.85	1.05	18.16	11.65	1.07	71643.58
12	5.97	5.99	60.03	0.69	18.19	11.60	1.09	72535.47
13	8.58	5.71	46.25	1.08	17.63	11.31	1.10	75758.46
14	8.67	5.69	50.39	0.88	18.54	11.05	1.07	76650.30
15	6.77	5.86	47.98	1.25	17.72	11.34	1.06	75309.05
16	5.73	7.40	53.60	0.76	18.40	11.46	1.05	74046.58
17	3.96	8.50	66.53	0.38	19.22	11.45	1.04	73122.64
18	6.61	7.70	48.22	0.71	18.71	11.00	1.02	77314.58
19	7.28	8.28	49.80	1.35	17.79	11.20	1.03	76345.61
20	6.26	7.37	55.06	0.78	18.20	11.32	1.05	74888.09
21	7.19	7.58	54.42	0.54	18.50	11.21	1.05	75309.83
22	9.13	7.56	50.49	0.84	18.73	11.07	1.05	76455.96
23	6.05	7.79	61.72	0.41	18.95	11.49	1.06	73160.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.90	7.33	52.70	0.77	18.60	11.30	1.05	75307.05
最大值	9.43	10.41	66.53	1.35	20.02	12.05	1.12	84368.66
發生時間	5	0	17	19	1	0		5
最小值	0.83	5.69	31.80	0.38	17.37	10.71	1.02	69760.52
發生時間	10	14	9	17	9	8		0
零點偏移(率)	-0.15 %	-0.05 %	-0.01 %	-0.01 %		-0.21		0.00 %
全幅偏移(率)	0.00 %	-0.20 %	-0.02 %	0.08 %		0.00		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.63	10.22	56.37	2.03	16.44	10.55	0.99	83856.86
1	9.33	1.62	62.88	1.58	18.50	10.03	0.99	86782.50
2	9.35	2.93	55.22	2.01	16.87	10.34	0.99	86085.56
3	8.94	8.80	58.74	1.68	16.76	10.62	0.99	83384.53
4	9.02	5.66	48.33	1.42	17.21	10.49	0.99	84543.21
5	4.26	4.80	57.45	1.61	16.89	10.61	0.99	83216.25
6	0.10	5.74	51.83	1.15	17.11	11.71	0.99	80330.29
7	3.79	4.58	56.63	1.39	17.55	10.74	0.99	81016.77
8	5.84	3.94	55.61	1.44	17.52	10.43	0.99	83427.02
9	6.03	2.27	57.71	1.80	15.39	11.00	0.99	80677.03
10	6.03	5.01	57.99	1.72	16.00	10.95	1.02	80783.72
11	6.34	4.50	56.71	1.70	16.70	10.20	1.02	85616.12
12	6.85	4.81	58.04	2.29	15.22	10.87	1.01	82032.35
13	6.42	4.02	61.43	1.40	17.32	10.61	1.01	81588.00
14	6.37	5.92	49.68	2.78	15.32	10.86	1.01	82791.17
15	5.79	6.43	62.08	2.63	14.92	10.93	0.99	82871.86
16	1.78	2.61	59.80	1.62	16.51	10.32	1.00	85186.02
17	1.86	3.91	59.24	1.91	16.29	10.36	0.99	84580.98
18	3.06	3.97	64.55	1.94	16.46	10.50	0.98	83803.17
19	4.07	4.67	57.06	2.08	15.97	10.52	0.99	84504.31
20	5.94	5.12	58.52	2.43	15.82	10.51	0.98	84066.03
21	8.26	13.31	56.29	2.15	16.32	10.47	0.99	83948.14
22	8.92	2.44	60.34	2.68	15.89	10.62	0.99	83367.61
23	8.91	3.94	60.58	1.22	17.64	10.02	0.99	86573.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.12	5.05	57.63	1.86	16.53	10.59	0.99	83543.06
最大值	9.63	13.31	64.55	2.78	18.50	11.71	1.04	86782.50
發生時間	0	21	18	14	1	6		1
最小值	0.10	1.62	48.33	1.15	14.92	10.02	0.98	80330.29
發生時間	6	1	4	6	15	23		6
零點偏移(率)	-0.19 %	-0.01 %	-0.01 %	-0.01 %		0.03		-0.10 %
全幅偏移(率)	0.00 %	0.10 %	-0.08 %	0.14 %		-0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.06	2.56	54.10	1.71	15.37	11.19	0.98	76436.68
1	6.15	3.03	57.77	1.29	17.49	11.06	0.99	78716.54
2	8.15	9.96	51.30	2.49	14.15	11.05	0.98	77585.39
3	5.73	4.79	54.19	2.17	14.99	10.86	0.97	78697.72
4	8.01	5.32	50.47	2.10	16.79	10.35	0.97	80419.48
5	4.15	6.96	42.11	1.62	15.40	10.75	0.98	73405.54
6	3.25	7.04	50.34	1.55	15.68	10.87	0.97	74211.90
7	5.37	6.25	49.96	1.75	15.76	10.82	0.95	74028.49
8	5.04	6.49	51.49	1.44	16.47	10.61	0.95	77515.06
9	6.76	4.91	46.34	1.76	15.55	10.72	0.96	77899.39
10	6.07	3.81	51.15	1.66	15.98	10.59	0.96	79000.10
11	4.52	4.48	48.92	1.35	15.69	10.76	0.95	75851.45
12	4.60	4.60	66.10	1.32	16.80	11.09	0.95	75281.54
13	3.70	4.52	46.61	1.43	16.17	10.75	0.94	79903.18
14	5.64	4.15	57.25	1.54	15.99	11.01	0.96	77566.51
15	4.98	5.02	53.70	1.62	15.46	11.21	0.95	75029.95
16	4.90	4.75	62.05	1.27	17.53	10.53	0.95	78707.01
17	3.67	5.13	49.06	1.26	16.21	10.91	0.96	76073.64
18	1.11	5.21	52.48	0.99	16.73	10.78	0.97	78241.26
19	2.04	8.00	54.08	1.22	16.13	10.86	0.96	79246.06
20	3.76	11.74	45.35	1.44	15.58	10.74	0.94	78569.70
21	3.51	6.32	53.34	1.90	14.73	11.23	0.96	77045.31
22	3.15	3.49	49.87	1.32	16.17	10.84	0.96	78926.20
23	2.94	3.52	54.16	1.11	17.16	10.72	0.97	79325.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.72	5.50	52.17	1.55	16.00	10.85	0.96	77403.47
最大值	8.15	11.74	66.10	2.49	17.53	11.23	0.99	80419.48
發生時間	2	20	12	2	16	21		4
最小值	1.11	2.56	42.11	0.99	14.15	10.35	0.94	73405.54
發生時間	18	0	5	18	2	4		5
零點偏移(率)	-0.04 %	0.00 %	-0.03 %	0.00 %		0.02		0.00 %
全幅偏移(率)	0.04 %	-0.34 %	-0.50 %	0.14 %		0.21		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								