

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年05月02日

報表日期: 114年05月02日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.17	5.26	59.91	1.24	19.08	10.41	1.37	86230.87
1	5.75	5.80	59.65	1.58	19.62	10.68	1.39	82957.07
2	8.56	5.87	53.82	1.84	18.50	10.49	1.39	83413.81
3	9.69	7.33	45.98	2.46	16.52	10.62	1.39	79522.08
4	10.05	4.68	50.75	2.41	16.59	10.81	1.36	76888.10
5	8.44	6.10	44.54	2.23	16.59	10.49	1.34	83447.68
6	8.38	1.50	54.22	1.96	17.37	10.75	1.34	79583.93
7	9.08	2.41	57.48	1.86	17.64	10.60	1.35	80877.87
8	9.67	6.55	51.89	2.61	16.78	10.82	1.34	81523.24
9	7.58	5.43	53.96	2.18	16.96	10.79	1.35	82272.34
10	6.18	4.12	59.77	1.48	18.08	11.03	1.33	79218.11
11	6.75	6.48	52.05	2.78	15.95	11.16	1.34	81386.07
12	9.56	2.86	55.76	3.33	15.65	11.45	1.35	79320.92
13	8.30	6.70	53.99	3.49	14.77	11.39	1.35	78451.43
14	5.21	4.19	58.04	2.73	15.40	11.27	1.34	78088.64
15	5.75	4.29	54.91	2.77	14.97	11.22	1.34	80326.69
16	8.43	4.58	57.63	2.28	16.15	11.04	1.34	81831.22
17	7.02	1.94	48.93	1.53	17.13	10.67	1.35	82711.82
18	5.84	2.14	51.47	2.51	16.15	10.89	1.35	79698.96
19	1.95	1.36	55.43	2.19	15.76	11.27	1.34	77014.90
20	2.99	2.27	55.39	1.73	16.69	10.92	1.31	79892.53
21	5.19	2.95	51.89	2.97	14.98	10.86	1.31	79857.25
22	8.21	1.90	56.04	2.15	16.20	11.15	1.34	79836.83
23	8.70	1.76	62.41	1.14	17.53	11.04	1.35	82970.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.35	4.10	54.41	2.23	16.71	10.91	1.35	80721.79
最 大 值	10.05	7.33	62.41	3.49	19.62	11.45	1.39	86230.87
發生時間	4	3	23	13	1	12		0
最 小 值	1.95	1.36	44.54	1.14	14.77	10.41	1.30	76888.10
發生時間	19	19	5	23	13	0		4
零點偏移(率)	0.00 %	-0.05 %	-0.07 %	-0.00 %		-0.01		0.30 %
全幅偏移(率)	0.00 %	-0.65 %	-0.30 %	-0.12 %		0.14		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月02日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.69	3.57	56.60	2.26	16.27	11.00	1.06	79421.00
1	11.08	3.40	61.28	2.32	17.81	10.35	1.06	83911.16
2	11.73	1.92	50.46	2.99	15.94	10.55	1.04	81190.74
3	12.32	2.84	54.68	3.53	14.91	10.77	1.04	80311.89
4	11.26	6.15	55.62	2.94	16.62	10.52	1.05	81127.35
5	14.08	8.60	42.71	4.20	16.11	10.16	1.05	81935.52
6	5.80	7.90	42.52	5.37	15.19	10.82	1.05	90442.91
7	9.40	6.38	50.60	3.41	15.69	11.18	1.04	76716.95
8	10.91	2.34	58.59	2.46	15.88	10.97	1.05	81681.17
9	9.91	1.73	52.80	2.07	16.58	10.67	1.07	83871.24
10	8.32	1.68	51.73	1.69	17.10	10.66	1.06	84649.63
11	8.60	1.89	52.38	2.43	14.87	11.24	1.06	80617.66
12	11.60	10.86	59.08	3.10	13.31	11.53	1.06	79275.71
13	13.27	3.16	58.86	3.01	14.01	11.50	1.06	79385.96
14	9.81	1.34	65.66	2.45	14.83	11.29	1.06	81835.43
15	8.48	2.60	51.24	2.84	15.15	11.18	1.06	79409.63
16	11.43	6.63	55.22	3.24	15.23	10.96	1.06	83052.83
17	9.27	2.36	57.46	2.91	15.03	11.31	1.06	80689.04
18	6.33	1.98	58.56	2.91	14.84	11.17	1.05	79751.25
19	10.72	5.61	61.93	3.40	15.46	10.53	1.05	81381.54
20	10.42	1.46	60.77	3.59	14.88	10.44	1.06	81150.87
21	9.89	1.74	53.80	2.71	16.05	10.36	1.06	80799.95
22	10.71	1.97	60.35	2.87	15.79	10.75	1.06	81002.86
23	14.44	4.86	59.01	3.13	15.30	10.98	1.05	83814.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.39	3.87	55.50	2.99	15.54	10.87	1.06	81559.46
最 大 值	14.44	10.86	65.66	5.37	17.81	11.53	1.09	90442.91
發生時間	23	12	14	6	1	12		6
最 小 值	5.80	1.34	42.52	1.69	13.31	10.16	1.04	76716.95
發生時間	6	14	6	10	12	5		7
零點偏移(率)	-0.05 %	-0.01 %	-0.03 %	-0.06 %		-0.05		0.00 %
全幅偏移(率)	-1.02 %	0.14 %	0.04 %	0.14 %		-0.05		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年05月02日

報表日期: 114年05月02日

[illegible]