

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月26日

報表日期: 115年08月26日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.88	11.82	63.11	1.50	19.97	11.18	1.18	71584.20
1	8.95	11.21	61.64	1.17	22.09	10.31	1.15	76419.01
2	10.16	11.16	51.92	1.89	20.39	10.38	1.18	77523.07
3	9.55	11.39	54.02	2.14	19.45	10.71	1.17	76110.33
4	9.43	12.31	53.89	2.41	17.92	11.75	1.16	69665.93
5	6.93	13.38	62.37	1.67	19.52	11.28	1.16	73666.01
6	10.86	12.03	54.03	3.04	19.82	10.11	1.15	79041.16
7	11.51	12.62	46.12	2.42	19.29	10.52	1.15	76646.15
8	8.91	13.10	50.38	1.68	19.48	10.80	1.18	74990.04
9	9.38	12.72	52.31	1.68	19.74	10.82	1.18	74842.66
10	8.72	12.83	47.87	2.08	19.37	11.11	1.18	72299.29
11	9.58	12.71	57.11	1.87	19.66	10.73	1.15	75002.59
12	11.05	12.88	54.18	2.40	18.51	11.26	1.17	72374.05
13	6.69	12.82	57.69	1.76	18.87	11.14	1.18	71635.12
14	10.94	12.73	59.21	2.74	18.38	11.15	1.18	71695.50
15	8.97	12.53	55.68	2.38	17.90	11.01	1.18	73461.51
16	11.09	12.82	59.84	3.12	16.28	11.29	1.18	72737.01
17	10.39	13.47	56.76	3.57	15.59	11.74	1.17	70877.40
18	10.00	12.85	56.45	2.76	16.25	11.49	1.16	71576.96
19	7.54	12.92	59.11	2.18	16.97	11.47	1.16	71944.93
20	7.95	13.32	60.93	2.36	16.69	11.57	1.16	70721.31
21	6.32	13.10	62.50	2.15	16.96	11.57	1.17	71824.62
22	7.47	12.89	59.31	2.01	17.39	11.39	1.17	72537.17
23	10.08	12.80	64.67	2.03	18.27	11.20	1.17	72999.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.18	12.60	56.71	2.21	18.53	11.08	1.17	73423.99
最 大 值	11.51	13.47	64.67	3.57	22.09	11.75	1.18	79041.16
發生時間	7	17	23	17	1	4		6
最 小 值	6.32	11.16	46.12	1.17	15.59	10.11	1.14	69665.93
發生時間	21	2	7	1	17	6		4
零點偏移(率)	-0.04 %	-0.01 %	-0.05 %	-0.06 %		-0.03	-0.01	0.10 %
全幅偏移(率)	0.53 %	0.34 %	0.42 %	0.59 %		-0.20	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月26日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.32	13.12	58.40	0.56	18.47	11.48	1.02	77821.06
1	2.36	13.08	55.56	0.69	19.72	11.26	1.02	78480.98
2	5.42	12.50	53.77	1.08	19.15	10.75	1.01	83343.10
3	8.12	12.93	55.02	1.34	18.64	11.06	1.01	81697.08
4	2.72	12.84	60.41	1.10	18.76	11.23	1.00	80338.69
5	8.48	12.44	53.00	0.97	19.38	10.73	1.01	83374.89
6	8.22	12.55	43.30	1.88	17.79	10.74	0.97	80955.79
7	11.13	12.78	51.77	1.47	18.35	11.24	0.98	80340.17
8	4.96	13.03	49.80	1.25	18.79	11.01	1.00	81931.25
9	7.25	12.56	55.06	1.62	18.61	10.95	0.99	82551.30
10	9.15	13.42	54.63	1.07	18.14	11.77	1.00	76172.85
11	4.67	12.67	46.93	0.62	19.79	10.73	0.99	82673.93
12	7.75	12.89	48.91	1.34	18.74	10.53	0.98	84897.89
13	2.13	12.99	57.81	1.23	17.45	11.37	0.97	79568.14
14	7.45	12.64	56.01	0.73	18.19	11.19	0.97	80356.12
15	9.81	12.30	54.25	1.36	17.81	10.93	0.98	82519.06
16	7.94	12.74	60.56	1.51	16.43	11.43	0.99	80170.57
17	12.48	13.03	62.24	3.63	15.62	11.72	0.99	78169.01
18	5.68	12.84	59.27	2.15	16.69	11.49	0.99	79776.86
19	7.72	13.07	60.88	2.08	17.19	11.47	0.98	79899.53
20	8.57	13.02	64.45	2.92	16.53	11.58	0.99	79516.36
21	8.81	12.62	60.18	2.62	17.55	11.22	0.99	80952.84
22	8.26	12.31	64.08	2.53	18.37	10.79	1.00	83827.38
23	8.68	12.67	59.16	3.68	17.80	10.99	1.00	82615.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.38	12.79	56.06	1.64	18.08	11.15	0.99	80914.59
最 大 值	12.48	13.42	64.45	3.68	19.79	11.77	1.02	84897.89
發生時間	17	10	20	23	11	10		12
最 小 值	2.13	12.30	43.30	0.56	15.62	10.53	0.96	76172.85
發生時間	13	15	6	0	17	12		10
零點偏移(率)	-0.10 %	-0.01 %	-0.06 %	-0.02 %		0.00	-0.01	-0.10 %
全幅偏移(率)	-0.66 %	-0.34 %	0.23 %	0.58 %		-0.34	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月26日

報表日期: 115年08月26日

[illegible]