

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年11月13日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	9.29	2.57	60.55	0.48	17.58	11.10	1.09	85733.96
1	9.38	2.83	60.13	0.79	18.45	10.98	1.06	85940.02
2	12.28	2.56	56.57	1.55	16.59	11.07	1.07	87697.28
3	9.91	3.45	51.05	1.66	16.03	11.79	1.08	81552.37
4	8.01	3.74	55.51	0.76	17.30	11.84	1.09	80002.91
5	8.52	3.93	51.34	0.32	19.30	10.39	1.10	82631.42
6	2.69	1.48	62.70	0.42	17.63	11.08	1.10	86437.23
7	4.07	1.54	52.91	0.92	16.78	11.19	1.09	85761.59
8	4.99	2.20	48.34	1.04	17.33	11.28	1.07	84771.45
9	4.84	2.48	56.12	0.73	18.94	10.79	1.06	87274.00
10	4.83	2.09	69.19	0.84	19.17	10.75	1.06	87085.50
11	7.11	2.81	52.85	1.49	16.79	11.77	1.06	80602.91
12	7.29	2.71	47.91	0.97	17.81	11.79	1.06	79682.22
13	6.82	2.54	42.78	0.53	18.77	11.06	1.07	84741.40
14	6.77	4.08	37.00	2.27	16.95	11.17	1.07	85575.33
15	6.83	5.80	37.93	2.49	16.76	11.29	1.07	84313.22
16	6.93	1.39	43.85	0.91	17.06	11.42	1.06	83860.13
17	6.81	2.59	48.68	1.60	16.95	11.25	1.07	85027.20
18	6.96	4.06	42.76	1.96	17.22	11.42	1.06	83182.13
19	6.87	4.63	52.02	2.12	17.23	11.30	1.06	83917.91
20	6.91	3.10	54.34	2.43	16.82	11.42	1.06	82846.00
21	6.82	4.20	56.08	1.99	18.24	11.12	1.07	84427.30
22	6.64	3.25	62.81	2.00	19.32	10.71	1.07	86885.09
23	6.70	3.54	47.78	2.41	17.89	11.00	1.07	86054.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.01	3.07	52.13	1.36	17.62	11.21	1.07	84416.78
最 大 值	12.28	5.80	69.19	2.49	19.32	11.84	1.14	87697.28
發生時間	2	15	10	15	22	4		2
最 小 值	2.69	1.39	37.00	0.32	16.03	10.39	1.05	79682.22
發生時間	6	16	14	5	3	5		12
零點偏移(率)	0.00 %	-0.00 %	-0.06 %	-0.01 %		0.02		0.00 %
全幅偏移(率)	0.00 %	-0.16 %	-0.90 %	1.22 %		0.09		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年11月13日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	8.23	1.55	58.43	0.50	16.72	10.74	1.72	81673.78
1	8.12	1.72	54.81	0.51	16.88	10.56	1.69	82658.61
2	8.27	3.38	53.73	4.09	15.75	10.79	1.69	80263.07
3	8.46	1.73	52.84	0.90	16.14	11.04	1.70	76897.76
4	7.98	3.54	49.57	0.47	17.13	10.33	1.70	82072.74
5	8.09	2.42	48.45	0.51	17.23	10.44	1.71	83761.18
6	8.33	1.69	50.53	0.44	17.06	10.74	1.70	80792.49
7	5.74	3.26	50.84	1.68	14.45	11.11	1.72	79637.78
8	6.03	5.82	57.77	1.18	15.37	11.12	1.74	77701.77
9	5.94	1.74	55.15	0.45	16.31	10.91	1.71	79069.95
10	5.87	1.63	58.57	0.47	16.71	10.74	1.71	80116.26
11	7.63	2.06	58.85	0.48	16.75	10.84	1.74	79552.00
12	7.67	2.07	57.77	0.42	17.47	10.67	1.75	80671.22
13	7.54	2.74	56.06	0.56	17.44	10.46	1.73	82976.88
14	8.77	2.95	53.19	1.18	15.06	11.17	1.72	79311.70
15	3.46	7.08	54.20	1.57	14.24	11.48	1.72	76547.58
16	2.42	5.23	55.86	1.35	15.50	11.08	1.72	78573.59
17	6.08	4.99	55.55	1.00	15.75	11.05	1.71	78568.55
18	7.40	3.22	55.16	1.22	15.35	11.36	1.73	74856.94
19	7.39	7.76	50.48	1.04	16.08	10.77	1.75	80201.82
20	10.46	4.80	53.67	1.36	15.41	11.00	1.74	76249.40
21	9.32	1.99	55.30	0.76	16.35	10.58	1.76	80359.13
22	7.01	1.56	59.12	0.68	16.11	10.75	1.76	80367.12
23	6.98	3.23	60.97	0.75	16.13	10.69	1.76	80607.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.22	3.26	54.87	0.98	16.14	10.85	1.72	79728.71
最 大 值	10.46	7.76	60.97	4.09	17.47	11.48	1.76	83761.18
發生時間	20	19	23	2	12	15		5
最 小 值	2.42	1.55	48.45	0.42	14.24	10.33	1.69	74856.94
發生時間	16	0	5	12	15	4		18
零點偏移(率)	-0.06 %	0.00 %	-0.05 %	-0.01 %		-0.37		-0.10 %
全幅偏移(率)	0.02 %	-0.35 %	-0.48 %	0.27 %		0.18		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								