

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.73	9.92	50.05	1.16	17.57	11.72	1.03	77232.19
1	1.71	8.54	59.09	0.94	19.43	11.43	1.05	78033.81
2	1.20	12.23	54.46	1.75	16.72	11.95	1.03	75818.75
3	1.15	9.25	58.24	1.44	17.55	11.62	1.02	78085.03
4	2.89	9.95	52.04	1.93	16.29	11.77	1.03	78237.45
5	2.14	12.07	54.59	1.71	17.25	11.69	1.05	96339.37
6	0.79	11.41	54.12	1.35	17.34	11.74	1.06	77445.56
7	0.72	9.89	58.75	0.91	18.79	11.34	1.07	79503.15
8	4.25	7.23	53.45	2.13	16.98	11.78	1.06	77688.42
9	7.96	6.59	56.62	2.09	17.87	11.69	1.05	77370.33
10	6.60	5.93	58.64	1.47	18.56	11.58	1.05	77707.68
11	2.05	6.64	68.76	0.53	20.78	11.06	1.05	79969.13
12	1.51	6.60	51.44	1.11	18.45	11.43	1.05	79250.74
13	3.60	5.78	53.82	1.34	19.19	11.46	1.06	78668.90
14	5.34	5.06	56.52	0.98	19.73	10.58	1.06	83075.33
15	8.75	7.78	47.80	2.56	16.20	12.21	1.07	73248.13
16	8.35	9.55	54.22	1.91	17.81	11.62	1.07	78104.25
17	7.87	9.73	66.53	1.09	18.25	11.84	1.07	76275.09
18	9.28	12.70	48.19	1.48	17.95	11.52	1.07	78823.70
19	9.54	9.45	59.95	1.36	18.43	11.57	1.07	78152.87
20	7.64	10.19	53.60	1.68	17.17	12.02	1.06	75278.60
21	7.80	11.31	59.18	1.19	17.62	11.69	1.07	77885.27
22	7.92	11.91	54.08	1.64	16.88	11.98	1.07	75894.87
23	4.72	11.94	59.91	1.16	17.69	11.99	1.07	75171.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.85	9.24	56.00	1.45	17.94	11.64	1.06	78469.15
最大值	9.54	12.70	68.76	2.56	20.78	12.21	1.10	96339.37
發生時間	19	18	11	15	11	15		5
最小值	0.72	5.06	47.80	0.53	16.20	10.58	1.02	73248.13
發生時間	7	14	15	11	15	14		15
零點偏移(率)	-0.04 %	0.00 %	-0.01 %	0.00 %		-0.06		0.00 %
全幅偏移(率)	0.02 %	0.72 %	0.13 %	0.08 %		-0.15		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.11	6.00	54.10	2.02	16.65	10.61	0.99	83713.03
1	0.04	5.43	58.76	1.68	18.40	10.65	1.01	81801.35
2	0.08	7.23	60.31	2.49	15.66	10.92	1.02	81307.44
3	0.81	5.54	59.68	2.23	16.25	10.56	1.01	81453.05
4	1.55	6.76	53.43	2.36	16.83	10.44	1.01	83759.76
5	1.12	6.31	63.22	1.48	17.58	10.47	1.00	83554.48
6	2.54	3.72	55.75	1.14	18.13	10.35	1.01	88050.91
7	4.03	5.14	50.86	2.22	16.77	10.41	0.99	85176.52
8	0.50	4.29	57.68	1.48	16.97	10.70	1.00	82434.31
9	0.19	4.30	53.70	1.60	17.99	10.52	1.02	83241.77
10	0.22	4.42	63.93	1.52	18.16	10.56	1.02	82747.83
11	0.11	4.51	53.52	1.79	17.41	10.96	1.02	80478.96
12	0.10	5.84	59.71	1.30	18.60	10.40	1.02	83874.49
13	0.09	7.61	46.38	2.20	16.46	10.82	0.99	82948.87
14	1.93	4.56	54.90	2.22	15.81	10.85	0.99	81287.02
15	2.07	4.94	51.72	2.17	15.33	11.00	1.01	80580.58
16	4.01	7.90	55.54	1.73	16.48	11.54	1.02	75705.83
17	3.61	8.57	59.89	1.21	17.88	10.56	1.00	81912.03
18	3.58	6.37	63.17	1.14	17.60	10.46	1.00	81936.80
19	3.81	7.71	66.50	1.03	18.22	10.63	1.00	81989.27
20	4.40	8.38	54.91	1.21	18.72	9.54	1.01	88708.26
21	3.52	5.24	58.11	1.54	15.48	10.39	1.01	80120.76
22	3.56	6.92	65.02	0.97	18.20	10.34	1.00	83463.98
23	2.16	7.75	58.09	0.80	18.01	9.87	1.00	83380.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	1.84	6.06	57.45	1.65	17.23	10.56	1.01	82651.15
最大值	4.40	8.57	66.50	2.49	18.72	11.54	1.05	88708.26
發生時間	20	17	19	2	20	16		20
最小值	0.04	3.72	46.38	0.80	15.33	9.54	0.99	75705.83
發生時間	1	6	13	23	15	20		16
零點偏移(率)	-0.06 %	-0.04 %	-0.22 %	-0.01 %		-0.01		-0.10 %
全幅偏移(率)	0.00 %	-0.24 %	0.09 %	0.17 %		-0.48		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.15	7.99	48.12	1.45	16.21	10.75	0.99	78010.49
1	0.02	7.24	56.34	1.23	17.39	10.93	1.01	76855.67
2	0.02	8.37	56.75	1.51	16.04	10.96	0.99	76436.66
3	0.29	10.40	55.33	1.70	15.76	10.95	0.99	76304.29
4	1.13	13.47	59.41	1.75	15.91	10.93	0.99	74747.20
5	1.24	11.77	47.48	1.50	16.50	10.34	0.99	75620.25
6	1.95	11.92	50.32	1.58	16.62	10.75	0.99	74258.03
7	2.16	7.56	50.54	1.62	16.75	10.38	0.99	75825.68
8	3.82	5.19	52.76	2.04	15.78	10.76	0.99	75362.86
9	1.52	4.62	57.92	1.58	16.06	10.92	0.99	75520.43
10	1.32	4.36	49.35	1.33	16.81	10.76	0.98	76598.58
11	0.90	8.88	63.78	1.58	16.15	11.64	0.98	71665.01
12	0.26	5.13	51.40	1.23	16.86	11.28	0.99	78638.71
13	0.21	5.02	59.13	1.17	17.23	11.32	0.98	77604.16
14	1.41	5.22	54.14	1.99	14.70	11.40	0.97	75898.73
15	2.18	4.75	65.90	1.80	15.78	11.40	0.99	75947.86
16	3.30	8.28	59.27	1.59	16.90	10.84	0.99	82207.08
17	5.09	8.51	52.90	1.73	15.43	11.21	1.00	80784.84
18	6.06	9.12	58.27	1.99	15.66	11.25	1.00	80368.44
19	4.06	9.83	63.73	1.25	18.27	10.83	0.99	81330.98
20	7.60	9.49	64.25	1.75	16.12	10.86	0.99	80910.84
21	6.10	10.23	59.72	1.40	16.28	10.80	0.98	79132.44
22	7.33	10.70	42.96	1.26	17.63	10.14	0.99	83467.05
23	4.25	7.18	49.93	1.43	17.63	9.42	0.97	77608.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.60	8.13	55.40	1.56	16.44	10.87	0.99	77546.03
最大值	7.60	13.47	65.90	2.04	18.27	11.64	1.02	83467.05
發生時間	20	4	15	8	19	11		22
最小值	0.02	4.36	42.96	1.17	14.70	9.42	0.95	71665.01
發生時間	1	10	22	13	14	23		11
零點偏移(率)	-0.04 %	-0.01 %	-0.00 %	-0.02 %		-0.01		0.00 %
全幅偏移(率)	0.20 %	0.78 %	-0.67 %	0.09 %		0.02		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								