

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月27日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.32	4.16	49.38	1.51	17.87	10.26	1.27	81806.78
1	8.93	5.22	50.67	2.27	18.27	10.41	1.29	80618.63
2	13.61	5.73	46.41	3.40	16.43	10.33	1.29	80251.53
3	6.81	6.19	49.39	2.28	16.78	10.38	1.29	79827.69
4	7.72	4.20	49.80	2.44	16.31	10.45	1.27	78679.18
5	3.44	5.56	52.30	1.68	18.40	9.81	1.24	80455.69
6	10.24	3.64	59.12	1.85	19.00	9.84	1.24	79709.42
7	12.82	6.64	63.38	3.02	16.50	10.23	1.25	78950.89
8	10.54	3.60	56.05	2.78	16.96	10.11	1.24	79420.77
9	9.84	4.68	60.65	2.63	16.41	10.32	1.25	80861.51
10	6.97	7.83	54.22	2.45	15.57	10.74	1.24	78728.17
11	7.34	3.69	54.66	2.07	15.97	11.12	1.25	77822.05
12	8.53	4.06	54.73	2.59	14.97	11.77	1.24	75448.94
13	3.34	2.81	57.77	1.92	16.26	11.64	1.25	76250.74
14	7.23	5.90	53.04	1.89	17.05	10.55	1.25	81552.03
15	8.41	3.30	57.53	2.35	16.55	10.91	1.25	79781.39
16	10.71	3.23	51.68	2.31	17.67	10.31	1.24	82067.51
17	8.99	3.32	58.62	1.89	18.68	9.79	1.25	80340.23
18	7.38	2.44	55.59	1.39	19.73	9.50	1.25	82101.74
19	9.61	4.71	43.41	1.64	19.20	9.55	1.25	82158.76
20	8.70	5.08	32.29	1.68	18.40	9.54	1.23	81848.42
21	7.58	4.97	32.86	1.81	17.30	9.72	1.23	79127.15
22	10.70	6.12	54.18	1.98	17.60	10.34	1.25	80402.88
23	7.20	4.64	57.33	1.52	17.90	10.35	1.25	80449.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.42	4.65	52.29	2.14	17.32	10.33	1.25	79944.24
最 大 值	13.61	7.83	63.38	3.40	19.73	11.77	1.29	82158.76
發生時間	2	10	7	2	18	12		19
最 小 值	3.34	2.44	32.29	1.39	14.97	9.50	1.22	75448.94
發生時間	13	18	20	18	12	18		12
零點偏移(率)	-0.04 %	-0.01 %	-0.04 %	-0.00 %		-0.01		0.20 %
全幅偏移(率)	0.00 %	0.49 %	-0.48 %	0.28 %		-0.11		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年03月27日

報表日期: 114年03月27日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.95	3.28	57.31	2.92	15.33	10.39	1.50	78793.84
1	12.77	4.23	59.98	2.84	16.28	10.32	1.51	79900.91
2	12.82	6.40	56.80	2.48	16.65	9.86	1.52	80373.37
3	7.47	8.59	52.89	2.84	15.00	9.88	1.51	77070.61
4	8.17	7.36	48.85	2.62	15.12	9.94	1.49	76412.29
5	7.91	3.72	48.57	2.25	15.64	9.81	1.50	77423.24
6	12.20	3.23	57.40	2.58	15.75	9.98	1.52	79070.86
7	12.10	5.64	49.23	2.82	15.23	9.78	1.52	79176.33
8	7.11	1.80	62.14	1.73	16.35	9.91	1.54	77718.51
9	10.86	9.65	54.65	2.20	15.32	9.87	1.54	80388.27
10	7.42	10.92	51.48	1.79	15.33	10.21	1.55	77830.10
11	7.45	5.70	58.47	2.53	14.60	10.61	1.52	78039.99
12	12.23	5.36	63.32	2.93	14.08	11.39	1.53	74992.04
13	10.63	10.12	57.30	2.76	14.29	11.42	1.51	75111.93
14	8.48	7.53	57.59	1.81	16.04	10.36	1.52	80354.29
15	6.43	8.80	55.28	1.31	16.57	9.86	1.50	82215.24
16	5.91	4.83	42.69	1.08	16.87	9.34	1.52	80650.60
17	5.27	1.88	52.65	1.01	18.54	9.14	1.53	78689.39
18	8.75	1.64	60.79	1.30	18.13	10.01	1.51	81428.92
19	8.46	5.53	57.23	1.24	17.44	10.19	1.52	81600.58
20	10.93	5.36	46.51	1.96	15.47	10.07	1.54	81885.92
21	11.19	2.38	54.99	2.03	15.80	9.93	1.55	82837.64
22	12.40	3.71	59.09	1.74	16.74	10.12	1.53	82748.35
23	9.33	4.34	59.63	1.72	16.08	10.38	1.52	79717.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.51	5.50	55.20	2.10	15.94	10.12	1.52	79351.29
最 大 值	12.82	10.92	63.32	2.93	18.54	11.42	1.57	82837.64
發生時間	2	10	12	12	17	13		21
最 小 值	5.27	1.64	42.69	1.01	14.08	9.14	1.48	74992.04
發生時間	17	18	16	17	12	17		12
零點偏移(率)	-0.06 %	-0.00 %	-0.06 %	-0.01 %		0.01		-0.10 %
全幅偏移(率)	-0.48 %	-0.85 %	-0.14 %	-0.09 %		0.23		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								