

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月26日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.00	7.72	62.75	0.76	17.73	11.89	1.02	70031.49
1	2.30	7.50	56.89	0.71	19.69	10.84	1.02	76542.38
2	6.43	9.19	46.85	1.90	16.38	11.60	1.01	73260.77
3	2.45	8.65	60.71	1.22	17.10	11.79	0.99	71405.11
4	8.12	9.34	55.86	1.70	16.71	11.45	0.99	74103.57
5	8.82	9.75	46.76	1.50	17.87	11.41	0.99	70553.19
6	3.75	8.89	59.15	0.74	18.26	11.70	0.99	71366.18
7	3.43	8.56	59.87	0.70	18.01	11.49	0.99	72906.11
8	5.08	6.85	53.00	1.09	16.59	12.09	1.02	69507.39
9	3.42	5.89	64.59	0.52	17.90	11.51	1.01	72892.24
10	4.02	6.39	51.28	0.87	17.49	11.53	0.99	72411.08
11	8.79	6.62	47.58	1.39	17.65	11.31	1.02	73973.29
12	2.62	2.71	59.75	0.61	18.65	11.48	1.02	71749.05
13	3.00	5.66	54.05	0.85	18.93	11.38	1.01	72224.93
14	5.34	8.87	42.08	1.80	16.38	11.69	1.01	71925.26
15	0.71	3.78	55.98	1.01	17.11	12.19	1.03	68226.43
16	1.13	5.80	47.53	0.76	17.77	11.41	1.00	73125.87
17	6.71	12.37	42.51	2.19	15.57	12.00	0.99	70102.24
18	8.85	6.62	52.87	1.28	17.40	11.69	0.99	71563.87
19	4.86	7.89	54.85	1.05	16.96	11.81	1.02	71546.34
20	1.64	7.73	58.22	0.95	17.55	11.63	1.02	72389.35
21	2.81	7.28	59.34	0.51	18.76	11.24	1.02	74779.11
22	4.34	8.00	51.39	0.85	17.87	11.37	1.02	74262.10
23	4.26	8.60	63.86	0.55	18.98	11.70	0.99	71332.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.45	7.53	54.49	1.06	17.64	11.59	1.01	72174.16
最大值	8.85	12.37	64.59	2.19	19.69	12.19	1.05	76542.38
發生時間	18	17	9	17	1	15		1
最小值	0.71	2.71	42.08	0.51	15.57	10.84	0.98	68226.43
發生時間	15	12	14	21	17	1		15
零點偏移(率)	-0.04 %	0.00 %	-0.13 %	0.00 %		-0.03		0.00 %
全幅偏移(率)	0.02 %	0.96 %	0.12 %	0.31 %		0.06		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月26日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.23	4.97	44.88	1.26	18.08	10.39	0.99	85175.00
1	0.10	5.18	46.95	2.11	18.18	10.46	0.99	84106.73
2	0.96	5.57	55.53	2.78	15.62	10.82	1.00	83595.69
3	2.24	3.85	43.75	1.84	17.84	10.17	1.00	86858.41
4	5.17	3.57	44.77	2.02	17.31	10.25	1.00	86306.73
5	6.06	9.55	50.79	1.89	17.32	10.67	1.02	83169.15
6	1.08	9.04	41.35	2.11	17.90	10.16	1.02	86643.75
7	0.92	5.21	52.04	1.52	17.65	10.81	1.02	81325.41
8	0.37	5.11	43.99	1.52	18.28	10.25	1.02	84890.13
9	0.63	7.24	49.86	1.39	17.86	10.25	1.02	85776.93
10	0.86	4.01	47.02	2.21	17.85	10.13	1.04	86779.55
11	2.31	3.68	46.59	2.01	17.48	10.51	1.04	83722.59
12	1.12	3.65	38.39	2.13	18.16	10.46	1.02	85428.44
13	2.47	3.85	47.79	2.54	16.33	10.63	1.02	85116.97
14	3.25	3.05	43.28	1.91	17.63	10.18	1.02	86882.98
15	7.64	8.04	45.73	2.45	17.42	10.19	1.02	85964.88
16	9.54	5.59	43.38	1.65	18.66	9.82	1.04	86928.59
17	8.58	8.77	47.68	1.93	17.40	10.18	1.01	86399.88
18	5.37	4.38	54.92	1.12	18.54	10.55	1.00	82768.56
19	4.90	6.69	43.71	1.34	18.77	10.04	1.00	86508.89
20	5.59	9.75	44.06	2.08	17.40	10.14	1.01	86610.01
21	9.22	7.27	60.14	1.71	17.95	10.04	1.00	86993.73
22	8.14	8.66	41.75	1.80	18.13	10.12	0.99	85957.21
23	4.41	4.81	45.98	1.28	18.81	9.93	1.00	86872.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.80	5.90	46.85	1.86	17.77	10.30	1.01	85449.29
最大值	9.54	9.75	60.14	2.78	18.81	10.82	1.05	86993.73
發生時間	16	20	21	2	23	2		21
最小值	0.10	3.05	38.39	1.12	15.62	9.82	0.99	81325.41
發生時間	1	14	12	18	2	16		7
零點偏移(率)	-0.04 %	-0.02 %	-0.11 %	0.00 %		0.02		-0.20 %
全幅偏移(率)	0.04 %	0.71 %	0.40 %	0.21 %		0.07		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月26日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.93	5.52	55.91	1.23	16.34	10.70	0.95	78321.14
1	1.39	5.27	43.74	0.85	17.50	10.58	0.96	80377.94
2	1.74	4.91	48.00	1.62	15.12	10.88	0.94	77412.54
3	3.14	5.15	50.57	1.69	14.91	10.95	0.93	75835.14
4	3.09	5.96	44.86	1.56	15.37	10.54	0.92	78242.39
5	7.30	7.17	51.18	1.89	14.99	10.87	0.94	76663.92
6	4.95	6.63	48.24	1.20	16.64	10.40	0.94	80262.38
7	4.88	8.37	43.73	1.27	15.78	10.41	0.96	79767.14
8	1.52	5.21	49.54	1.52	14.93	10.84	0.94	77666.11
9	1.22	5.75	53.81	1.51	15.22	10.89	0.94	78783.16
10	1.46	7.10	50.46	1.29	16.07	10.79	0.97	79313.36
11	2.61	6.51	52.67	2.00	14.33	11.12	0.97	77407.82
12	1.52	4.45	47.10	0.95	16.67	10.33	0.92	79523.01
13	0.48	2.00	49.85	0.88	17.16	10.31	0.91	79241.74
14	1.95	4.99	48.00	1.22	16.01	10.46	0.91	77572.38
15	6.21	3.96	45.37	1.29	16.89	10.34	0.93	77380.90
16	5.38	13.40	44.95	1.44	16.06	10.02	0.96	79347.43
17	7.54	5.82	43.33	1.81	15.06	10.44	0.93	76810.02
18	7.79	11.33	45.50	2.12	14.06	10.75	0.91	72555.36
19	5.89	5.44	49.92	1.53	15.33	10.63	0.95	76800.81
20	5.27	10.59	44.02	1.31	16.13	10.25	0.96	79569.51
21	6.01	4.85	49.07	1.26	15.83	10.46	0.95	79323.46
22	2.59	7.62	50.95	0.98	16.77	10.27	0.96	79561.52
23	5.01	11.56	45.05	1.42	15.53	10.72	0.94	76786.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.91	6.65	48.16	1.41	15.78	10.58	0.94	78105.26
最大值	7.79	13.40	55.91	2.12	17.50	11.12	1.00	80377.94
發生時間	18	16	0	18	1	11		1
最小值	0.48	2.00	43.33	0.85	14.06	10.02	0.89	72555.36
發生時間	13	13	17	1	18	16		18
零點偏移(率)	-0.02 %	-0.02 %	-0.06 %	-0.02 %		0.01		-0.10 %
全幅偏移(率)	0.75 %	0.11 %	-0.78 %	0.26 %		0.41		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								