

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年03月26日

報表日期: 114年03月26日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.59	3.37	56.48	2.43	20.24	9.38	1.29	84933.78
1	9.93	5.79	54.37	2.63	20.64	9.37	1.29	84108.70
2	10.99	5.27	55.70	3.01	18.71	9.50	1.29	82866.87
3	8.82	5.35	52.02	3.18	16.60	9.97	1.27	79733.72
4	5.26	3.25	64.15	3.03	17.05	10.22	1.24	77889.58
5	8.12	2.01	48.10	1.74	17.90	10.08	1.23	82269.87
6	9.91	3.69	54.30	1.60	19.18	9.74	1.25	83751.16
7	11.25	5.16	50.11	2.12	18.47	9.95	1.25	82615.62
8	7.72	4.50	53.49	1.84	18.14	10.02	1.26	82121.92
9	7.61	4.93	53.87	1.38	18.67	9.74	1.29	82491.51
10	11.46	8.19	46.01	2.25	17.44	10.14	1.29	80868.35
11	8.28	5.28	50.73	1.84	18.22	10.15	1.28	81174.73
12	8.07	11.25	52.80	2.37	16.78	10.42	1.29	78545.74
13	7.97	15.23	45.79	2.68	16.49	10.29	1.26	76104.61
14	7.95	2.68	50.63	2.14	16.69	10.43	1.26	76248.06
15	8.67	4.24	53.03	1.44	17.69	10.34	1.26	78524.72
16	8.84	12.44	45.05	2.14	17.66	9.63	1.26	78869.86
17	8.82	5.33	37.38	2.10	18.85	9.17	1.28	79866.85
18	8.57	2.99	34.45	1.25	20.76	9.04	1.25	80971.01
19	10.40	6.61	34.34	1.71	19.76	9.12	1.25	83739.38
20	11.20	3.22	46.76	2.29	17.68	9.63	1.26	80732.69
21	10.11	4.42	44.22	2.33	17.45	9.83	1.25	78265.73
22	12.15	4.90	48.30	2.82	16.66	10.42	1.26	78572.97
23	8.71	3.80	48.43	1.95	17.82	10.25	1.27	80646.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.18	5.58	49.19	2.18	18.15	9.87	1.27	80663.09
最 大 值	12.15	15.23	64.15	3.18	20.76	10.43	1.30	84933.78
發生時間	22	13	4	3	18	14		0
最 小 值	5.26	2.01	34.34	1.25	16.49	9.04	1.23	76104.61
發生時間	4	5	19	18	13	18		13
零點偏移(率)	-0.23 %	0.01 %	-0.16 %	-0.01 %		-0.01		0.30 %
全幅偏移(率)	0.00 %	-0.28 %	0.32 %	-0.50 %		-0.10		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月26日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.32	3.12	54.25	1.89	17.65	9.76	1.06	86543.10
1	6.66	4.38	62.08	1.62	18.97	9.82	1.09	85277.03
2	9.74	5.59	56.45	2.64	16.67	9.87	1.09	86037.61
3	9.41	3.66	63.28	2.73	15.38	10.12	1.09	83263.10
4	8.84	4.38	58.89	2.96	14.42	10.36	1.07	81571.01
5	8.78	3.47	58.03	2.74	15.18	10.21	1.06	82644.39
6	4.75	1.46	51.06	1.92	16.65	10.01	1.03	84575.80
7	9.60	2.59	59.08	2.95	15.28	10.19	1.04	82211.38
8	6.30	2.11	56.38	2.14	16.17	10.38	1.06	82876.74
9	10.35	2.87	51.37	2.42	15.60	10.78	1.06	81484.92
10	0.72	2.75	48.09	1.83	15.50	10.47	1.06	81541.81
11	0.36	8.47	54.63	2.01	15.97	10.37	1.06	81323.21
12	2.66	7.87	55.95	2.14	14.46	10.59	1.05	80049.30
13	5.23	3.06	57.58	2.17	15.51	10.77	1.05	82423.77
14	14.54	7.95	54.25	4.21	15.11	10.91	1.04	81442.07
15	12.45	6.64	58.32	3.36	15.20	11.16	1.04	81458.56
16	5.93	6.96	49.09	3.41	16.56	10.48	1.02	79492.95
17	5.54	12.36	39.08	1.86	20.03	8.95	1.02	85145.84
18	10.27	3.33	32.91	3.01	18.02	10.27	1.04	82967.41
19	13.98	4.60	51.59	4.20	16.17	10.69	1.05	85559.89
20	13.15	5.01	50.48	1.97	15.43	11.04	1.06	82087.84
21	8.60	10.58	44.98	2.04	16.29	10.59	1.05	81925.79
22	14.35	3.35	54.90	2.90	15.12	11.37	1.04	84147.40
23	12.73	4.64	58.57	3.21	14.92	11.37	1.02	83319.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.39	5.05	53.39	2.60	16.09	10.44	1.05	82890.43
最 大 值	14.54	12.36	63.28	4.21	20.03	11.37	1.09	86543.10
發生時間	14	17	3	14	17	22		0
最 小 值	0.36	1.46	32.91	1.62	14.42	8.95	1.00	79492.95
發生時間	11	6	18	1	4	17		16
零點偏移(率)	0.00 %	-0.11 %	-0.49 %	0.00 %		0.01		-0.10 %
全幅偏移(率)	0.14 %	-0.17 %	1.05 %	-0.26 %		0.11		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月26日

[illegible]