

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月18日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.20	2.25	60.08	2.57	15.45	12.37	1.45	69392.94
1	7.12	2.18	62.66	2.50	16.11	12.10	1.44	70786.62
2	8.59	4.59	51.17	3.92	12.89	12.65	1.42	69829.84
3	7.31	5.10	59.54	3.93	13.49	12.80	1.40	67839.44
4	4.75	2.95	60.57	2.64	15.11	12.18	1.40	71417.38
5	1.55	2.99	53.68	2.48	14.87	12.03	1.43	69472.05
6	3.32	3.55	57.16	3.26	13.75	12.42	1.46	70254.71
7	8.41	3.17	67.94	3.03	14.38	12.32	1.46	70415.47
8	9.20	5.67	52.31	3.52	13.68	12.24	1.46	71279.22
9	10.16	7.24	55.29	3.61	14.22	12.33	1.45	70518.46
10	9.56	3.85	60.16	3.39	14.82	12.42	1.44	68384.40
11	9.88	3.54	57.50	3.30	15.09	11.97	1.44	72362.75
12	6.01	6.67	54.49	3.63	14.33	12.70	1.45	67048.83
13	4.13	3.52	62.05	2.91	14.91	12.08	1.43	71312.74
14	6.64	4.07	59.32	3.74	14.56	12.31	1.46	69669.42
15	11.28	5.44	63.27	4.04	14.59	12.42	1.46	68519.69
16	10.63	19.46	47.59	4.65	13.34	12.33	1.46	70613.90
17	9.25	8.70	57.38	4.13	13.00	12.52	1.44	69180.01
18	6.85	5.11	62.54	4.02	13.26	12.64	1.44	68451.10
19	4.70	6.23	54.02	3.82	13.54	12.63	1.47	68151.99
20	6.12	6.15	52.81	3.83	13.46	12.45	1.42	69909.64
21	3.78	3.63	61.30	3.15	14.41	12.37	1.41	69622.17
22	4.30	3.75	63.06	3.11	14.88	12.59	1.45	67674.86
23	4.92	3.33	61.97	3.01	14.98	12.40	1.46	69259.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.86	5.13	58.24	3.42	14.30	12.39	1.44	69640.28
最大值	11.28	19.46	67.94	4.65	16.11	12.80	1.48	72362.75
發生時間	15	16	7	16	1	3		11
最小值	1.55	2.18	47.59	2.48	12.89	11.97	1.39	67048.83
發生時間	5	1	16	5	2	11		12
零點偏移(率)	-0.30 %	-0.05 %	-0.03 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	-2.00 %	-0.66 %	-0.33 %	0.55 %		0.19	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月18日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.57	5.08	57.94	1.57	16.33	10.91	1.72	82768.95
1	8.40	4.95	61.21	1.85	15.99	11.12	1.73	83611.39
2	8.70	8.01	53.94	2.91	13.62	11.35	1.74	78815.38
3	8.01	2.72	59.26	2.15	14.82	11.25	1.76	77809.36
4	9.01	3.01	55.95	1.97	15.27	11.15	1.76	80988.88
5	7.91	4.47	58.25	1.95	15.43	11.20	1.74	81504.02
6	8.83	3.04	62.02	1.92	16.25	10.92	1.72	80620.35
7	7.17	5.52	57.53	1.67	16.51	10.96	1.73	79196.07
8	8.95	8.76	57.07	2.61	14.21	11.59	1.71	75239.92
9	8.13	2.65	54.74	2.42	15.56	11.00	1.72	79956.97
10	7.90	2.36	52.57	1.92	16.29	10.85	1.74	81899.71
11	4.83	2.00	58.76	1.60	16.33	10.80	1.76	82579.42
12	2.44	2.32	65.53	1.61	16.44	11.40	1.76	79170.46
13	7.63	3.81	49.38	1.79	15.74	10.74	1.76	84760.44
14	7.86	4.07	59.10	2.25	14.72	10.85	1.79	82684.00
15	12.71	4.00	54.67	2.43	15.17	10.83	1.76	83200.70
16	10.16	7.12	57.97	2.91	14.41	11.07	1.75	82758.09
17	9.81	2.49	58.75	1.97	15.79	10.86	1.73	84288.90
18	9.77	1.98	63.04	2.08	15.12	11.15	1.73	83250.05
19	5.45	2.00	61.34	1.80	15.50	11.07	1.74	84258.82
20	11.79	4.79	60.40	2.45	14.85	10.98	1.72	84314.48
21	7.57	2.70	56.47	1.85	15.49	11.06	1.73	82232.24
22	5.43	3.41	50.08	1.52	16.70	10.48	1.73	84935.50
23	3.43	2.11	57.76	1.28	17.38	10.52	1.73	84335.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.89	3.89	57.66	2.02	15.58	11.00	1.74	81882.47
最大值	12.71	8.76	65.53	2.91	17.38	11.59	1.81	84935.50
發生時間	15	8	12	2	23	8		22
最小值	2.44	1.98	49.38	1.28	13.62	10.48	1.67	75239.92
發生時間	12	18	13	23	2	22		8
零點偏移(率)	0.00 %	-0.06 %	-0.00 %	-0.03 %		0.01	0.00	0.00 %
全幅偏移(率)	1.55 %	0.79 %	-0.68 %	0.18 %		0.17	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								