

報表日期: 115年01月01日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.57	12.48	39.68	2.02	16.96	11.28	1.29	83814.98
1	7.83	12.32	49.14	2.14	17.32	11.55	1.29	81147.58
2	7.63	11.79	50.34	1.79	16.58	11.35	1.29	83366.83
3	7.78	12.05	59.22	2.37	15.30	11.67	1.29	82315.49
4	8.01	12.66	56.06	3.44	14.34	11.96	1.30	80416.81
5	6.59	12.05	48.69	1.35	15.11	11.89	1.27	82062.74
6	6.59	12.19	54.42	2.32	15.82	11.66	1.26	81184.97
7	6.48	11.93	48.63	1.72	16.97	11.44	1.25	82272.72
8	6.54	11.82	48.94	1.63	16.60	11.50	1.26	82251.59
9	6.96	12.01	40.26	2.81	14.77	11.86	1.26	80926.92
10	7.84	12.09	38.19	2.30	16.04	11.80	1.26	80130.32
11	7.92	12.02	45.92	1.64	16.91	11.26	1.26	83892.55
12	9.85	13.06	49.82	2.10	15.61	11.61	1.26	81897.16
13	9.79	14.43	52.30	2.06	15.37	12.40	1.26	74823.85
14	8.85	13.63	40.21	2.10	15.89	11.79	1.29	80159.73
15	6.80	12.20	47.82	2.23	15.21	11.89	1.29	79989.46
16	6.89	12.10	56.12	2.40	15.20	11.89	1.29	79807.65
17	6.80	12.50	64.35	1.57	16.34	12.00	1.29	78181.02
18	6.49	11.99	60.96	1.15	17.52	11.42	1.29	82039.96
19	6.58	12.13	57.22	1.37	16.70	11.64	1.29	80819.31
20	6.56	12.04	53.76	1.67	16.52	11.62	1.29	81075.85
21	6.47	11.90	58.35	1.08	17.36	11.41	1.29	82187.55
22	6.84	12.58	47.09	3.10	14.34	12.20	1.29	78090.90
23	7.04	13.36	55.00	2.59	15.57	12.33	1.29	75917.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.36	12.39	50.94	2.04	16.01	11.73	1.28	80782.22
最 大 值	9.85	14.43	64.35	3.44	17.52	12.40	1.31	83892.55
發生時間	12	13	17	4	18	13		11
最 小 值	6.47	11.79	38.19	1.08	14.34	11.26	1.25	74823.85
發生時間	21	2	10	21	4	11		13
零點偏移(率)	-0.09 %	-0.01 %	-0.01 %	-0.01 %		-0.06	-0.01	0.40 %
全幅偏移(率)	-1.32 %	0.92 %	-1.30 %	-0.86 %		0.08	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

