

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.70	9.76	51.45	0.94	20.03	10.65	1.09	78023.52
1	8.99	11.29	60.49	1.18	18.94	11.44	1.10	73050.71
2	10.33	11.39	60.85	1.74	16.86	11.70	1.09	72835.96
3	8.74	11.54	57.40	1.85	15.96	11.82	1.08	72487.24
4	9.04	10.07	62.95	1.93	16.95	11.54	1.08	74632.85
5	0.71	8.81	60.20	0.85	16.77	11.98	1.09	73056.29
6	7.52	11.15	59.70	1.16	17.66	11.16	1.08	76487.32
7	9.24	11.06	58.31	1.77	16.69	11.71	1.08	72964.83
8	4.84	8.99	65.15	0.89	18.08	11.65	1.10	72467.28
9	2.97	8.53	43.68	0.37	19.48	10.54	1.11	78565.94
10	8.04	9.05	49.57	0.78	18.76	10.50	1.14	80334.15
11	7.46	10.83	64.15	1.35	16.94	11.55	1.12	74055.74
12	9.34	10.21	52.64	1.33	19.11	10.57	1.10	79272.05
13	9.11	10.92	53.92	1.61	18.00	10.90	1.10	77381.44
14	9.24	9.69	56.65	1.24	17.77	10.97	1.10	77339.96
15	8.46	8.97	61.70	1.62	17.83	11.22	1.10	74945.25
16	4.89	15.30	68.87	1.10	17.08	12.56	1.15	65914.03
17	1.79	6.12	58.47	0.68	17.37	11.97	1.15	70079.68
18	4.53	7.21	57.74	0.73	19.10	10.80	1.13	77273.19
19	9.72	7.27	43.53	2.03	16.95	11.08	1.12	75748.09
20	9.14	9.78	48.00	1.03	18.88	10.89	1.11	76816.41
21	9.30	6.85	42.76	1.15	18.33	10.93	1.10	76972.87
22	8.23	8.97	61.07	0.88	18.78	11.02	1.10	76147.54
23	9.26	11.22	48.37	1.30	17.06	11.08	1.10	74336.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.48	9.79	56.15	1.23	17.89	11.26	1.10	75049.52
最大值	10.33	15.30	68.87	2.03	20.03	12.56	1.25	80334.15
發生時間	2	16	16	19	0	16		10
最小值	0.71	6.12	42.76	0.37	15.96	10.50	1.07	65914.03
發生時間	5	17	21	9	3	10		16
零點偏移(率)	0.00 %	-0.05 %	-0.03 %	-0.00 %		0.01		0.00 %
全幅偏移(率)	0.02 %	0.80 %	0.54 %	0.15 %		0.08		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.56	6.86	55.31	1.43	17.67	10.49	1.08	83901.35
1	2.49	7.04	60.70	1.35	19.01	10.33	1.09	83456.97
2	5.39	7.41	49.53	1.76	17.71	10.07	1.08	87389.98
3	9.28	11.47	48.53	2.63	15.98	10.43	1.08	84957.01
4	8.87	5.83	55.82	2.12	16.52	10.41	1.07	85163.36
5	8.16	9.04	56.00	1.99	16.50	10.36	1.07	84969.41
6	4.80	5.76	62.06	0.91	18.66	9.84	1.09	91729.57
7	8.10	5.91	54.49	1.24	18.92	9.48	1.07	89603.69
8	7.82	5.44	59.20	1.82	17.00	10.10	1.07	86292.79
9	4.14	5.62	57.12	1.23	18.08	10.30	1.06	84631.48
10	6.46	5.48	61.09	1.34	18.18	9.95	1.05	87219.87
11	9.73	8.07	55.72	1.97	16.77	10.05	1.05	87083.98
12	8.32	5.25	62.40	1.37	17.24	10.02	1.06	87223.09
13	9.56	8.92	58.59	2.28	15.55	10.50	1.07	84745.05
14	9.47	5.37	65.73	1.72	16.55	10.34	1.06	85265.49
15	8.55	6.37	56.34	1.32	16.58	10.63	1.05	83663.09
16	9.48	6.83	64.68	1.20	17.59	10.15	1.05	85723.38
17	9.08	8.13	46.10	1.99	16.80	10.25	1.03	86073.83
18	8.72	10.70	60.95	2.33	15.33	10.64	1.05	84761.47
19	9.71	3.15	64.67	1.58	16.08	10.72	1.05	82965.44
20	7.75	3.75	53.38	1.58	16.85	10.39	1.05	85209.63
21	8.20	3.76	59.50	1.64	16.66	10.49	1.07	84363.83
22	9.21	5.52	60.63	1.66	15.87	10.42	1.07	85559.42
23	9.30	6.04	66.30	1.63	16.03	10.82	1.06	82648.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.88	6.57	58.12	1.67	17.01	10.30	1.06	85608.40
最大值	9.73	11.47	66.30	2.63	19.01	10.82	1.11	91729.57
發生時間	11	3	23	3	1	23		6
最小值	2.49	3.15	46.10	0.91	15.33	9.48	1.02	82648.49
發生時間	1	19	17	6	18	7		23
零點偏移(率)	-0.02 %	-0.02 %	-0.05 %	-0.03 %		0.04		-0.20 %
全幅偏移(率)	0.04 %	0.70 %	0.11 %	0.31 %		-0.08		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.81	6.49	57.83	0.97	16.33	11.10	0.99	78371.74
1	7.95	8.21	51.35	1.18	16.67	11.05	0.98	75733.36
2	9.27	7.36	49.56	1.31	16.35	10.65	0.98	78038.63
3	8.74	8.70	47.49	1.88	14.42	10.84	0.97	76040.66
4	10.65	7.49	51.94	1.85	15.23	10.63	0.97	77575.62
5	9.32	9.95	45.22	1.50	16.09	10.24	0.97	79668.75
6	7.47	5.71	54.53	1.39	15.19	11.05	0.97	75892.00
7	8.45	8.42	44.08	1.00	16.56	10.61	0.97	79451.34
8	6.75	5.54	49.79	0.93	16.42	10.53	0.97	80305.18
9	9.12	6.61	52.08	0.76	18.66	9.97	0.98	84489.04
10	8.94	6.49	43.76	1.52	16.52	10.36	0.98	82225.22
11	8.95	5.74	52.39	1.44	14.87	10.69	0.99	77526.01
12	9.14	8.26	51.91	1.57	14.65	10.91	0.97	79254.69
13	8.36	10.06	56.27	1.14	15.30	11.14	0.97	81385.40
14	7.94	10.21	49.36	1.29	14.95	11.15	0.97	79920.71
15	9.86	8.91	56.58	0.99	17.32	10.19	0.98	86113.19
16	6.60	10.25	60.81	0.95	16.37	10.45	0.97	81542.12
17	11.86	5.80	47.22	1.21	16.01	10.36	0.98	78218.86
18	9.04	6.92	45.14	1.20	16.43	9.93	0.97	78829.32
19	11.73	11.18	41.72	1.64	15.22	10.45	0.95	76955.66
20	9.44	5.53	40.53	1.06	16.41	10.33	0.97	77438.16
21	9.57	3.98	51.91	1.47	17.07	9.62	0.97	79982.91
22	10.32	9.82	50.03	1.01	17.31	9.46	0.97	79315.41
23	9.56	6.92	65.33	0.86	17.20	9.69	0.97	77588.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.08	7.69	50.70	1.25	16.15	10.48	0.97	79244.27
最大值	11.86	11.18	65.33	1.88	18.66	11.15	0.99	86113.19
發生時間	17	19	23	3	9	14		15
最小值	6.60	3.98	40.53	0.76	14.42	9.46	0.94	75733.36
發生時間	16	21	20	9	3	22		1
零點偏移(率)	-0.06 %	-0.01 %	-0.06 %	-0.04 %		0.01		0.00 %
全幅偏移(率)	1.96 %	0.49 %	0.03 %	0.37 %		0.43		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								