

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年05月24日

報表日期: 114年05月24日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
0	2.24	3.98	63.99	3.03	15.08	12.08	1.46	68620.89
1	4.82	5.03	57.62	3.18	16.10	11.94	1.63	69391.77
2	4.63	2.52	66.34	3.18	15.30	12.10	1.34	68246.33
3	3.38	2.98	56.14	3.27	16.54	11.35	1.45	73665.70
4	6.28	1.41	58.08	3.92	14.36	11.94	1.34	77825.65
5	2.65	7.64	61.27	4.11	14.90	12.18	2.91	76266.27
6	4.19	3.18	60.54	3.86	15.71	11.99	1.06	73811.35
7	4.19	2.58	64.30	4.30	14.16	12.60	1.08	67890.18
8	4.80	1.93	69.23	2.57	14.18	12.96	1.30	64512.64
9	2.76	2.50	67.96	2.52	13.71	13.01	1.47	63657.04
10	7.91	2.81	71.49	2.35	15.42	11.70	1.61	76419.91
11	8.97	9.38	42.26	3.39	13.81	11.88	1.89	77878.06
12	7.86	10.50	45.46	2.92	13.73	12.24	1.50	74770.12
13	4.59	10.33	52.09	3.01	12.66	12.27	1.56	73626.06
14	7.76	9.41	55.09	2.78	13.90	12.31	1.56	72188.42
15	5.20	1.87	70.34	2.76	15.53	11.98	1.50	73333.79
16	2.63	7.18	59.59	4.26	14.15	12.02	1.74	73506.09
17	5.66	6.34	64.56	3.96	14.75	11.90	1.51	74839.21
18	7.07	4.62	62.90	3.27	13.23	12.08	1.62	74006.72
19	4.52	3.64	58.76	3.53	15.65	11.74	1.45	75732.56
20	4.49	4.44	53.62	3.30	14.96	11.80	1.53	74866.46
21	1.34	2.77	59.65	2.90	15.33	11.93	1.44	73076.17
22	0.48	7.80	50.91	3.30	14.36	11.74	1.87	75282.84
23	4.65	4.90	57.71	3.38	14.58	12.25	1.58	72696.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.71	4.99	59.58	3.29	14.67	12.08	1.55	72754.60
最 大 值	8.97	10.50	71.49	4.30	16.54	13.01	5.85	77878.06
發生時間	11	12	10	7	3	9		11
最 小 值	0.48	1.41	42.26	2.35	12.66	11.35	0.91	63657.04
發生時間	22	4	11	10	13	3		9
零點偏移(率)	-0.08 %	-0.00 %	-0.28 %	-0.24 %		-0.03		0.20 %
全幅偏移(率)	-0.09 %	-0.19 %	-0.03 %	0.21 %		-0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月24日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.21	2.45	49.56	1.64	19.27	10.24	0.99	84147.22
1	1.22	2.37	38.12	1.88	19.41	10.34	0.97	80166.78
2	5.44	5.20	41.72	1.91	17.86	10.37	0.98	84160.20
3	8.49	5.11	39.80	2.74	17.64	10.49	0.98	83755.65
4	12.56	2.23	40.51	2.48	18.50	10.25	0.98	83638.03
5	9.09	3.05	36.19	2.19	18.97	10.16	0.98	84634.77
6	6.84	3.86	40.51	2.07	18.86	9.71	1.01	87196.91
7	5.72	4.50	61.39	3.00	15.94	11.18	1.01	78779.62
8	1.35	3.49	54.54	2.22	16.45	11.07	1.00	76017.06
9	1.62	5.55	58.62	2.43	16.76	11.09	0.98	73805.02
10	9.74	1.93	57.23	2.62	17.53	10.26	0.98	86280.41
11	7.81	2.68	59.08	2.60	16.46	10.56	0.97	84379.69
12	2.37	10.08	66.34	3.31	13.91	11.12	0.96	80956.90
13	1.33	2.09	63.39	2.45	15.44	10.93	0.98	82849.76
14	1.55	2.41	62.59	1.80	16.86	10.50	0.98	84566.74
15	0.16	1.34	64.94	2.38	16.18	10.52	0.98	85481.70
16	2.55	1.82	59.96	2.02	17.25	10.50	0.99	84204.80
17	2.18	2.71	61.19	1.90	17.63	10.58	0.99	82277.84
18	4.89	3.37	61.01	2.29	17.59	10.52	0.99	85069.23
19	4.25	1.97	57.58	2.01	17.69	10.36	0.98	86356.57
20	2.78	3.71	56.76	2.53	16.94	10.50	0.97	84478.92
21	2.43	2.91	61.66	2.10	16.93	10.54	0.96	85383.26
22	4.00	2.00	59.80	1.47	18.27	10.41	0.95	85341.88
23	5.14	2.60	57.30	1.37	18.67	10.17	0.97	86682.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.61	3.31	54.57	2.23	17.38	10.52	0.98	83358.82
最 大 值	12.56	10.08	66.34	3.31	19.41	11.18	1.02	87196.91
發生時間	4	12	12	12	1	7		6
最 小 值	0.16	1.34	36.19	1.37	13.91	9.71	0.94	73805.02
發生時間	15	15	5	23	12	6		9
零點偏移(率)	-0.02 %	-0.01 %	-0.05 %	-0.03 %		-0.06		-0.10 %
全幅偏移(率)	0.14 %	0.15 %	-0.06 %	0.41 %		-0.01		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

