

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.00	1.29	51.94	0.16	21.88	11.12	1.45	75307.01
1	4.34	1.18	38.12	0.08	22.82	10.75	1.44	77498.74
2	8.02	1.29	44.52	0.19	22.65	10.24	1.43	80967.71
3	9.52	7.89	45.50	0.70	20.54	10.88	1.42	78113.53
4	9.90	2.26	54.66	0.82	20.47	11.01	1.41	77706.31
5	11.76	1.59	57.15	0.89	21.26	10.62	1.40	79030.11
6	8.89	1.82	56.35	0.94	20.10	11.08	1.39	77089.39
7	9.79	2.15	47.27	1.11	19.51	11.32	1.38	75741.46
8	8.69	1.82	58.00	1.02	20.21	11.54	1.38	73690.83
9	9.69	2.19	55.33	0.95	21.32	10.89	1.37	77351.12
10	8.80	0.92	55.78	0.61	20.81	10.91	1.38	78043.59
11	11.19	1.56	50.81	0.84	20.68	10.82	1.38	79266.16
12	8.79	2.81	48.87	1.00	20.29	11.03	1.39	77600.11
13	9.97	2.16	49.58	0.90	20.00	10.94	1.38	78167.80
14	10.27	5.72	54.16	0.42	21.82	10.42	1.38	80563.82
15	9.78	4.07	50.60	0.82	20.81	10.90	1.38	77454.10
16	8.87	1.81	55.79	0.52	21.39	10.94	1.38	77264.13
17	7.61	5.30	54.09	0.36	21.65	10.84	1.38	78075.79
18	8.86	1.00	44.94	0.52	21.64	10.71	1.38	78721.10
19	9.38	2.44	54.78	0.51	21.84	10.82	1.39	78368.61
20	11.04	3.43	50.52	0.51	21.68	10.47	1.39	80926.04
21	9.06	7.23	52.11	0.67	21.55	10.75	1.41	78891.74
22	10.03	1.31	58.70	0.67	21.09	11.00	1.41	76818.79
23	10.35	5.05	46.38	0.81	20.89	10.88	1.41	77305.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.11	2.85	51.50	0.67	21.12	10.87	1.39	77915.15
最大值	11.76	7.89	58.70	1.11	22.82	11.54	1.46	80967.71
發生時間	5	3	22	7	1	8		2
最小值	4.00	0.92	38.12	0.08	19.51	10.24	1.36	73690.83
發生時間	0	10	1	1	7	2		8
零點偏移(率)	-0.01 %	-0.07 %	-0.02 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	0.02 %	0.03 %	-0.26 %	0.01 %		0.21	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.87	1.63	66.16	1.68	17.82	11.23	1.50	62587.78
1	1.97	1.83	60.89	1.38	18.75	11.01	1.49	63391.25
2	4.94	2.01	60.37	2.01	17.19	10.94	1.49	65262.32
3	8.44	1.05	59.93	2.06	18.85	10.35	1.49	68157.66
4	8.29	1.76	57.13	2.08	19.28	10.28	1.49	67745.51
5	8.66	1.27	56.81	2.18	18.35	10.35	1.51	68030.43
6	4.45	2.68	63.37	1.49	18.92	10.50	1.51	65556.31
7	7.21	4.05	58.45	1.84	19.02	10.28	1.51	67359.40
8	6.98	10.13	60.58	2.08	18.40	10.29	1.51	67845.88
9	10.67	0.96	62.44	2.43	19.23	10.01	1.51	69443.16
10	9.41	3.69	56.94	2.17	17.62	10.62	1.51	66202.35
11	10.51	1.14	59.45	1.88	19.80	10.09	1.51	68302.83
12	9.95	0.64	65.24	1.95	19.11	10.04	1.51	69271.77
13	9.36	3.14	63.03	1.99	19.15	10.18	1.51	68068.58
14	10.54	4.78	60.77	2.44	19.84	9.58	1.51	70158.18
15	9.37	0.80	61.22	2.06	19.06	10.26	1.51	66935.59
16	10.53	8.63	57.31	2.00	21.78	8.78	1.51	75001.74
17	9.55	1.26	53.86	1.92	19.92	9.83	1.51	69595.89
18	9.81	7.27	51.94	2.24	21.99	8.85	1.50	74502.43
19	9.98	1.22	49.78	2.25	17.62	10.30	1.48	67890.78
20	9.54	5.47	57.92	2.14	18.05	10.09	1.46	68328.09
21	5.93	3.43	58.36	1.39	19.84	10.32	1.46	64502.70
22	10.04	0.68	59.98	1.60	19.91	9.68	1.46	70491.79
23	9.96	2.16	60.20	2.36	17.99	9.91	1.46	69074.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.29	2.99	59.26	1.98	19.06	10.16	1.50	68071.14
最大值	10.67	10.13	66.16	2.44	21.99	11.23	1.52	75001.74
發生時間	9	8	0	14	18	0		16
最小值	1.97	0.64	49.78	1.38	17.19	8.78	1.45	62587.78
發生時間	1	12	19	1	2	16		0
零點偏移(率)	0.00 %	-0.04 %	-0.11 %	0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	0.47 %	0.09 %	0.18 %	0.09 %		0.08	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.91	4.61	49.12	2.23	16.02	10.24	1.25	84691.84
1	5.82	6.73	55.43	2.41	17.90	10.32	1.25	86418.97
2	5.50	1.29	52.87	2.75	15.81	10.71	1.25	82047.33
3	8.49	0.51	57.33	2.30	18.18	10.34	1.25	85476.33
4	10.25	1.29	57.77	2.65	17.09	10.40	1.25	89615.62
5	8.44	1.09	53.96	2.22	17.35	10.48	1.25	87642.95
6	7.14	4.52	52.74	2.08	17.54	10.23	1.25	87991.29
7	10.93	4.62	59.49	2.39	16.16	10.76	1.28	86278.24
8	6.25	2.20	59.76	2.68	14.74	11.58	1.29	78973.94
9	8.24	4.03	54.20	2.20	16.71	10.39	1.30	87630.93
10	8.35	1.02	55.07	2.42	15.44	10.83	1.30	84124.33
11	9.97	6.64	59.03	2.28	17.57	10.37	1.30	88692.14
12	10.61	4.09	53.85	2.40	17.15	10.34	1.30	87152.53
13	12.04	4.54	49.50	2.64	17.01	10.08	1.30	91371.48
14	8.18	2.64	57.71	2.28	16.70	10.52	1.30	89363.69
15	13.03	1.67	57.92	2.62	18.24	9.81	1.30	89997.72
16	9.66	6.93	50.49	2.51	17.25	9.94	1.30	86386.20
17	12.40	1.95	56.86	2.45	18.35	9.60	1.30	93891.18
18	10.00	3.12	51.20	1.98	18.73	9.79	1.30	89400.30
19	11.20	2.99	64.40	2.51	18.60	9.76	1.28	90851.59
20	11.62	9.28	54.37	2.45	18.00	9.50	1.26	87549.48
21	10.42	9.94	46.43	2.13	17.26	9.47	1.25	84479.61
22	11.21	2.76	48.56	2.16	17.40	9.71	1.25	83286.17
23	9.34	5.54	49.28	1.98	17.08	9.90	1.25	82239.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.46	3.92	54.47	2.36	17.18	10.21	1.27	86898.07
最大值	13.03	9.94	64.40	2.75	18.73	11.58	1.32	93891.18
發生時間	15	21	19	2	18	8		17
最小值	5.50	0.51	46.43	1.98	14.74	9.47	1.24	78973.94
發生時間	2	3	21	18	8	21		8
零點偏移(率)	-0.04 %	-0.07 %	-0.15 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.45 %	0.18 %	-0.40 %	0.13 %		0.35	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								