

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.66	13.34	56.12	1.82	17.09	11.44	1.21	80416.44
1	9.22	12.67	51.87	1.69	18.87	10.92	1.19	82899.49
2	7.35	11.88	49.76	1.92	16.51	11.49	1.19	80637.21
3	10.45	12.05	53.97	2.25	17.13	11.43	1.19	81015.21
4	8.16	11.89	49.37	3.02	16.37	11.54	1.20	81014.88
5	9.64	13.08	44.33	2.66	16.62	11.31	1.18	78286.20
6	5.45	13.10	49.48	2.70	16.73	11.50	1.19	80612.07
7	9.42	13.49	50.52	1.82	18.13	10.98	1.19	83383.39
8	5.45	13.46	50.39	2.14	17.59	11.15	1.19	82431.49
9	8.36	12.94	62.92	2.46	18.48	11.10	1.19	82048.87
10	11.66	13.24	56.95	2.69	18.16	11.17	1.18	81812.90
11	9.02	13.04	52.38	2.87	17.42	11.10	1.18	82670.85
12	8.43	13.10	59.43	1.98	17.17	11.41	1.18	80631.05
13	7.03	13.24	57.71	1.63	17.45	11.42	1.19	80300.87
14	8.63	13.20	61.74	1.50	18.14	11.35	1.20	80563.57
15	8.73	12.95	62.09	1.79	18.87	11.06	1.18	81970.91
16	9.83	12.21	54.20	2.12	17.67	11.20	1.18	81515.23
17	11.03	11.48	63.07	2.22	18.01	10.99	1.18	83508.13
18	9.93	11.75	54.98	1.97	17.20	11.46	1.19	80091.50
19	8.23	11.93	55.34	1.34	18.89	10.97	1.18	82655.50
20	11.57	11.28	61.18	1.59	18.59	10.85	1.18	83952.43
21	6.60	12.52	59.37	1.47	18.66	11.05	1.20	82333.43
22	9.56	12.51	55.88	1.16	19.39	10.77	1.20	83646.94
23	10.38	12.29	58.52	2.35	19.84	10.45	1.20	85430.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.78	12.61	55.48	2.05	17.87	11.17	1.19	81826.21
最大值	11.66	13.49	63.07	3.02	19.84	11.54	1.22	85430.50
發生時間	10	7	17	4	23	4		23
最小值	5.45	11.28	44.33	1.16	16.37	10.45	1.16	78286.20
發生時間	6	20	5	22	4	23		5
零點偏移(率)	-0.65 %	-0.01 %	-0.18 %	-0.13 %		-0.03	-0.01	0.20 %
全幅偏移(率)	-0.96 %	1.64 %	-0.06 %	0.35 %		-0.27	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.06	13.03	52.03	1.14	19.07	10.50	1.01	83513.38
1	7.48	13.73	44.14	1.37	18.54	10.87	0.99	81631.31
2	10.76	13.51	52.06	0.80	19.14	10.77	1.00	82324.24
3	8.71	13.54	51.65	1.27	18.27	10.89	1.00	82353.97
4	10.42	13.37	50.16	2.05	18.77	10.52	0.99	84545.70
5	6.17	13.35	58.68	0.92	19.28	10.60	1.00	83526.55
6	8.21	11.67	55.04	0.73	19.62	10.07	0.97	88316.76
7	6.90	11.97	49.60	0.91	18.92	10.44	0.98	84823.55
8	8.65	12.91	51.19	1.51	17.81	11.27	0.98	79324.73
9	6.71	12.25	48.06	0.87	19.49	10.63	0.97	82492.15
10	16.24	12.74	51.45	2.50	17.15	10.93	0.97	82752.49
11	3.39	12.13	56.91	0.95	18.78	10.53	0.98	84255.91
12	5.03	12.32	61.47	0.72	19.50	10.74	0.98	81681.30
13	6.42	12.23	48.46	0.80	18.94	10.72	0.98	82080.91
14	3.92	12.91	52.55	1.13	18.39	11.26	0.98	78572.17
15	10.51	12.85	55.49	0.89	18.33	11.32	0.97	78388.77
16	4.16	12.80	52.33	1.64	17.36	11.28	0.98	79032.85
17	8.77	12.72	55.80	1.64	17.36	11.31	0.94	79167.15
18	5.44	12.61	57.97	1.14	18.14	11.11	0.95	80602.71
19	10.25	12.69	62.78	1.06	17.92	11.24	0.97	79469.10
20	11.89	12.52	54.12	1.48	17.84	11.04	0.96	81658.23
21	10.23	12.62	58.83	0.95	18.60	11.08	0.94	80576.53
22	4.76	12.34	54.17	0.75	19.93	10.67	0.94	82187.11
23	7.45	12.26	52.60	0.48	20.94	10.40	0.95	83220.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.90	12.71	53.65	1.15	18.67	10.84	0.97	81937.40
最大值	16.24	13.73	62.78	2.50	20.94	11.32	1.02	88316.76
發生時間	10	1	19	10	23	15		6
最小值	3.39	11.67	44.14	0.48	17.15	10.07	0.94	78388.77
發生時間	11	6	1	23	10	6		15
零點偏移(率)	-0.09 %	-0.02 %	-0.04 %	0.00 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	-2.04 %	-2.31 %	0.35 %	0.38 %		-0.10	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.66	11.21	59.23	2.71	17.99	9.87	1.27	74883.35
1	6.19	11.33	60.78	2.95	18.93	9.84	1.30	73451.38
2	4.14	11.39	52.81	2.60	17.83	9.67	1.32	73883.78
3	6.43	11.24	60.01	2.77	17.49	9.91	1.29	74989.92
4	5.69	11.25	63.73	2.92	18.05	9.89	1.27	75128.25
5	7.95	10.98	57.98	3.21	19.41	9.35	1.28	77160.46
6	9.63	11.14	55.62	2.61	18.48	9.14	1.28	75198.10
7	4.62	11.57	57.54	2.21	20.84	9.56	1.31	81085.81
8	8.36	11.88	59.56	3.46	17.96	9.52	1.32	75364.48
9	6.47	11.22	59.95	3.06	19.06	9.49	1.30	75139.30
10	9.19	10.98	61.93	3.64	19.07	9.45	1.29	74860.91
11	11.09	11.38	64.55	3.39	17.24	10.23	1.29	74539.63
12	7.59	11.94	66.84	3.11	17.24	10.28	1.29	75750.31
13	7.64	13.73	64.06	2.80	17.21	10.32	1.28	72903.25
14	4.85	13.89	67.30	2.84	17.83	10.38	1.27	72740.08
15	4.80	11.80	53.61	2.45	18.70	10.46	1.29	79764.64
16	3.43	11.45	54.60	1.89	20.37	9.58	1.29	73214.21
17	5.71	11.25	49.14	1.80	18.96	9.61	1.28	76288.16
18	3.42	11.23	52.18	1.65	18.46	9.73	1.28	73809.84
19	2.83	11.37	58.28	1.69	19.01	9.86	1.28	72844.79
20	2.85	11.31	53.63	1.72	18.94	9.64	1.31	73869.03
21	4.19	14.88	49.66	2.05	18.07	9.41	1.31	74159.98
22	3.69	12.44	53.43	1.15	19.89	8.94	1.31	76592.01
23	4.67	11.43	63.11	2.94	19.86	9.42	1.31	73378.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.84	11.76	58.31	2.57	18.62	9.73	1.29	75041.69
最大值	11.09	14.88	67.30	3.64	20.84	10.46	1.34	81085.81
發生時間	11	21	14	10	7	15		7
最小值	2.83	10.98	49.14	1.15	17.21	8.94	1.26	72740.08
發生時間	19	5	17	22	13	22		14
零點偏移(率)	-0.07 %	-0.06 %	-0.04 %	-0.00 %		-0.07	-0.01	-0.20 %
全幅偏移(率)	0.02 %	0.54 %	-0.37 %	0.75 %		0.00	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								