

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.82	11.33	51.44	1.84	17.89	11.43	0.99	78799.92
1	7.18	13.89	53.69	2.38	16.77	11.91	0.99	75815.78
2	5.85	12.11	54.70	1.65	17.87	11.49	0.97	77989.56
3	8.21	14.19	45.49	2.18	17.01	11.58	0.97	77575.86
4	7.02	11.33	53.63	2.07	17.98	11.84	0.97	75148.10
5	4.37	13.28	49.11	2.40	16.07	12.12	0.97	80192.02
6	5.77	10.39	52.51	2.08	17.33	11.72	0.98	75621.59
7	8.87	10.98	59.25	2.20	17.26	11.84	0.97	74351.78
8	8.77	10.40	49.02	2.08	16.74	11.85	1.00	74935.75
9	8.36	6.99	61.66	1.26	18.61	11.37	1.00	77388.47
10	8.06	8.86	47.57	2.49	16.05	12.22	1.00	72172.29
11	7.14	8.35	50.55	2.39	16.16	12.43	1.00	69561.79
12	5.93	5.98	55.72	1.49	18.00	12.09	0.99	71396.44
13	8.50	6.26	51.74	1.73	17.97	11.27	0.99	77406.66
14	8.19	8.30	53.82	2.39	16.36	12.53	0.98	68662.11
15	8.43	7.92	49.93	1.55	18.20	11.26	0.98	76677.74
16	7.49	6.98	56.21	1.19	18.49	11.67	0.99	74949.21
17	6.74	6.96	53.10	1.28	18.92	11.14	0.98	79873.15
18	7.04	10.75	44.00	1.50	18.83	11.35	0.98	78093.26
19	4.19	3.77	41.50	0.84	20.61	10.65	0.99	82006.56
20	0.77	3.52	41.79	0.83	20.79	10.88	1.00	80295.49
21	1.46	3.63	42.65	0.89	19.28	11.02	0.98	80207.70
22	3.24	4.69	39.61	1.93	18.11	11.46	0.97	78257.72
23	2.05	9.19	58.62	1.00	19.31	11.36	0.96	78018.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.35	8.75	50.72	1.74	17.94	11.60	0.98	76474.87
最大值	8.87	14.19	61.66	2.49	20.79	12.53	1.02	82006.56
發生時間	7	3	9	10	20	14		19
最小值	0.77	3.52	39.61	0.83	16.05	10.65	0.95	68662.11
發生時間	20	20	22	20	10	19		14
零點偏移(率)	-0.04 %	-0.04 %	-0.10 %	0.00 %		-0.01		0.00 %
全幅偏移(率)	0.04 %	0.04 %	-0.05 %	0.04 %		-0.18		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.00	7.12	54.60	1.71	17.30	10.97	0.98	79001.66
1	2.44	9.67	47.62	2.73	16.81	10.66	0.97	82232.35
2	2.48	9.43	51.94	1.87	17.77	10.67	0.97	82126.20
3	2.40	9.30	44.64	1.63	18.50	10.20	0.98	85542.54
4	2.68	13.70	42.17	1.61	18.71	10.10	0.98	85576.00
5	4.19	7.32	48.28	2.26	17.72	10.47	0.98	83898.28
6	3.09	8.88	41.51	1.65	19.52	9.51	1.01	96152.13
7	4.97	10.55	39.47	1.93	18.22	10.23	1.02	83640.64
8	2.90	6.40	46.27	1.36	19.06	9.83	1.01	85827.67
9	8.18	4.42	57.44	2.43	16.72	10.52	1.02	84433.03
10	6.20	7.41	57.06	3.39	13.76	11.63	1.04	74495.82
11	8.98	4.31	55.16	2.56	15.81	11.13	1.02	76887.17
12	7.42	3.60	57.99	2.41	15.82	11.31	1.02	74638.42
13	4.92	2.53	60.95	2.10	16.86	11.06	1.02	78668.46
14	2.54	15.35	55.27	1.25	18.02	10.86	1.02	80319.37
15	8.30	3.66	56.55	2.45	16.59	10.52	1.00	83564.42
16	8.33	7.27	42.30	1.62	18.04	10.13	1.01	85268.61
17	2.92	3.34	61.48	1.32	18.31	10.59	1.00	81287.11
18	4.09	4.11	55.09	1.66	19.42	10.33	1.01	83599.35
19	0.32	11.37	51.89	1.07	21.09	9.34	1.00	89672.80
20	0.09	5.15	53.71	1.58	18.11	10.23	1.02	85288.47
21	0.07	3.90	46.60	2.22	17.21	10.49	1.01	83983.93
22	0.08	4.42	52.82	1.87	17.77	10.19	0.99	84454.72
23	0.06	5.93	48.48	4.41	16.92	10.21	0.99	83234.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.69	7.05	51.22	2.05	17.67	10.47	1.00	83074.74
最大值	8.98	15.35	61.48	4.41	21.09	11.63	1.05	96152.13
發生時間	11	14	17	23	19	10		6
最小值	0.06	2.53	39.47	1.07	13.76	9.34	0.97	74495.82
發生時間	23	13	7	19	10	19		10
零點偏移(率)	-0.05 %	-0.08 %	-0.02 %	-0.01 %		0.00		-0.20 %
全幅偏移(率)	0.04 %	0.85 %	-0.71 %	-0.11 %		-0.29		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.99	11.12	46.75	1.87	16.09	10.70	0.97	78230.06
1	2.23	8.32	58.07	1.86	17.23	11.18	0.96	76707.90
2	4.22	10.03	56.03	2.19	16.11	10.76	0.94	81676.65
3	9.25	8.27	57.36	3.01	14.66	11.19	0.92	78044.56
4	6.19	6.25	57.07	2.35	15.71	11.07	0.93	80459.41
5	9.28	7.94	53.55	3.23	14.67	11.01	0.94	77653.26
6	8.21	9.42	55.70	3.38	14.43	11.15	0.92	73988.88
7	8.86	6.67	48.44	2.88	15.16	10.63	0.98	75498.79
8	11.53	9.65	47.51	3.23	14.93	10.51	0.96	76946.48
9	8.07	5.37	49.43	2.94	15.26	10.60	0.98	74543.91
10	4.92	3.64	57.28	2.67	14.54	11.53	0.98	67315.44
11	4.86	9.70	50.94	2.83	14.08	11.64	0.94	66561.51
12	4.76	5.55	54.95	2.80	14.13	11.59	0.97	67276.85
13	7.02	8.06	50.81	1.87	16.62	10.87	0.95	72777.28
14	6.93	10.97	55.13	2.53	14.66	11.57	0.96	69218.12
15	10.12	7.97	45.09	2.84	15.01	10.62	0.93	74953.66
16	7.60	3.13	63.06	2.29	17.23	10.41	0.94	79916.94
17	8.17	5.87	59.29	2.50	15.48	11.22	0.97	76112.05
18	7.25	5.56	54.57	2.49	15.53	10.88	0.96	77285.61
19	2.05	5.75	58.71	2.14	15.48	11.19	0.94	74970.94
20	1.31	6.03	58.50	1.79	17.03	10.56	0.96	79091.14
21	1.16	8.24	54.61	2.22	15.09	11.01	0.99	76238.27
22	0.53	1.76	56.95	2.09	15.07	11.09	0.99	75356.27
23	0.15	5.21	56.18	2.26	14.51	10.86	0.97	74535.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.74	7.10	54.42	2.51	15.36	10.99	0.96	75223.31
最大值	11.53	11.12	63.06	3.38	17.23	11.64	1.00	81676.65
發生時間	8	0	16	6	1	11		2
最小值	0.15	1.76	45.09	1.79	14.08	10.41	0.91	66561.51
發生時間	23	22	15	20	11	16		11
零點偏移(率)	-0.02 %	0.00 %	-0.02 %	0.00 %		-0.02		0.00 %
全幅偏移(率)	0.04 %	0.34 %	-1.27 %	0.14 %		0.29		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								