

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.79	2.82	58.00	3.10	20.28	11.05	1.41	77725.30
1	9.70	3.35	63.99	2.97	20.89	11.14	1.40	75864.57
2	8.64	3.50	57.70	2.84	20.86	10.94	1.40	77394.98
3	10.68	3.32	58.36	3.46	19.42	11.29	1.40	75743.37
4	9.25	2.77	63.62	3.31	20.18	11.26	1.41	75268.67
5	5.77	3.61	54.92	3.03	19.72	10.73	1.41	81090.40
6	6.63	5.73	55.64	3.50	18.08	11.87	1.43	72340.80
7	10.85	6.48	57.38	3.34	19.66	11.22	1.42	75946.02
8	9.69	1.55	55.81	3.24	19.89	11.18	1.41	76193.75
9	10.69	1.13	59.30	3.51	18.53	11.43	1.41	75295.11
10	10.98	1.36	56.26	3.30	19.57	11.17	1.43	76247.73
11	13.10	1.78	53.04	3.61	18.83	11.36	1.43	75337.12
12	8.85	1.53	52.20	3.43	19.24	11.27	1.42	76562.32
13	10.85	1.15	54.16	3.34	19.24	11.18	1.42	77686.39
14	11.07	2.49	53.17	3.72	17.72	11.78	1.44	73775.43
15	10.20	4.00	51.78	3.58	18.09	11.56	1.44	75172.64
16	10.15	4.03	57.21	3.56	18.22	11.70	1.46	74156.06
17	8.59	3.61	57.53	3.51	18.58	11.68	1.46	74577.70
18	5.26	3.95	63.28	3.44	19.06	11.79	1.46	73375.14
19	10.52	9.17	47.36	3.78	17.20	11.75	1.46	75256.18
20	9.78	1.37	55.75	3.52	18.82	11.39	1.46	76431.73
21	10.93	2.37	54.78	3.66	17.79	11.71	1.46	74801.79
22	14.80	7.28	49.37	3.79	17.50	11.66	1.46	74942.95
23	18.25	7.28	55.66	3.88	17.87	11.55	1.45	75656.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.04	3.57	56.09	3.43	18.97	11.40	1.43	75701.77
最大值	18.25	9.17	63.99	3.88	20.89	11.87	1.47	81090.40
發生時間	23	19	1	23	1	6		5
最小值	5.26	1.13	47.36	2.84	17.20	10.73	1.39	72340.80
發生時間	18	9	19	2	19	5		6
零點偏移(率)	0.00 %	-0.00 %	-0.04 %	-0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	2.85 %	0.09 %	-0.33 %	0.39 %		0.29	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.09	2.76	58.33	1.59	18.37	10.20	1.38	67967.18
1	7.68	4.69	59.87	1.69	18.00	10.71	1.38	64256.87
2	9.03	2.90	58.29	1.77	18.60	10.55	1.38	65085.58
3	9.54	4.80	52.93	1.87	18.77	10.29	1.38	67164.79
4	8.91	8.02	62.00	1.79	18.47	10.29	1.39	66362.74
5	7.65	5.87	53.41	1.78	18.30	10.15	1.41	65932.05
6	11.77	4.67	61.57	2.28	18.44	10.23	1.41	66033.50
7	10.24	5.50	53.43	2.30	17.59	10.45	1.40	64489.55
8	10.03	5.37	59.75	2.24	17.35	10.45	1.38	66960.58
9	10.33	2.87	54.93	2.14	17.62	10.14	1.38	66392.27
10	11.82	0.95	59.37	2.60	16.36	10.48	1.38	64454.26
11	9.69	2.09	64.02	2.56	14.90	11.11	1.39	63702.25
12	9.97	1.31	60.27	2.29	16.32	10.67	1.38	64785.56
13	10.09	1.11	58.07	2.62	14.95	10.94	1.37	64268.60
14	10.10	0.97	67.39	2.41	15.09	11.02	1.37	63493.18
15	10.77	9.00	64.05	2.65	14.29	11.14	1.36	63794.72
16	7.69	8.10	65.57	2.66	14.19	11.45	1.34	61606.96
17	10.04	3.06	66.40	2.32	15.78	11.10	1.36	64334.20
18	10.45	5.24	62.29	2.71	16.16	10.77	1.38	65071.40
19	10.42	9.24	61.47	3.68	13.57	11.20	1.39	62621.99
20	10.48	5.49	67.42	3.84	13.74	11.19	1.39	60633.35
21	12.27	5.57	66.95	3.35	13.43	11.17	1.38	61916.20
22	9.86	1.73	47.53	2.59	15.21	11.26	1.40	62060.57
23	10.37	5.54	65.15	2.67	14.91	11.17	1.41	62320.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.93	4.45	60.44	2.43	16.27	10.76	1.38	64404.54
最大值	12.27	9.24	67.42	3.84	18.77	11.45	1.44	67967.18
發生時間	21	19	20	20	3	16		0
最小值	7.65	0.95	47.53	1.59	13.43	10.14	1.33	60633.35
發生時間	5	10	22	0	21	9		20
零點偏移(率)	-0.01 %	0.00 %	-0.00 %	0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	2.12 %	0.70 %	-0.13 %	0.39 %		0.25	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.34	4.24	60.26	2.04	16.10	10.55	1.75	84868.03
1	7.94	11.94	64.61	2.14	17.46	10.40	1.75	86562.76
2	5.74	5.77	52.15	1.91	17.91	10.21	1.75	84951.05
3	7.63	1.54	61.44	2.13	16.46	10.66	1.75	83055.51
4	5.04	2.99	59.84	2.11	16.38	10.62	1.76	83221.13
5	6.03	1.34	61.94	2.27	15.60	10.83	1.76	82338.55
6	6.13	2.80	57.93	2.35	15.28	11.01	1.77	81215.28
7	8.49	4.49	62.49	2.41	15.61	10.86	1.75	86238.94
8	7.73	7.03	58.95	2.41	16.00	10.65	1.73	82940.29
9	9.51	3.55	62.07	2.65	15.85	10.66	1.75	84343.30
10	10.06	4.26	52.04	2.32	16.03	10.56	1.75	85269.01
11	9.47	2.51	61.10	2.71	14.73	10.84	1.74	82256.05
12	8.58	5.23	56.44	2.69	14.92	10.91	1.74	81386.36
13	7.58	3.54	58.55	2.75	14.39	10.84	1.73	81070.44
14	9.77	3.59	58.09	3.08	13.95	10.97	1.74	80214.92
15	9.07	3.39	61.03	2.69	15.44	10.79	1.74	83852.50
16	9.17	6.35	62.96	2.80	14.52	11.23	1.73	83432.01
17	10.12	9.26	61.51	2.71	15.08	11.09	1.72	83545.81
18	8.67	4.14	62.79	2.42	15.86	10.93	1.72	85552.15
19	11.32	6.38	63.18	2.89	14.81	11.26	1.74	82262.64
20	13.06	16.26	61.26	3.14	14.19	11.29	1.75	82220.05
21	13.74	10.00	57.75	3.49	13.94	10.92	1.72	81351.69
22	12.39	1.73	61.47	2.75	14.90	10.81	1.73	80991.66
23	11.18	4.28	60.91	2.82	14.73	10.91	1.75	82464.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.95	5.28	60.03	2.57	15.42	10.83	1.74	83150.19
最大值	13.74	16.26	64.61	3.49	17.91	11.29	1.78	86562.76
發生時間	21	20	1	21	2	20		1
最小值	5.04	1.34	52.04	1.91	13.94	10.21	1.72	80214.92
發生時間	4	5	10	2	21	2		14
零點偏移(率)	0.00 %	0.00 %	-0.00 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	2.41 %	0.21 %	-0.42 %	0.32 %		0.47	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								