

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月21日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.94	13.31	56.26	2.22	19.36	10.78	1.24	83520.85
1	4.03	12.87	57.91	2.06	21.03	10.37	1.25	85425.74
2	9.82	13.54	40.12	2.86	18.81	10.44	1.24	87212.70
3	8.38	13.74	52.45	2.90	17.51	11.29	1.21	80891.89
4	10.03	12.61	56.97	2.08	19.81	10.81	1.23	83327.94
5	0.22	12.45	50.02	1.85	17.89	11.58	1.20	88750.04
6	7.97	10.94	50.61	1.94	18.88	10.54	1.21	86177.42
7	8.46	11.73	51.23	2.18	18.64	10.69	1.23	85157.55
8	8.18	11.35	56.51	2.50	18.36	11.02	1.23	83077.89
9	9.42	11.45	59.54	2.37	19.15	10.84	1.21	83807.69
10	7.62	11.76	48.78	2.43	18.92	10.58	1.22	85788.55
11	9.99	11.14	50.85	3.06	18.72	10.47	1.22	86589.96
12	11.05	12.50	54.28	2.36	17.67	11.04	1.21	83212.28
13	7.82	10.94	57.79	1.35	19.35	10.42	1.20	86267.61
14	7.44	11.63	57.93	1.15	18.15	11.12	1.20	82099.53
15	9.09	12.76	61.33	1.39	16.13	12.22	1.20	74975.96
16	9.24	11.43	54.33	1.16	18.09	10.94	1.20	83595.03
17	8.25	11.19	57.20	0.86	19.19	10.71	1.22	84383.15
18	10.38	11.11	55.72	1.35	19.10	10.50	1.23	85830.23
19	8.45	11.07	54.28	1.23	18.44	10.53	1.24	86526.09
20	10.03	11.61	55.73	1.43	17.01	11.21	1.23	82677.63
21	8.57	10.98	57.68	1.44	19.36	10.52	1.23	85438.73
22	9.31	11.02	54.93	2.04	18.04	10.49	1.23	87209.26
23	9.74	11.12	58.92	2.41	18.92	10.61	1.24	85559.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.35	11.84	54.64	1.94	18.61	10.82	1.22	84479.31
最 大 值	11.05	13.74	61.33	3.06	21.03	12.22	1.26	88750.04
發生時間	12	3	15	11	1	15		5
最 小 值	0.22	10.94	40.12	0.86	16.13	10.37	1.18	74975.96
發生時間	5	6	2	17	15	1		15
零點偏移(率)	-0.08 %	-0.01 %	-0.02 %	0.00 %		-0.02	-0.01	0.10 %
全幅偏移(率)	-0.73 %	0.55 %	1.51 %	0.53 %		-0.10	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年07月21日

報表日期: 115年07月21日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.89	13.08	57.60	2.72	19.35	10.37	1.31	77271.22
1	2.11	13.52	57.55	2.60	20.28	10.51	1.31	77706.93
2	3.39	12.55	54.23	2.52	20.56	9.31	1.34	82706.82
3	4.26	12.03	40.21	2.70	20.24	8.89	1.34	81621.73
4	3.46	12.41	53.30	2.43	18.70	9.80	1.35	80527.12
5	3.80	12.91	57.15	2.64	19.15	10.19	1.36	77140.03
6	2.66	12.51	55.69	2.45	18.95	9.84	1.34	79302.74
7	5.98	11.56	46.96	2.81	18.97	10.06	1.33	76825.17
8	2.55	11.68	54.88	2.34	18.84	9.99	1.33	79377.61
9	2.31	11.45	56.51	2.35	19.15	9.93	1.35	79279.93
10	1.47	11.68	55.18	2.11	18.46	10.01	1.32	78794.81
11	2.32	11.52	51.99	2.14	19.35	9.57	1.31	78463.97
12	1.99	11.68	62.18	1.27	18.03	10.03	1.34	80245.61
13	2.63	11.97	60.18	1.10	17.66	10.64	1.32	77350.79
14	1.87	12.28	61.98	1.16	17.49	10.86	1.32	74363.56
15	4.87	12.31	53.46	1.23	18.00	10.83	1.31	74257.96
16	4.14	11.67	58.66	1.29	19.05	10.20	1.31	82450.70
17	6.67	11.47	55.85	1.30	18.09	10.10	1.33	79640.14
18	4.47	11.51	58.19	1.25	16.75	10.31	1.31	77264.67
19	7.32	11.35	57.51	1.42	18.67	9.92	1.31	80854.86
20	6.39	11.47	51.84	1.38	16.86	10.23	1.31	78455.28
21	2.61	13.30	51.15	1.37	16.79	10.28	1.30	78389.56
22	6.37	11.55	57.99	1.01	18.46	10.06	1.30	79204.97
23	5.21	11.59	59.79	2.00	18.80	10.11	1.30	79439.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.91	12.04	55.42	1.90	18.61	10.08	1.32	78788.97
最 大 值	7.32	13.52	62.18	2.81	20.56	10.86	1.36	82706.82
發生時間	19	1	12	7	2	14		2
最 小 值	1.47	11.35	40.21	1.01	16.75	8.89	1.28	74257.96
發生時間	10	19	3	22	18	3		15
零點偏移(率)	-0.03 %	0.00 %	-0.07 %	0.00 %		-0.05	-0.01	-0.20 %
全幅偏移(率)	-0.07 %	0.77 %	1.09 %	1.61 %		0.35	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								