

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.68	12.58	49.23	2.35	17.04	12.06	1.49	72227.30
1	10.95	4.58	50.91	2.30	17.78	11.99	1.49	72245.01
2	10.99	1.81	57.97	2.08	18.96	11.67	1.49	74255.11
3	9.48	1.55	57.85	2.16	17.99	11.80	1.49	73491.80
4	11.39	2.69	60.15	2.14	18.14	11.48	1.49	75788.61
5	17.22	10.30	50.98	3.32	16.57	12.19	1.49	68840.00
6	10.14	1.45	53.94	2.94	16.43	12.23	1.47	71883.60
7	13.10	1.16	55.81	2.86	16.91	12.04	1.44	73516.36
8	11.28	3.19	58.27	3.09	16.18	12.56	1.43	69804.25
9	7.05	2.80	65.03	2.79	16.87	12.70	1.46	68937.75
10	11.44	1.44	44.86	2.66	17.29	11.87	1.43	74220.26
11	10.83	1.92	40.01	2.92	16.44	11.93	1.44	74606.89
12	11.97	11.72	42.19	3.02	16.04	12.07	1.46	73623.24
13	10.24	1.35	41.92	2.99	16.09	12.23	1.46	72071.13
14	11.34	2.47	43.31	3.15	15.22	12.16	1.43	73105.76
15	11.71	4.11	39.73	3.20	15.35	12.34	1.44	72103.05
16	9.72	1.80	39.63	2.93	16.09	12.16	1.46	72996.74
17	8.04	1.78	45.59	2.88	16.42	12.27	1.46	71609.84
18	9.94	0.94	45.06	2.63	16.65	11.98	1.46	73927.33
19	8.99	1.31	50.23	2.54	16.90	12.11	1.46	72165.88
20	11.32	2.43	41.15	2.91	16.10	12.10	1.46	72875.72
21	9.45	2.93	41.38	2.90	16.05	12.12	1.46	73091.89
22	9.91	2.36	45.33	2.76	16.02	12.17	1.46	72645.44
23	10.86	6.89	44.38	2.82	16.00	12.20	1.46	72377.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.71	3.57	48.54	2.76	16.65	12.10	1.46	72600.44
最大值	17.22	12.58	65.03	3.32	18.96	12.70	1.55	75788.61
發生時間	5	0	9	5	2	9		4
最小值	7.05	0.94	39.63	2.08	15.22	11.48	1.41	68840.00
發生時間	9	18	16	2	14	4		5
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	3.39 %	0.48 %	-0.61 %	-0.05 %		0.26	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.22	6.95	48.44	2.05	15.45	10.60	1.41	63379.55
1	10.74	9.27	48.46	2.03	15.51	10.68	1.41	62217.33
2	10.66	2.80	48.19	2.19	15.05	10.73	1.40	62397.45
3	9.82	3.22	50.72	2.12	15.42	10.80	1.40	62142.37
4	9.74	6.81	48.15	2.18	14.32	10.83	1.40	61201.97
5	8.33	6.23	54.52	2.22	14.30	11.12	1.40	60728.97
6	2.13	8.36	53.43	2.06	14.45	10.95	1.41	61230.68
7	10.18	7.04	54.62	2.25	14.84	10.90	1.43	65673.94
8	10.34	2.35	47.61	1.97	16.16	10.51	1.38	65962.37
9	10.16	1.22	46.44	1.74	17.45	10.23	1.37	65292.58
10	10.80	3.57	46.03	2.10	15.50	10.35	1.37	64210.66
11	10.36	1.80	47.13	2.18	14.87	10.70	1.38	64660.41
12	10.52	4.58	49.77	2.32	14.65	10.75	1.40	63818.41
13	11.03	6.75	51.85	2.44	14.09	10.86	1.38	64030.43
14	16.56	8.64	54.94	3.56	13.20	11.11	1.37	63621.50
15	10.57	2.96	53.09	3.38	14.20	10.82	1.35	62729.31
16	10.41	1.19	56.05	2.65	15.81	10.18	1.37	65942.76
17	10.35	0.75	52.37	2.74	15.70	10.77	1.38	63261.98
18	10.52	2.33	50.30	2.28	16.44	10.73	1.37	62621.63
19	10.36	1.89	49.93	2.09	15.74	10.74	1.37	65262.88
20	11.79	4.52	53.31	2.42	14.12	11.25	1.36	64500.02
21	12.06	4.81	52.68	2.67	13.52	11.41	1.36	64485.30
22	9.91	1.69	51.44	2.51	14.00	11.30	1.37	64939.47
23	10.54	3.43	51.53	2.45	14.18	11.26	1.36	64423.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.34	4.30	50.88	2.36	14.96	10.82	1.38	63697.29
最大值	16.56	9.27	56.05	3.56	17.45	11.41	1.44	65962.37
發生時間	14	1	16	14	9	21		8
最小值	2.13	0.75	46.03	1.74	13.20	10.18	1.35	60728.97
發生時間	6	17	10	9	14	16		5
零點偏移(率)	-0.04 %	-0.00 %	-0.01 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	4.22 %	2.35 %	0.08 %	0.42 %		0.25	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

