

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.67	11.87	56.02	3.97	14.11	12.63	1.08	74510.02
1	5.49	12.34	64.61	3.15	14.86	12.93	1.06	70728.80
2	9.30	12.17	53.41	5.12	14.36	12.36	1.07	75598.03
3	4.52	11.26	60.05	3.49	14.97	12.33	1.08	75383.37
4	3.46	11.22	58.85	3.23	14.41	12.45	1.08	75420.58
5	12.05	13.87	61.05	3.70	14.27	12.52	1.10	74794.56
6	8.69	13.90	62.45	2.84	14.99	12.43	1.11	75276.80
7	12.22	13.64	57.58	3.29	15.42	12.21	1.11	77152.13
8	7.37	13.62	61.81	2.86	15.82	12.00	1.09	78840.10
9	8.93	13.89	52.57	3.09	15.05	12.25	1.10	76761.92
10	9.72	13.73	55.32	3.42	13.95	12.37	1.09	76584.19
11	9.26	14.29	64.23	2.99	13.93	12.58	1.09	74581.10
12	11.49	14.24	51.30	4.19	13.64	12.32	1.09	75774.08
13	10.19	14.05	59.33	3.35	14.02	12.52	1.09	74021.57
14	9.46	14.02	59.44	3.18	13.85	12.52	1.09	73940.43
15	3.96	15.08	65.40	1.85	15.16	12.56	1.09	72679.80
16	12.83	14.45	65.95	3.68	13.84	12.48	1.09	75511.03
17	6.33	13.74	62.70	2.48	14.95	12.18	1.09	77624.45
18	10.07	13.74	59.65	3.22	14.01	12.34	1.09	76787.72
19	7.17	13.57	64.85	3.29	14.50	12.18	1.09	77588.21
20	9.42	13.49	60.36	3.02	14.90	12.06	1.09	78006.92
21	10.31	13.76	67.20	2.51	15.93	12.14	1.09	76469.49
22	8.73	13.85	60.88	2.07	16.06	12.27	1.10	75199.23
23	11.75	13.18	52.90	2.75	16.20	11.58	1.10	80854.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.81	13.46	59.91	3.20	14.72	12.34	1.09	75837.03
最大值	12.83	15.08	67.20	5.12	16.20	12.93	1.13	80854.19
發生時間	16	15	21	2	23	1		23
最小值	3.46	11.22	51.30	1.85	13.64	11.58	1.05	70728.80
發生時間	4	4	12	15	12	23		1
零點偏移(率)	-0.01 %	0.01 %	-0.01 %	-0.00 %		-0.16	-0.01	0.20 %
全幅偏移(率)	0.64 %	1.52 %	-0.26 %	1.10 %		-0.03	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.78	12.49	36.56	0.28	17.90	10.89	1.03	80087.63
1	7.59	13.10	58.02	1.09	15.99	11.73	1.04	75893.71
2	6.95	12.88	47.85	1.91	16.21	11.55	1.02	74863.67
3	7.39	11.84	49.26	0.75	16.90	10.66	1.02	77775.36
4	6.66	12.05	59.97	0.35	18.08	10.67	1.02	78404.12
5	6.30	12.24	65.96	0.54	16.91	10.95	1.02	77001.45
6	4.86	11.38	57.56	0.74	16.71	11.23	1.03	80407.54
7	6.51	12.75	54.49	1.40	17.09	11.23	1.04	78139.62
8	6.88	11.96	47.73	1.64	16.55	10.84	1.03	79471.32
9	6.31	12.01	52.37	1.36	17.14	10.85	1.03	79112.95
10	6.06	11.78	50.86	1.09	17.06	10.58	1.03	80198.69
11	6.48	12.47	52.95	1.42	15.60	11.42	1.05	76300.55
12	6.58	13.44	66.36	1.25	15.89	11.74	1.04	75478.50
13	6.48	12.81	45.99	0.63	16.64	11.48	1.03	76686.58
14	6.28	12.25	42.09	1.04	16.21	11.19	1.04	80167.74
15	6.44	12.63	53.32	1.11	15.46	11.55	1.03	77056.91
16	6.32	12.50	55.22	0.89	16.93	11.27	1.02	77718.75
17	6.13	12.05	46.73	0.65	17.09	10.91	1.03	78374.47
18	6.00	12.04	54.13	1.42	16.86	10.78	1.02	79463.70
19	6.21	12.19	65.99	0.71	18.07	10.87	1.03	80944.46
20	6.06	12.42	46.55	1.74	17.26	10.78	1.03	81655.00
21	6.53	11.84	58.58	1.45	17.59	10.62	1.04	82678.89
22	6.57	11.94	55.09	0.70	19.00	10.53	1.03	82190.49
23	6.52	12.06	57.63	0.38	19.56	10.58	1.02	80904.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.45	12.30	53.39	1.02	17.03	11.04	1.03	78790.70
最大值	7.59	13.44	66.36	1.91	19.56	11.74	1.09	82678.89
發生時間	1	12	12	2	23	12		21
最小值	4.86	11.38	36.56	0.28	15.46	10.53	1.02	74863.67
發生時間	6	6	0	0	15	22		2
零點偏移(率)	0.00 %	-0.00 %	-0.02 %	-0.00 %		-0.12	-0.01	-0.10 %
全幅偏移(率)	-1.09 %	1.26 %	-0.10 %	2.33 %		-0.28	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.88	10.64	37.19	1.84	18.32	9.42	1.37	73714.13
1	9.52	10.88	41.21	2.26	19.06	9.53	1.38	76656.58
2	5.25	11.31	45.20	2.13	17.28	10.28	1.36	63964.48
3	6.81	10.05	33.44	2.79	18.63	8.55	1.34	77946.11
4	8.44	10.29	44.55	2.73	17.27	9.13	1.34	72068.57
5	6.29	10.85	51.15	3.06	18.18	8.53	1.32	73382.36
6	4.55	11.23	61.66	0.29	16.20	10.24	1.33	68255.97
7	4.41	13.27	35.19	1.75	18.09	9.53	1.35	67687.15
8	3.29	11.03	59.37	1.72	18.74	9.51	1.34	75530.78
9	7.20	11.07	53.09	2.22	17.76	9.31	1.35	77655.36
10	2.49	11.23	56.77	1.75	16.89	9.99	1.31	73523.12
11	5.46	11.04	52.80	1.93	16.04	10.02	1.36	72356.23
12	2.08	11.52	57.83	1.42	17.02	10.35	1.35	72762.38
13	2.35	12.10	57.58	1.61	16.18	10.93	1.32	73587.43
14	2.53	11.85	54.85	1.97	15.35	10.84	1.35	75868.39
15	1.26	12.06	61.57	1.87	15.88	10.97	1.36	72255.59
16	5.21	11.55	52.31	1.87	16.14	10.53	1.35	73889.43
17	2.92	11.43	54.82	1.61	16.26	10.54	1.31	73056.69
18	7.61	10.09	62.98	1.62	17.12	10.43	1.32	76003.74
19	8.58	11.58	65.00	1.77	17.69	10.38	1.36	74889.22
20	10.35	13.68	53.05	1.78	17.44	10.39	1.36	76604.95
21	8.19	10.80	50.38	1.77	18.01	10.69	1.36	75036.11
22	10.35	10.64	46.71	1.84	17.72	10.56	1.36	75746.18
23	8.08	11.43	62.76	1.79	18.09	10.66	1.34	71650.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.84	11.32	52.14	1.89	17.31	10.05	1.35	73503.82
最大值	10.35	13.68	65.00	3.06	19.06	10.97	1.39	77946.11
發生時間	20	20	19	5	1	15		3
最小值	1.26	10.05	33.44	0.29	15.35	8.53	1.30	63964.48
發生時間	15	3	3	6	14	5		2
零點偏移(率)	-0.05 %	-0.02 %	-0.11 %	0.00 %		0.01	-0.01	0.00 %
全幅偏移(率)	-1.84 %	0.70 %	0.17 %	0.87 %		0.14	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								