

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月27日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.14	10.86	50.45	1.41	18.68	10.52	1.04	87743.73
1	7.62	2.39	56.75	0.81	17.77	11.48	1.03	82167.69
2	9.16	3.56	58.06	0.72	19.31	11.14	1.03	83732.62
3	9.69	3.34	40.65	1.02	17.76	11.07	1.03	85920.93
4	10.14	4.58	43.56	1.44	17.44	11.17	1.03	85233.14
5	1.32	13.74	67.07	1.76	15.33	13.31	1.05	85059.30
6	3.89	10.41	53.66	1.15	16.24	12.61	1.05	74259.04
7	9.04	7.47	41.42	0.89	18.36	11.17	1.03	84587.25
8	7.97	5.69	29.23	1.20	15.72	11.99	1.04	80851.86
9	9.00	4.55	56.29	1.34	16.74	11.68	1.06	82254.04
10	9.74	4.34	51.76	1.81	15.15	11.70	1.06	83042.60
11	9.72	7.24	56.59	1.49	15.48	11.98	1.05	80405.12
12	10.89	5.34	51.07	3.00	13.31	12.06	1.03	81633.35
13	10.94	3.82	55.06	2.97	13.57	12.20	1.02	79954.01
14	10.55	6.84	51.29	2.55	13.81	12.02	1.02	81393.06
15	11.54	4.97	52.67	2.88	13.46	12.11	1.02	81031.52
16	10.20	5.51	59.77	2.33	13.99	12.00	1.02	81478.11
17	7.29	7.51	64.97	1.46	15.14	11.98	1.03	80756.15
18	8.61	9.83	53.78	1.26	16.58	11.46	1.03	83661.45
19	8.81	6.33	56.19	1.04	16.26	11.59	1.03	83252.86
20	9.62	7.01	51.63	1.12	15.97	11.56	1.02	83622.76
21	9.66	6.47	53.60	1.45	16.29	11.34	1.02	85296.37
22	9.02	6.64	52.62	1.36	16.18	11.50	1.02	83763.48
23	10.25	8.28	61.62	0.89	16.81	11.50	1.03	82827.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.95	6.53	52.91	1.56	16.06	11.71	1.03	82663.67
最 大 值	11.54	13.74	67.07	3.00	19.31	13.31	1.11	87743.73
發生時間	15	5	5	12	2	5		0
最 小 值	1.32	2.39	29.23	0.72	13.31	10.52	1.02	74259.04
發生時間	5	1	8	2	12	0		6
零點偏移(率)	-0.05 %	-0.00 %	-0.01 %	0.01 %		-0.05		0.10 %
全幅偏移(率)	0.00 %	0.29 %	0.75 %	0.22 %		0.34		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月27日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.24	5.54	43.19	1.88	14.66	12.40	1.07	72010.93
1	4.03	5.87	32.77	2.80	15.31	11.82	1.06	76247.52
2	8.26	4.00	39.27	1.49	16.84	11.29	1.06	79060.23
3	7.79	4.38	32.54	1.73	16.06	11.53	1.06	77927.06
4	6.87	4.81	49.74	2.70	15.44	11.90	1.07	75542.87
5	6.44	6.46	53.16	1.52	17.90	11.12	1.09	79035.50
6	5.10	10.33	55.03	3.19	15.11	11.74	1.06	79037.18
7	4.38	4.16	51.32	1.84	17.10	11.37	1.07	78236.69
8	4.61	3.74	40.24	1.43	17.04	11.11	1.06	80400.11
9	8.86	3.51	42.41	2.03	15.51	11.41	1.06	79335.00
10	7.22	7.25	40.21	3.19	13.84	11.48	1.06	78766.92
11	1.91	2.75	45.90	3.05	12.57	11.97	1.06	77218.65
12	8.69	4.95	49.04	4.54	11.19	12.29	1.06	74300.02
13	9.36	1.47	53.58	1.93	12.49	12.48	1.06	72752.96
14	9.57	6.30	42.49	3.56	11.60	12.34	1.07	74423.93
15	12.22	7.48	47.27	3.32	11.50	12.36	1.09	74516.82
16	9.26	2.41	39.23	3.40	12.14	12.06	1.09	77066.88
17	8.15	0.96	44.17	2.65	14.22	11.61	1.10	78511.52
18	6.10	4.06	56.07	1.38	15.92	11.66	1.09	76802.82
19	2.04	4.66	45.39	1.24	17.43	10.99	1.08	80977.58
20	5.94	5.37	40.94	2.02	15.53	11.39	1.06	79252.45
21	5.53	3.92	41.69	2.77	14.85	11.22	1.06	81153.92
22	7.06	4.35	54.49	2.50	15.24	11.38	1.06	79571.21
23	9.70	3.43	59.08	2.03	16.74	11.06	1.06	80416.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.72	4.67	45.80	2.42	14.84	11.67	1.07	77606.87
最 大 值	12.22	10.33	59.08	4.54	17.90	12.48	1.13	81153.92
發生時間	15	6	23	12	5	13		21
最 小 值	1.91	0.96	32.54	1.24	11.19	10.99	1.06	72010.93
發生時間	11	17	3	19	12	19		0
零點偏移(率)	-0.06 %	0.00 %	-0.01 %	-0.00 %		-0.02		0.10 %
全幅偏移(率)	0.13 %	-0.50 %	-0.27 %	0.04 %		0.11		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年02月27日

報表日期: 113年02月27日

[illegible]