

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月20日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.43	5.15	49.65	0.91	18.86	10.40	1.34	83859.37
1	4.30	4.71	58.73	1.08	19.20	10.75	1.34	80731.40
2	6.17	3.12	53.36	1.34	17.96	10.62	1.34	80666.53
3	9.08	2.99	52.67	1.53	17.91	10.65	1.34	79804.17
4	6.40	3.46	55.47	1.24	18.13	10.71	1.33	79117.11
5	6.59	1.49	61.10	1.21	19.34	10.51	1.35	82171.73
6	8.87	2.93	54.17	0.94	19.38	10.16	1.34	82806.88
7	5.07	5.20	53.31	0.48	20.08	10.08	1.36	84083.56
8	7.65	6.30	43.26	1.52	18.24	10.23	1.36	81728.80
9	9.10	1.59	48.38	1.20	18.74	10.24	1.37	81091.84
10	10.58	4.11	48.07	1.37	18.56	10.03	1.37	80863.37
11	7.87	2.55	48.05	1.40	18.08	10.55	1.34	77609.62
12	8.06	3.93	44.73	0.85	18.65	10.10	1.34	80949.91
13	7.44	5.43	41.17	1.79	17.27	10.42	1.34	78235.80
14	9.79	2.05	43.29	1.27	18.36	10.20	1.35	79639.86
15	4.92	1.68	60.42	0.38	19.20	10.53	1.34	75592.28
16	7.95	3.43	54.95	0.64	19.47	10.37	1.36	80614.12
17	9.63	2.96	53.75	1.13	18.78	10.74	1.37	81130.84
18	12.58	8.72	56.24	1.33	17.71	10.79	1.36	81664.56
19	11.50	3.35	49.32	1.60	16.43	10.93	1.36	81258.70
20	7.50	2.87	50.96	1.58	16.74	10.87	1.36	81177.45
21	7.27	5.65	55.62	1.02	18.24	10.55	1.38	82878.02
22	9.77	5.32	46.14	0.96	18.33	10.58	1.38	82377.21
23	12.60	4.69	55.60	0.74	19.30	10.34	1.37	84363.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.26	3.90	51.60	1.15	18.46	10.47	1.35	81017.37
最 大 值	12.60	8.72	61.10	1.79	20.08	10.93	1.39	84363.77
發生時間	23	18	5	13	7	19		23
最 小 值	4.30	1.49	41.17	0.38	16.43	10.03	1.32	75592.28
發生時間	1	5	13	15	19	10		15
零點偏移(率)	0.08 %	-0.00 %	-0.11 %	-0.00 %		-0.30		0.30 %
全幅偏移(率)	0.77 %	0.00 %	-0.56 %	0.98 %		0.12		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月20日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.68	2.69	47.67	1.66	18.13	10.22	1.06	83657.81
1	8.95	5.74	51.90	2.12	19.13	10.13	1.06	84825.04
2	9.44	4.99	47.79	2.73	16.07	10.55	1.07	84541.34
3	9.04	2.30	54.68	2.50	16.77	10.71	1.09	80315.54
4	9.11	2.57	57.87	2.02	17.77	10.60	1.09	81402.08
5	10.21	4.52	53.43	2.35	18.06	10.11	1.09	84909.20
6	7.39	1.16	52.64	1.79	17.98	10.05	1.09	89760.40
7	8.67	2.34	53.06	2.60	17.09	10.30	1.08	84934.23
8	9.37	2.23	62.17	2.53	17.32	10.34	1.09	83672.57
9	9.09	3.34	45.87	2.96	16.64	10.41	1.10	81683.22
10	9.32	3.34	47.66	3.15	16.16	10.54	1.09	80930.93
11	7.46	4.07	46.13	2.49	15.56	10.83	1.09	78966.63
12	8.70	4.86	55.63	2.44	15.70	10.64	1.09	82489.39
13	9.05	1.65	61.81	2.41	16.55	10.67	1.08	82460.78
14	10.05	2.04	65.19	2.33	16.55	10.60	1.09	83449.39
15	8.89	2.22	60.13	2.50	16.78	10.80	1.08	81620.57
16	8.75	4.27	53.56	2.42	16.51	10.50	1.09	82636.07
17	10.06	4.31	48.07	3.22	15.59	10.49	1.07	81632.55
18	8.93	2.56	50.13	3.05	15.01	10.90	1.08	80724.78
19	7.73	1.95	60.26	1.97	16.32	11.25	1.09	78599.48
20	9.17	2.61	55.83	2.04	16.82	10.75	1.09	78547.43
21	9.04	4.09	51.43	1.46	18.88	9.88	1.09	85775.39
22	9.61	1.71	60.69	2.45	16.95	10.43	1.09	86819.83
23	9.49	2.21	60.31	2.61	15.47	10.80	1.10	85090.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.01	3.07	54.33	2.41	16.83	10.52	1.08	82893.55
最 大 值	10.21	5.74	65.19	3.22	19.13	11.25	1.10	89760.40
發生時間	5	1	14	17	1	19		6
最 小 值	7.39	1.16	45.87	1.46	15.01	9.88	1.06	78547.43
發生時間	6	6	9	21	18	21		20
零點偏移(率)	-0.12 %	0.00 %	-0.01 %	-0.00 %		-0.01		0.00 %
全幅偏移(率)	0.14 %	-0.02 %	0.79 %	0.15 %		0.06		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月20日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	4.03	2.80	57.14	1.64	18.20	9.43	1.52	81472.96
1	3.40	4.51	59.42	1.65	19.61	9.29	1.54	84413.07
2	3.84	4.29	57.89	1.92	17.15	9.72	1.57	84717.56
3	4.82	3.02	62.91	1.99	16.63	10.29	1.57	82548.35
4	6.10	4.13	58.44	2.00	18.66	9.56	1.57	84737.06
5	6.11	5.38	60.59	1.98	18.41	9.63	1.57	86519.60
6	7.38	3.87	61.42	2.16	17.52	9.99	1.57	81944.40
7	6.52	4.30	53.72	2.31	18.08	9.66	1.54	79130.32
8	9.77	5.60	58.34	2.49	17.77	9.46	1.54	83857.37
9	11.38	2.60	67.13	2.41	17.67	9.98	1.53	81693.65
10	11.25	6.55	57.78	2.82	18.12	9.83	1.55	83972.95
11	12.33	7.13	51.43	2.27	17.73	9.63	1.58	82154.64
12	6.62	7.70	50.03	2.10	17.39	9.39	1.58	81514.32
13	7.36	4.95	52.34	1.94	18.11	9.39	1.53	81479.06
14	9.99	3.44	61.58	2.35	18.15	9.61	1.52	86927.00
15	6.21	9.03	50.18	2.01	16.11	9.90	1.53	76541.66
16	7.62	6.44	55.05	2.85	15.21	10.33	1.51	79620.27
17	10.63	1.26	58.73	2.50	15.74	10.40	1.54	78741.31
18	11.70	3.32	64.73	2.65	16.36	10.14	1.54	81840.29
19	10.81	5.27	60.63	2.79	15.30	10.57	1.53	78993.96
20	6.60	2.68	56.94	1.84	17.67	9.99	1.55	83903.80
21	9.18	2.26	61.27	2.02	18.48	9.84	1.56	84103.16
22	14.64	8.87	59.10	2.19	17.11	9.90	1.53	83410.79
23	10.20	5.58	60.54	2.62	16.04	10.25	1.52	82199.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.27	4.79	58.22	2.23	17.38	9.84	1.55	82351.53
最 大 值	14.64	9.03	67.13	2.85	19.61	10.57	1.60	86927.00
發生時間	22	15	9	16	1	19		14
最 小 值	3.40	1.26	50.03	1.64	15.21	9.29	1.50	76541.66
發生時間	1	17	12	0	16	1		15
零點偏移(率)	-0.06 %	-0.01 %	-0.06 %	-0.03 %		0.01		-0.10 %
全幅偏移(率)	0.02 %	0.32 %	0.08 %	0.13 %		0.33		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								