

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月16日

| 項目<br>單位<br>小時\限標 | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 1.08     | 8.01     | 64.47    | 1.79     | 17.53    | 11.77    | 1.25     | 78121.84  |
| 1                 | 1.03     | 8.02     | 54.67    | 2.38     | 17.93    | 11.44    | 1.25     | 80940.02  |
| 2                 | 2.16     | 8.30     | 59.35    | 1.81     | 17.74    | 11.86    | 1.26     | 77752.82  |
| 3                 | 3.15     | 7.78     | 44.03    | 2.10     | 18.36    | 11.17    | 1.26     | 83267.80  |
| 4                 | 10.11    | 9.95     | 50.01    | 3.64     | 16.09    | 11.79    | 1.25     | 80837.94  |
| 5                 | 5.12     | 8.69     | 51.63    | 2.29     | 14.50    | 12.11    | 1.25     | 81277.08  |
| 6                 | 11.38    | 7.18     | 59.51    | 3.61     | 16.51    | 11.68    | 1.25     | 80957.20  |
| 7                 | 7.84     | 7.42     | 51.16    | 3.74     | 16.00    | 11.75    | 1.25     | 81434.91  |
| 8                 | 10.97    | 10.74    | 50.43    | 3.94     | 15.88    | 11.74    | 1.25     | 80879.42  |
| 9                 | 2.42     | 8.70     | 55.57    | 3.02     | 15.55    | 12.09    | 1.24     | 77570.61  |
| 10                | 3.22     | 9.66     | 51.62    | 1.92     | 16.68    | 11.87    | 1.25     | 77539.78  |
| 11                | 10.17    | 8.37     | 47.67    | 3.17     | 16.34    | 11.81    | 1.25     | 79296.39  |
| 12                | 7.37     | 8.02     | 59.47    | 2.66     | 16.29    | 11.96    | 1.25     | 77818.50  |
| 13                | 8.36     | 8.57     | 53.83    | 3.39     | 15.48    | 12.13    | 1.25     | 76878.10  |
| 14                | 11.00    | 8.78     | 61.75    | 3.05     | 16.22    | 11.91    | 1.25     | 79422.89  |
| 15                | 9.31     | 8.98     | 53.05    | 3.76     | 13.96    | 12.16    | 1.25     | 75405.70  |
| 16                | 6.92     | 8.83     | 53.07    | 1.94     | 15.83    | 11.79    | 1.25     | 78556.45  |
| 17                | 4.94     | 7.88     | 58.00    | 1.57     | 17.20    | 11.58    | 1.25     | 80205.25  |
| 18                | 9.94     | 7.23     | 55.11    | 3.39     | 16.46    | 11.45    | 1.25     | 80462.00  |
| 19                | 5.86     | 8.61     | 48.91    | 3.16     | 16.17    | 11.55    | 1.25     | 79832.47  |
| 20                | 9.35     | 9.90     | 43.48    | 3.38     | 15.82    | 11.55    | 1.25     | 79710.86  |
| 21                | 5.96     | 7.75     | 55.12    | 2.57     | 16.80    | 11.38    | 1.25     | 81731.86  |
| 22                | 7.61     | 8.11     | 50.28    | 3.48     | 15.74    | 11.68    | 1.25     | 80512.40  |
| 23                | 8.24     | 7.79     | 51.23    | 3.48     | 16.37    | 11.63    | 1.25     | 80334.33  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 6.81     | 8.47     | 53.48    | 2.89     | 16.31    | 11.74    | 1.25     | 79614.44  |
| 最 大 值             | 11.38    | 10.74    | 64.47    | 3.94     | 18.36    | 12.16    | 1.27     | 83267.80  |
| 發生時間              | 6        | 8        | 0        | 8        | 3        | 15       |          | 3         |
| 最 小 值             | 1.03     | 7.18     | 43.48    | 1.57     | 13.96    | 11.17    | 1.23     | 75405.70  |
| 發生時間              | 1        | 6        | 20       | 17       | 15       | 3        |          | 15        |
| 零點偏移(率)           | -0.06 %  | -0.09 %  | -0.01 %  | 0.00 %   |          | -0.06    |          | 0.10 %    |
| 全幅偏移(率)           | 0.00 %   | 1.11 %   | -0.85 %  | 1.45 %   |          | -0.20    |          | 0.20 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月16日

| 項目<br>單位<br>小時\限標 | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 7.62     | 9.54     | 63.15    | 2.56     | 17.98    | 11.00    | 1.03     | 80915.50  |
| 1                 | 7.59     | 7.06     | 61.14    | 1.70     | 20.16    | 10.52    | 1.02     | 82511.63  |
| 2                 | 9.47     | 7.20     | 53.38    | 2.16     | 18.99    | 10.48    | 1.02     | 83975.93  |
| 3                 | 9.00     | 7.43     | 51.73    | 2.65     | 17.83    | 10.80    | 1.02     | 80784.47  |
| 4                 | 8.37     | 7.03     | 57.42    | 2.15     | 18.54    | 10.77    | 1.03     | 81283.36  |
| 5                 | 10.13    | 7.33     | 54.14    | 3.32     | 16.32    | 11.12    | 1.02     | 79606.39  |
| 6                 | 10.62    | 7.86     | 56.33    | 4.32     | 17.04    | 11.10    | 1.02     | 91179.76  |
| 7                 | 8.13     | 7.76     | 55.57    | 3.37     | 16.81    | 11.13    | 1.02     | 81393.87  |
| 8                 | 8.55     | 6.88     | 58.18    | 2.74     | 17.32    | 10.96    | 1.02     | 81738.02  |
| 9                 | 10.68    | 7.03     | 56.62    | 2.36     | 17.84    | 10.98    | 1.00     | 78857.63  |
| 10                | 9.89     | 8.15     | 58.27    | 2.01     | 18.50    | 10.70    | 1.00     | 78325.02  |
| 11                | 7.22     | 8.26     | 59.92    | 2.47     | 17.48    | 10.96    | 1.00     | 79600.51  |
| 12                | 8.83     | 8.10     | 52.71    | 2.78     | 18.15    | 10.51    | 1.00     | 82138.27  |
| 13                | 8.44     | 8.69     | 57.91    | 3.40     | 16.30    | 11.23    | 0.98     | 77793.12  |
| 14                | 10.11    | 8.86     | 58.61    | 3.13     | 16.28    | 11.02    | 0.97     | 78602.95  |
| 15                | 10.54    | 8.64     | 58.64    | 2.91     | 17.60    | 10.65    | 0.99     | 79621.69  |
| 16                | 8.26     | 8.10     | 53.38    | 2.37     | 18.42    | 10.21    | 1.00     | 83946.12  |
| 17                | 9.29     | 8.09     | 53.71    | 2.55     | 17.70    | 10.59    | 1.02     | 83093.29  |
| 18                | 7.44     | 8.06     | 56.38    | 2.36     | 17.35    | 10.79    | 1.01     | 83203.94  |
| 19                | 9.10     | 8.19     | 60.41    | 2.71     | 16.51    | 10.98    | 1.01     | 82529.40  |
| 20                | 8.84     | 8.14     | 60.77    | 2.82     | 16.64    | 10.91    | 1.02     | 83233.52  |
| 21                | 8.31     | 8.18     | 58.14    | 2.73     | 16.53    | 10.93    | 1.02     | 80623.15  |
| 22                | 9.29     | 9.77     | 61.01    | 3.06     | 15.50    | 11.36    | 1.01     | 79501.01  |
| 23                | 8.76     | 9.23     | 55.89    | 2.66     | 16.48    | 11.21    | 1.00     | 78734.11  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 8.94     | 8.07     | 57.23    | 2.72     | 17.43    | 10.87    | 1.01     | 81383.03  |
| 最 大 值             | 10.68    | 9.77     | 63.15    | 4.32     | 20.16    | 11.36    | 1.04     | 91179.76  |
| 發生時間              | 9        | 22       | 0        | 6        | 1        | 22       |          | 6         |
| 最 小 值             | 7.22     | 6.88     | 51.73    | 1.70     | 15.50    | 10.21    | 0.95     | 77793.12  |
| 發生時間              | 11       | 8        | 3        | 1        | 22       | 16       |          | 13        |
| 零點偏移(率)           | -0.05 %  | -0.12 %  | -0.06 %  | -0.01 %  |          | -0.13    |          | -0.10 %   |
| 全幅偏移(率)           | 0.13 %   | -0.51 %  | -0.26 %  | -0.64 %  |          | -0.06    |          | 0.00 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月16日

報表日期: 114年07月16日

[illegible]