

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月13日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.97	11.23	42.96	2.91	17.45	10.92	0.99	83974.87
1	8.11	9.21	57.07	0.67	19.57	11.46	1.00	80134.74
2	9.97	12.91	47.83	2.22	16.18	11.54	1.01	82458.69
3	9.12	12.66	45.82	2.83	15.57	11.10	1.02	84642.97
4	8.71	4.49	41.08	1.42	16.60	10.80	1.02	82584.24
5	5.77	11.10	46.16	0.33	17.52	11.04	1.00	82153.36
6	7.18	11.93	52.27	0.25	17.98	11.36	1.00	80284.39
7	6.25	11.43	56.31	0.30	18.33	11.16	1.00	83298.89
8	8.42	10.78	42.37	0.56	17.89	10.95	0.98	84763.53
9	9.55	10.90	45.10	0.89	16.96	11.22	1.01	82675.26
10	7.16	8.30	47.12	0.53	18.13	10.66	0.99	86963.07
11	4.19	10.46	47.67	0.45	17.50	10.93	1.00	84630.62
12	4.82	3.96	60.03	0.30	18.80	10.88	1.00	83718.90
13	9.19	5.66	48.67	0.67	18.14	10.84	0.99	86121.61
14	9.67	12.26	63.51	0.49	18.23	11.00	0.99	84104.33
15	9.64	10.12	59.91	0.37	18.81	10.84	1.01	85243.67
16	5.67	10.29	54.79	0.55	18.54	11.02	1.00	83276.17
17	2.72	11.18	50.20	0.63	16.53	11.62	0.99	79606.50
18	2.10	9.39	66.26	0.30	18.46	11.14	0.98	82985.26
19	3.70	10.92	49.29	0.50	17.67	11.21	0.98	83454.53
20	3.56	10.72	67.53	0.47	18.05	11.34	0.99	81926.40
21	1.84	11.95	55.30	0.28	18.35	11.28	1.00	82355.95
22	4.80	9.96	60.83	0.38	18.80	10.82	1.00	85124.18
23	6.77	11.20	62.31	0.27	18.62	11.16	0.99	82494.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.58	10.13	52.93	0.77	17.86	11.10	1.00	83290.70
最大值	9.97	12.91	67.53	2.91	19.57	11.62	1.03	86963.07
發生時間	2	2	20	0	1	17		10
最小值	1.84	3.96	41.08	0.25	15.57	10.66	0.97	79606.50
發生時間	21	12	4	6	3	10		17
零點偏移(率)	-0.01 %	0.00 %	-0.04 %	-0.01 %		0.06		0.00 %
全幅偏移(率)	0.00 %	3.75 %	0.29 %	1.19 %		-0.03		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月13日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.86	5.04	54.51	0.96	17.86	9.78	1.14	81552.96
1	9.03	5.98	58.02	1.30	17.72	10.07	1.15	80081.50
2	9.50	6.40	53.16	1.19	16.67	9.88	1.15	80319.53
3	6.06	9.85	41.94	1.33	16.11	9.55	1.15	73980.48
4	0.55	4.28	45.79	0.52	18.42	8.96	1.14	73507.75
5	5.10	6.39	50.47	0.59	17.80	9.07	1.15	80059.57
6	7.51	9.32	45.07	0.48	19.46	9.33	1.11	77613.91
7	8.59	8.40	55.76	0.71	17.69	9.50	1.11	79134.15
8	2.96	16.75	51.05	0.62	17.30	9.62	1.10	69882.86
9	6.08	13.38	43.43	0.39	17.73	8.62	1.10	75817.31
10	8.73	5.99	53.21	0.60	17.81	8.83	1.11	81433.12
11	6.78	12.39	65.34	0.79	16.49	9.85	1.12	78650.16
12	6.10	無效	43.79	1.00	16.38	9.61	1.11	76602.61
13	9.07	7.63	39.68	0.76	17.92	9.25	1.10	80888.23
14	8.53	無效	48.78	1.06	16.60	9.84	1.10	71270.06
15	6.82	7.27	37.94	0.52	18.26	9.48	1.10	71785.21
16	8.69	10.19	53.05	0.90	17.79	9.29	1.12	83826.07
17	6.41	4.50	56.52	0.61	17.74	9.79	1.13	81765.37
18	8.30	3.92	58.15	1.05	16.92	10.05	1.12	81423.59
19	7.91	3.76	61.59	1.09	16.70	10.26	1.10	76597.19
20	7.83	3.86	62.67	0.47	17.77	10.06	1.10	77308.49
21	9.79	4.23	59.99	0.81	17.50	10.27	1.10	83270.50
22	8.17	4.54	55.11	0.43	18.24	10.03	1.10	82785.12
23	6.03	5.95	59.22	0.63	17.82	10.13	1.10	81373.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	22	24	24	24	24	24	24
平均值	7.23	7.27	52.26	0.78	17.53	9.63	1.12	78372.05
最大值	9.79	16.75	65.34	1.33	19.46	10.27	1.15	83826.07
發生時間	21	8	11	3	6	21		16
最小值	0.55	3.76	37.94	0.39	16.11	8.62	1.10	69882.86
發生時間	4	19	15	9	3	9		8
零點偏移(率)	-0.08 %	-0.00 %	-0.02 %	-0.07 %		0.08		0.00 %
全幅偏移(率)	0.04 %	3.19 %	0.44 %	1.63 %		-0.01		0.00 %
有效比率	100.00 %	91.67%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月13日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.67	10.10	48.22	2.27	15.73	10.80	1.04	76644.09
1	4.64	8.05	47.95	2.34	15.94	10.74	1.00	74274.27
2	6.04	12.82	48.61	2.34	15.05	10.73	1.01	75853.60
3	7.31	8.86	42.40	3.06	13.53	10.54	1.02	75316.62
4	8.41	8.26	44.66	2.75	15.18	9.92	1.02	76337.29
5	9.13	7.87	59.39	2.27	15.57	10.21	1.03	77974.93
6	8.21	7.66	47.55	1.95	16.03	10.47	1.05	78774.18
7	9.56	13.31	37.18	1.78	16.06	9.86	1.01	76518.87
8	9.82	無效	36.20	3.74	13.60	10.20	1.01	72604.69
9	7.33	5.46	43.02	3.73	12.23	11.02	0.99	69709.06
10	8.03	6.02	45.16	2.37	14.43	10.69	1.03	71477.39
11	3.11	6.24	50.79	2.12	14.38	10.81	0.99	70441.73
12	4.16	7.44	42.57	1.76	15.06	10.54	0.99	72717.73
13	5.41	6.97	48.54	2.26	14.24	10.91	0.97	69660.98
14	4.55	9.39	51.46	2.14	14.76	11.07	1.00	69082.50
15	0.83	5.92	50.54	1.49	15.78	10.55	1.03	73265.34
16	4.50	7.99	47.16	3.16	14.64	10.90	1.05	75395.46
17	3.14	5.19	58.86	1.67	16.42	10.95	1.06	77117.77
18	1.78	5.84	58.47	1.38	16.91	10.63	1.03	80408.57
19	1.74	7.16	53.44	1.54	15.94	10.88	0.99	79985.34
20	2.69	11.97	55.99	1.46	17.32	10.68	1.00	82597.93
21	5.69	9.22	55.84	1.59	16.63	10.85	1.03	83088.22
22	3.28	7.63	54.18	1.80	15.82	10.99	1.05	81557.70
23	4.87	9.12	53.75	1.87	16.21	10.84	1.05	82123.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	23	24	24	24	24	24	24
平均值	5.50	8.20	49.25	2.20	15.31	10.66	1.02	75955.33
最大值	9.82	13.31	59.39	3.74	17.32	11.07	1.06	83088.22
發生時間	8	7	5	8	20	14		21
最小值	0.83	5.19	36.20	1.38	12.23	9.86	0.97	69082.50
發生時間	15	17	8	18	9	7		14
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	0.00 %		0.04		0.00 %
全幅偏移(率)	0.04 %	0.75 %	-0.64 %	0.19 %		0.31		0.10 %
有效比率	100.00 %	95.83%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								