

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月19日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.35	4.23	42.32	3.24	14.59	12.58	1.37	69012.41
1	3.01	2.87	52.53	2.97	15.51	12.25	1.38	70562.34
2	8.45	3.99	47.66	3.71	14.57	12.56	1.38	68680.35
3	8.02	3.63	43.21	4.69	13.32	12.90	1.38	68191.51
4	10.10	2.55	59.43	5.10	12.76	12.93	1.38	68304.68
5	6.41	3.39	61.35	3.67	13.81	12.70	1.39	63989.50
6	2.64	2.46	62.14	2.83	15.00	12.32	1.40	69432.06
7	2.89	3.25	46.76	3.54	13.68	12.37	1.41	69432.12
8	3.61	3.39	64.52	3.88	13.42	12.90	1.43	65563.30
9	2.56	3.14	57.78	3.61	13.59	12.77	1.44	66749.62
10	7.63	3.34	55.31	3.54	14.26	12.42	1.42	68805.35
11	10.49	5.10	52.31	4.39	13.05	12.76	1.39	66491.40
12	8.44	6.08	50.56	4.76	12.42	12.94	1.37	65373.91
13	9.53	2.93	62.27	3.91	13.90	12.57	1.40	67163.32
14	8.59	5.79	52.85	4.50	13.14	12.95	1.41	63485.46
15	10.28	3.81	49.39	4.46	12.90	12.61	1.42	67504.31
16	9.30	3.35	58.34	4.06	13.66	12.66	1.41	66511.61
17	10.30	2.87	64.88	3.57	14.79	12.39	1.42	67961.37
18	8.32	3.73	51.11	3.54	14.47	12.55	1.42	67059.44
19	6.44	3.98	68.86	3.00	14.78	12.55	1.41	65887.45
20	8.09	4.10	56.12	3.32	14.77	12.61	1.40	66144.67
21	0.56	5.16	62.81	2.84	15.24	12.91	1.43	63386.95
22	1.39	3.99	38.27	2.42	16.05	12.05	1.41	69509.36
23	5.56	3.30	47.62	2.99	14.82	12.16	1.42	69070.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.42	3.77	54.52	3.69	14.10	12.60	1.40	67261.38
最大值	10.49	6.08	68.86	5.10	16.05	12.95	1.48	70562.34
發生時間	11	12	19	4	22	14		1
最小值	0.56	2.46	38.27	2.42	12.42	12.05	1.36	63386.95
發生時間	21	6	22	22	12	22		21
零點偏移(率)	-0.05 %	-0.01 %	-0.16 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	2.64 %	-4.51 %	-0.28 %	0.15 %		0.22	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月19日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.05	5.47	53.66	2.29	16.45	11.25	1.59	78910.39
1	8.37	3.88	60.70	2.02	17.84	10.62	1.62	83362.47
2	6.67	4.65	58.94	2.09	18.32	10.82	1.62	82368.26
3	10.62	4.49	47.27	1.94	20.21	9.95	1.62	88271.07
4	10.45	3.90	52.96	2.18	19.00	10.16	1.62	85832.47
5	7.57	1.37	54.55	2.01	19.26	10.63	1.62	81724.71
6	8.57	8.28	46.77	1.57	19.41	10.51	1.56	87072.36
7	4.93	6.35	57.60	1.43	19.69	10.74	1.57	80568.95
8	9.78	4.27	45.69	1.94	19.05	10.20	1.57	87720.34
9	9.96	3.68	48.90	2.20	17.03	10.74	1.54	83881.80
10	8.82	3.82	47.17	2.72	16.51	10.59	1.50	80757.09
11	8.89	4.07	49.99	2.43	17.45	10.44	1.49	83996.55
12	9.68	5.10	41.88	2.67	17.11	10.59	1.51	83282.48
13	10.01	4.26	45.91	2.70	16.86	10.69	1.54	83362.47
14	10.03	3.71	45.10	2.41	17.47	10.38	1.55	83155.81
15	9.47	3.47	49.25	2.45	17.06	10.38	1.50	82663.99
16	9.72	3.86	44.09	2.56	17.75	10.07	1.51	83250.49
17	9.63	4.03	41.82	2.15	17.97	10.24	1.51	83203.94
18	10.28	4.59	43.17	2.11	18.38	10.13	1.53	84392.25
19	10.40	5.51	49.28	2.32	17.91	10.47	1.56	82323.59
20	8.95	3.85	44.85	2.14	18.05	10.16	1.56	84473.63
21	9.94	2.73	50.39	2.19	18.04	10.14	1.53	84986.17
22	12.50	4.00	50.12	2.67	16.90	10.38	1.53	84897.08
23	10.01	2.32	47.29	2.53	16.58	10.50	1.53	80774.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.22	4.24	49.06	2.24	17.93	10.45	1.55	83551.38
最大值	12.50	8.28	60.70	2.72	20.21	11.25	1.62	88271.07
發生時間	22	6	1	10	3	0		3
最小值	4.93	1.37	41.82	1.43	16.45	9.95	1.49	78910.39
發生時間	7	5	17	7	0	3		0
零點偏移(率)	-0.22 %	-0.05 %	-0.32 %	-0.06 %		-0.04	0.00	0.00 %
全幅偏移(率)	2.46 %	-2.48 %	-0.21 %	0.38 %		0.08	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月19日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.74	4.12	54.05	2.48	16.71	10.87	1.38	84930.16
1	8.79	3.52	63.66	2.45	16.89	10.80	1.38	84869.06
2	10.55	3.90	55.28	2.69	17.41	10.61	1.36	85556.26
3	4.92	3.66	69.70	2.34	16.96	11.21	1.37	79810.57
4	7.26	5.05	57.09	2.53	18.70	10.10	1.38	89594.22
5	9.35	4.36	61.78	2.73	18.80	10.07	1.37	90054.05
6	5.64	6.30	64.71	2.48	18.37	10.86	1.38	83409.09
7	7.90	4.41	55.35	2.19	19.29	9.83	1.38	84367.84
8	8.79	3.84	58.27	2.07	18.19	10.34	1.38	87359.26
9	8.03	6.44	56.37	2.01	16.31	10.77	1.38	85800.18
10	8.77	4.43	60.03	2.25	16.23	10.85	1.39	83825.35
11	8.37	7.22	50.61	2.43	15.52	10.70	1.40	81805.16
12	6.30	6.00	54.72	2.35	15.45	10.71	1.38	79713.41
13	9.28	5.97	51.45	2.90	15.32	10.59	1.38	77756.43
14	8.94	3.13	47.73	2.95	15.61	10.41	1.38	79031.61
15	10.46	3.43	55.39	3.45	14.11	11.17	1.38	75506.44
16	6.08	1.64	71.15	1.95	17.61	10.68	1.38	81728.85
17	6.88	1.34	55.41	1.92	18.50	10.31	1.38	83170.08
18	9.81	4.35	60.66	2.44	17.22	10.18	1.38	84677.78
19	9.89	5.29	55.31	2.14	17.07	10.76	1.38	83344.68
20	8.61	5.74	58.61	2.25	16.63	10.72	1.38	84586.86
21	5.98	4.14	61.56	2.08	17.14	10.58	1.40	82422.87
22	8.52	5.69	55.54	2.15	17.40	10.42	1.41	83713.80
23	9.85	5.38	59.06	2.80	14.74	11.08	1.40	81415.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.24	4.56	58.06	2.42	16.92	10.61	1.38	83268.74
最大值	10.55	7.22	71.15	3.45	19.29	11.21	1.42	90054.05
發生時間	2	11	16	15	7	3		5
最小值	4.92	1.34	47.73	1.92	14.11	9.83	1.36	75506.44
發生時間	3	17	14	17	15	7		15
零點偏移(率)	-0.36 %	-0.03 %	-0.24 %	-0.02 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.09 %	-1.91 %	-0.74 %	-0.08 %		-0.08	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								