

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月03日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.08	9.29	66.19	3.53	15.66	12.14	1.25	67926.63
1	1.43	10.19	54.21	3.92	17.19	11.71	1.25	70585.40
2	1.05	9.24	66.58	4.24	16.39	12.10	1.25	67962.86
3	2.96	9.01	62.31	4.04	15.55	12.02	1.26	69263.14
4	3.80	9.20	64.89	4.98	15.06	12.18	1.25	68456.66
5	3.03	7.43	62.16	2.93	14.96	11.92	1.25	68489.10
6	5.21	7.58	65.59	2.60	15.16	12.14	1.25	68635.20
7	9.03	7.48	63.86	2.97	15.02	12.02	1.25	69465.28
8	7.73	8.77	52.17	2.86	15.28	11.97	1.27	69684.56
9	7.87	8.75	61.93	2.81	15.22	11.98	1.27	69994.13
10	6.54	8.94	49.38	2.97	14.33	11.96	1.27	70517.30
11	8.69	9.04	56.23	2.68	15.49	11.97	1.27	69472.12
12	7.69	12.68	53.18	2.90	14.48	11.85	1.26	71297.37
13	6.85	8.92	63.73	2.70	14.86	12.06	1.25	68988.00
14	3.20	8.90	63.86	2.94	13.49	12.39	1.27	67456.04
15	4.91	9.09	66.38	2.92	14.03	12.40	1.26	66461.92
16	7.65	8.71	55.57	2.74	14.61	11.86	1.25	71337.20
17	7.67	8.94	58.05	3.06	14.32	12.02	1.25	69855.23
18	9.21	8.97	60.38	2.62	15.45	11.97	1.26	69343.39
19	7.24	9.05	64.96	2.94	14.48	12.19	1.26	68443.60
20	7.49	9.23	60.12	2.56	15.39	11.88	1.26	69888.94
21	8.79	8.90	63.15	2.72	15.31	11.77	1.25	70306.43
22	5.13	9.65	56.16	2.27	15.38	11.64	1.25	70290.01
23	8.23	8.98	62.64	3.05	15.63	11.70	1.27	70217.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.06	9.04	60.57	3.08	15.11	11.99	1.26	69347.42
最 大 值	9.21	12.68	66.58	4.98	17.19	12.40	1.27	71337.20
發生時間	18	12	2	4	1	15		16
最 小 值	1.05	7.43	49.38	2.27	13.49	11.64	1.24	66461.92
發生時間	2	5	10	22	14	22		15
零點偏移(率)	-0.08 %	-0.11 %	-0.11 %	-0.01 %		0.02		0.00 %
全幅偏移(率)	0.12 %	-1.22 %	0.13 %	0.01 %		0.19		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月03日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.51	7.68	56.01	1.14	19.28	10.49	1.01	82157.72
1	8.33	7.95	49.33	2.12	18.55	10.70	1.01	82846.31
2	10.40	8.03	52.38	3.02	16.90	10.94	1.00	79680.02
3	8.25	7.83	55.02	2.96	16.49	11.05	0.99	81253.57
4	8.24	8.47	58.04	2.81	17.18	10.91	0.99	82086.61
5	6.90	7.78	58.49	2.39	17.48	10.91	0.99	82703.72
6	0.10	8.17	54.79	3.55	16.87	10.83	0.99	87965.88
7	2.60	6.94	56.06	2.53	17.25	10.92	0.99	80961.81
8	8.92	9.76	55.21	3.59	16.38	11.14	1.02	81084.55
9	7.39	7.96	51.06	2.58	18.17	10.70	1.00	82769.74
10	8.34	7.80	51.57	2.56	18.27	10.59	1.00	84524.44
11	8.07	7.91	55.99	2.19	17.91	10.73	1.00	83069.75
12	9.62	7.93	57.89	2.32	18.31	10.75	0.99	82423.59
13	10.59	7.94	50.22	2.04	18.21	10.69	1.01	83039.17
14	7.33	9.34	55.13	2.17	17.24	11.18	1.00	79733.23
15	9.35	9.59	62.12	3.59	15.94	11.16	0.99	81157.94
16	6.75	8.73	58.29	2.83	17.22	10.91	0.98	77652.10
17	8.50	8.69	55.97	2.71	17.73	10.50	0.99	81550.54
18	9.86	9.56	54.71	2.09	16.23	11.09	0.99	80532.82
19	7.90	8.40	52.68	2.80	17.31	10.66	0.98	80866.40
20	10.50	9.56	52.18	2.31	19.01	10.07	0.99	83448.41
21	10.17	10.42	48.35	2.58	18.96	9.87	0.99	85132.76
22	7.69	8.80	57.30	1.99	18.46	10.29	0.99	81867.18
23	12.25	10.43	53.95	2.78	19.97	9.60	0.99	86436.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.98	8.57	54.70	2.57	17.72	10.70	0.99	82289.35
最 大 值	12.25	10.43	62.12	3.59	19.97	11.18	1.02	87965.88
發生時間	23	23	15	8	23	14		6
最 小 值	0.10	6.94	48.35	1.14	15.94	9.60	0.97	77652.10
發生時間	6	7	21	0	15	23		16
零點偏移(率)	-0.11 %	0.00 %	-0.03 %	0.00 %		-0.08		-0.10 %
全幅偏移(率)	0.14 %	1.13 %	0.45 %	0.00 %		-0.18		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月03日

報表日期: 114年08月03日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.96	7.17	63.79	1.99	17.35	10.44	1.47	71129.93
1	2.16	3.89	49.76	1.66	19.76	9.22	1.48	78445.45
2	10.06	6.81	56.60	3.42	17.45	9.26	1.48	79063.70
3	5.30	4.30	57.29	3.19	18.49	9.09	1.48	78019.52
4	2.68	5.28	52.75	2.22	18.96	8.91	1.48	77598.41
5	0.65	11.22	62.14	1.89	16.96	10.17	1.48	69675.78
6	0.64	9.59	56.64	2.00	16.40	9.96	1.48	70667.97
7	2.16	14.20	59.53	1.85	15.98	9.92	1.47	74547.45
8	9.34	7.94	56.96	2.24	16.20	9.47	1.45	78478.39
9	2.92	7.27	59.44	2.28	18.72	9.14	1.49	79089.32
10	3.12	7.38	55.51	2.30	17.66	9.31	1.51	79506.55
11	3.58	7.17	59.95	2.36	17.34	9.55	1.50	78876.32
12	7.48	7.27	61.63	2.99	18.15	9.47	1.49	79516.20
13	6.02	8.77	60.08	3.17	17.44	9.45	1.46	80499.61
14	4.36	6.96	58.69	2.46	17.70	9.62	1.49	78021.52
15	5.90	9.37	59.77	2.58	17.68	9.25	1.48	77419.81
16	8.00	7.84	59.71	2.50	17.55	9.46	1.48	78871.79
17	5.49	8.55	56.57	2.28	16.67	9.96	1.44	79781.18
18	4.70	7.62	53.61	2.01	16.51	9.56	1.48	79541.81
19	6.48	9.14	58.18	2.03	16.99	9.35	1.48	79006.42
20	6.84	8.48	53.12	2.93	17.51	9.05	1.48	79437.66
21	5.65	10.06	50.16	3.04	18.83	8.63	1.48	81703.82
22	5.41	9.42	51.42	3.04	17.72	8.70	1.47	80137.75
23	9.66	9.15	62.11	2.48	19.43	8.66	1.44	79873.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.11	8.12	57.31	2.45	17.64	9.40	1.48	77871.25
最 大 值	10.06	14.20	63.79	3.42	19.76	10.44	1.52	81703.82
發生時間	2	7	0	2	1	0		21
最 小 值	0.64	3.89	49.76	1.66	15.98	8.63	1.43	69675.78
發生時間	6	1	1	1	7	21		5
零點偏移(率)	-0.05 %	0.00 %	-0.19 %	-0.01 %		-0.17		-0.10 %
全幅偏移(率)	0.02 %	-0.37 %	0.21 %	0.34 %		0.12		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								