

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.20	4.77	52.91	3.87	13.15	12.60	1.38	68953.97
1	2.19	2.50	64.62	3.28	14.42	12.76	1.39	66767.73
2	1.72	2.34	58.82	2.95	14.98	12.70	1.40	66959.51
3	5.89	3.85	66.82	4.02	13.30	13.00	1.40	66064.24
4	5.35	3.09	64.27	3.86	13.57	13.08	1.43	65757.98
5	5.11	10.32	59.32	4.41	12.31	12.89	1.43	68884.62
6	10.20	4.62	68.75	3.90	13.36	12.48	1.46	69457.06
7	7.54	7.96	52.96	4.86	11.76	13.04	1.45	67735.36
8	5.40	5.68	71.08	4.51	12.71	13.28	1.46	64431.07
9	5.64	3.10	47.49	4.37	12.45	13.00	1.42	66089.07
10	4.74	2.06	49.58	3.20	14.45	12.40	1.39	69499.89
11	4.59	12.48	55.34	4.30	12.24	12.93	1.41	66443.12
12	8.49	6.77	63.28	3.94	13.21	12.64	1.42	67833.08
13	13.77	8.32	66.68	4.38	12.78	12.66	1.45	68641.16
14	8.80	6.71	55.78	4.66	12.05	12.93	1.46	67123.96
15	10.49	7.47	54.90	4.89	11.92	12.95	1.43	66628.80
16	1.32	2.46	71.63	3.71	13.26	12.69	1.42	68103.88
17	1.70	1.56	64.08	2.81	14.71	12.07	1.45	72183.39
18	3.30	1.83	63.22	3.45	13.61	12.41	1.45	69949.92
19	2.67	2.66	51.51	3.48	13.50	12.35	1.43	70538.01
20	3.69	4.89	63.66	4.02	12.79	12.69	1.43	68272.59
21	1.11	4.13	64.15	3.59	13.81	13.19	1.49	63831.54
22	5.02	2.81	61.45	3.05	14.48	12.24	1.45	70667.45
23	4.00	2.76	56.83	3.45	13.73	12.59	1.43	68352.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.25	4.80	60.38	3.87	13.27	12.73	1.43	67882.09
最大值	13.77	12.48	71.63	4.89	14.98	13.28	1.51	72183.39
發生時間	13	11	16	15	2	8		17
最小值	1.11	1.56	47.49	2.81	11.76	12.07	1.38	63831.54
發生時間	21	17	9	17	7	17		21
零點偏移(率)	0.00 %	-0.00 %	-0.01 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	2.37 %	-0.22 %	-0.12 %	0.10 %		0.24	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.69	6.85	50.50	1.11	18.64	9.72	1.38	64420.72
1	2.88	3.35	47.53	0.97	19.29	9.57	1.38	65664.86
2	4.28	0.74	59.67	0.90	19.75	9.59	1.38	63635.23
3	9.34	6.20	55.11	1.06	19.96	9.35	1.39	65339.20
4	7.52	8.18	44.18	1.03	20.03	8.81	1.40	68315.98
5	6.88	9.70	38.98	1.30	18.78	9.40	1.41	65611.84
6	5.67	1.64	60.81	1.14	19.08	10.00	1.45	65392.98
7	9.57	2.13	53.29	1.59	17.66	9.99	1.46	67596.05
8	8.71	7.69	52.88	1.78	17.00	10.22	1.44	63836.10
9	7.82	2.09	55.91	1.75	17.31	10.11	1.38	64363.55
10	10.82	2.39	57.36	1.90	16.86	10.50	1.39	61113.39
11	6.97	14.18	47.18	1.64	17.06	10.81	1.42	70290.38
12	10.89	11.93	56.22	1.94	15.69	11.21	1.43	75256.81
13	24.68	20.74	67.00	3.96	15.15	11.47	1.43	76677.68
14	7.85	14.20	57.54	3.17	15.52	11.09	1.43	82716.73
15	9.49	13.53	51.44	1.45	17.83	10.75	1.41	86061.40
16	9.78	12.22	44.17	1.62	17.60	10.15	1.38	90678.84
17	9.26	12.91	49.42	1.84	16.72	10.39	1.42	77735.96
18	9.58	10.92	52.45	2.02	16.57	10.52	1.45	69649.42
19	8.86	2.49	66.70	1.82	17.20	10.83	1.45	61483.70
20	8.99	1.90	61.08	1.64	17.54	10.52	1.45	64539.11
21	9.74	2.07	58.12	1.61	17.73	10.35	1.44	65292.83
22	7.57	4.26	65.85	1.79	16.37	10.62	1.44	63683.94
23	5.36	0.77	57.05	1.59	16.74	10.34	1.45	61223.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.55	7.21	54.60	1.69	17.59	10.26	1.42	69190.86
最大值	24.68	20.74	67.00	3.96	20.03	11.47	1.46	90678.84
發生時間	13	13	13	13	4	13		16
最小值	2.69	0.74	38.98	0.90	15.15	8.81	1.38	61113.39
發生時間	0	2	5	2	13	4		10
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	0.00 %		-0.07	0.00	0.00 %
全幅偏移(率)	0.43 %	-0.33 %	-0.05 %	-0.02 %		0.03	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.59	3.54	70.89	1.70	14.93	11.53	1.85	81066.03
1	2.85	3.87	66.06	2.07	14.84	11.85	1.85	79263.34
2	11.58	2.25	53.84	2.14	15.11	11.68	1.87	82699.73
3	5.97	5.41	59.41	2.37	14.14	12.52	1.87	75620.16
4	7.79	4.26	56.31	2.14	14.80	12.09	1.86	78405.29
5	7.18	2.97	53.70	2.29	14.28	11.89	1.86	81064.88
6	8.38	4.30	50.81	2.65	13.60	11.87	1.86	82276.29
7	9.44	7.69	65.75	2.40	14.12	12.36	1.82	75869.81
8	2.58	1.23	50.49	1.74	15.45	11.75	1.81	81230.56
9	7.04	1.25	50.24	1.58	15.39	11.59	1.81	83878.55
10	8.83	4.33	55.94	2.13	13.97	11.60	1.81	83329.53
11	6.79	1.22	68.58	1.76	14.71	11.34	1.80	82772.11
12	10.98	5.75	64.46	2.34	13.55	11.76	1.82	78547.79
13	4.01	1.87	67.03	2.18	13.91	11.61	1.81	77744.99
14	9.25	1.97	67.94	2.31	13.73	11.88	1.81	76794.92
15	13.72	2.70	69.46	2.89	13.30	11.96	1.80	80881.66
16	3.66	1.54	66.07	2.21	13.71	11.90	1.80	80540.30
17	11.61	0.99	70.28	2.04	14.97	11.87	1.80	83925.46
18	8.61	1.51	64.97	1.97	14.52	11.82	1.81	85041.76
19	12.98	2.20	62.40	1.61	16.01	11.24	1.82	87261.96
20	9.79	5.42	49.50	1.86	15.69	10.70	1.81	83989.69
21	6.75	1.57	56.43	1.19	16.49	10.73	1.81	84429.71
22	8.10	3.86	57.99	1.55	14.93	10.95	1.81	82372.80
23	7.73	4.61	59.60	1.66	15.30	10.89	1.82	82521.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.84	3.18	60.76	2.03	14.64	11.64	1.82	81313.72
最大值	13.72	7.69	70.89	2.89	16.49	12.52	1.88	87261.96
發生時間	15	7	0	15	21	3		19
最小值	2.58	0.99	49.50	1.19	13.30	10.70	1.78	75620.16
發生時間	8	17	20	21	15	20		3
零點偏移(率)	-0.02 %	0.00 %	0.00 %	-0.01 %		-0.04	0.00	0.00 %
全幅偏移(率)	3.96 %	0.05 %	-0.43 %	0.28 %		0.06	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								