

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月11日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.85	11.57	64.47	2.27	17.32	10.26	1.27	75957.18
1	9.30	12.04	62.89	2.45	18.89	10.50	1.27	77363.81
2	8.97	12.40	69.96	2.51	20.13	10.07	1.27	77029.43
3	10.93	12.31	58.09	2.54	18.43	10.39	1.28	81874.62
4	10.10	11.74	57.58	2.51	18.28	10.36	1.31	79388.82
5	10.22	11.66	57.74	2.50	18.49	10.23	1.31	79630.57
6	8.21	11.93	60.16	2.45	18.12	10.54	1.31	79754.46
7	11.72	11.95	54.31	3.73	18.69	10.44	1.31	77473.21
8	9.27	11.69	47.58	3.37	19.55	9.85	1.31	75270.68
9	8.46	11.96	56.12	3.52	19.13	10.38	1.28	67901.39
10	11.22	11.45	38.17	3.29	21.03	9.07	1.27	73724.27
11	8.74	11.52	38.99	3.21	19.55	9.38	1.25	74710.03
12	8.72	11.10	43.68	3.20	18.73	9.65	1.27	72755.69
13	9.71	11.33	44.58	3.28	18.86	9.65	1.27	73931.10
14	9.79	11.00	45.62	3.32	19.64	9.47	1.27	73913.57
15	10.35	11.36	42.26	3.33	18.65	9.52	1.27	75204.69
16	9.76	11.23	52.52	3.23	19.33	9.73	1.26	74370.89
17	9.75	11.29	52.49	3.13	18.18	9.83	1.26	74311.24
18	10.22	11.14	52.85	3.07	17.49	9.77	1.26	74359.43
19	9.02	11.82	56.17	3.32	19.30	9.99	1.27	72266.81
20	11.37	12.44	57.57	3.58	19.88	9.89	1.28	73744.18
21	15.58	12.80	50.66	3.94	17.72	9.79	1.27	75128.22
22	11.51	12.94	51.71	3.02	17.61	9.94	1.27	73398.43
23	9.97	12.32	55.65	2.59	18.13	9.81	1.30	74463.85
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.03	11.79	52.99	3.06	18.80	9.94	1.28	75330.27
最 大 值	15.58	12.94	69.96	3.94	21.03	10.54	1.32	81874.62
發生時間	21	22	2	21	10	6		3
最 小 值	7.85	11.00	38.17	2.27	17.32	9.07	1.25	67901.39
發生時間	0	14	10	0	0	10		9
零點偏移(率)	-0.25 %	-0.00 %	-0.46 %	-0.01 %		0.02	-0.01	-0.10 %
全幅偏移(率)	-4.88 %	-0.39 %	0.04 %	-0.28 %		0.34	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								