

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月27日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月27日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.32	8.47	59.87	1.43	19.32	10.85	1.02	81145.07
1	7.30	8.21	64.24	2.19	18.95	10.74	1.02	82283.31
2	11.24	8.09	63.30	2.49	19.08	10.47	1.02	84607.46
3	7.34	7.97	59.39	2.55	18.47	10.57	1.02	84504.22
4	7.64	7.89	51.85	2.30	18.75	10.16	1.02	83103.66
5	5.81	7.86	57.33	1.95	18.98	10.36	1.02	84289.30
6	4.38	8.96	54.45	2.74	18.49	10.49	1.01	82199.15
7	5.51	7.05	62.77	2.59	18.18	11.01	1.00	81194.43
8	5.97	6.53	60.36	2.39	19.43	10.32	1.02	85416.35
9	4.79	6.98	64.06	2.82	18.52	10.65	1.02	82786.84
10	8.71	6.83	62.34	2.47	18.28	10.75	1.01	81395.14
11	8.88	7.28	54.43	1.84	19.14	10.51	1.01	84440.43
12	8.12	8.88	55.99	2.41	18.62	10.41	1.00	85017.69
13	7.34	4.73	55.66	3.33	16.50	10.90	0.99	82402.29
14	9.70	5.37	40.43	2.99	17.57	10.37	0.99	81523.53
15	8.81	5.93	55.04	2.95	17.60	10.53	1.00	82085.73
16	8.29	7.46	57.11	2.61	17.89	10.65	1.01	83782.87
17	9.28	8.19	54.70	2.30	18.36	10.36	1.00	83901.69
18	9.14	8.31	55.27	1.78	19.46	10.11	0.99	87260.38
19	9.24	9.15	55.86	2.06	18.92	10.30	1.00	85980.41
20	7.46	8.62	59.09	2.22	18.37	10.41	1.02	84903.55
21	9.65	7.75	60.18	1.78	19.09	10.31	1.01	85305.35
22	9.31	7.84	58.76	2.00	18.69	10.48	0.99	84802.70
23	9.66	8.47	59.13	2.07	18.41	10.05	0.98	85699.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.83	7.62	57.57	2.34	18.54	10.49	1.01	83751.28
最 大 值	11.24	9.15	64.24	3.33	19.46	11.01	1.03	87260.38
發生時間	2	19	1	13	18	7		18
最 小 值	4.32	4.73	40.43	1.43	16.50	10.05	0.97	81145.07
發生時間	0	13	14	0	13	23		0
零點偏移(率)	-0.06 %	-0.01 %	-0.01 %	0.00 %		-0.10		-0.10 %
全幅偏移(率)	0.14 %	0.38 %	0.26 %	0.23 %		-0.14		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

