

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月13日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.93	10.67	58.20	0.96	18.62	11.05	1.03	79453.00
1	4.79	12.26	54.35	1.27	17.59	12.12	1.02	71554.90
2	7.17	9.26	59.89	1.62	17.73	11.45	1.03	78270.00
3	7.26	10.98	49.37	1.51	17.08	11.47	1.02	77156.18
4	9.95	9.94	53.09	1.59	18.01	11.16	1.02	77693.13
5	8.52	12.45	59.20	1.71	17.44	11.68	1.00	84268.47
6	9.59	7.00	58.39	1.38	18.36	10.86	1.02	81841.63
7	8.39	10.71	59.15	1.99	16.44	11.98	1.02	74033.75
8	9.85	8.47	57.90	0.67	20.18	10.79	1.01	81170.58
9	5.72	11.46	59.91	1.03	18.25	12.13	1.04	71293.52
10	6.99	8.45	26.98	1.03	18.41	11.09	1.03	76822.65
11	7.61	11.95	61.62	1.32	18.64	11.33	1.00	75706.31
12	7.84	11.89	47.88	1.16	18.04	11.20	1.03	76374.49
13	5.65	12.72	68.82	0.74	18.63	11.71	1.03	71995.54
14	8.24	11.66	46.94	1.14	17.86	11.31	1.03	75175.68
15	9.30	10.26	54.39	1.16	19.06	11.04	1.02	77283.77
16	9.14	11.45	56.39	1.02	18.65	11.20	1.02	75864.26
17	8.91	14.05	48.46	1.59	16.86	11.43	1.03	74902.96
18	7.59	6.64	59.84	1.71	18.57	11.45	1.02	73540.30
19	9.79	11.12	54.99	1.24	18.13	11.43	1.02	76454.29
20	7.27	13.77	61.75	1.24	18.01	11.79	1.01	72134.28
21	8.77	10.67	50.56	1.32	17.52	10.89	1.02	77927.82
22	7.32	11.29	55.14	1.20	17.06	11.30	1.04	75453.31
23	7.09	10.80	52.00	1.36	16.43	11.51	1.13	73041.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.95	10.83	54.80	1.29	17.98	11.39	1.03	76225.50
最大值	9.95	14.05	68.82	1.99	20.18	12.13	1.22	84268.47
發生時間	4	17	13	7	8	9		5
最小值	4.79	6.64	26.98	0.67	16.43	10.79	0.99	71293.52
發生時間	1	18	10	8	23	8		9
零點偏移(率)	-0.05 %	-0.02 %	-0.02 %	-0.00 %		-0.01		0.00 %
全幅偏移(率)	0.02 %	0.19 %	-0.25 %	-0.01 %		-0.12		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月13日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.19	7.28	59.85	0.51	20.44	9.93	1.07	83641.43
1	7.04	4.61	45.77	1.71	19.60	9.88	1.07	85000.99
2	7.51	6.26	54.45	1.39	19.53	9.79	1.07	85895.56
3	5.32	8.70	51.68	2.01	17.91	9.95	1.07	85516.59
4	2.67	4.52	64.76	1.48	17.32	11.25	1.08	76927.35
5	4.11	6.84	46.84	1.64	19.17	9.61	1.09	87231.47
6	8.70	6.91	54.31	2.39	17.29	10.04	1.07	81266.95
7	7.81	7.96	59.65	2.96	16.24	10.56	1.06	82946.26
8	5.95	3.33	56.15	2.10	18.40	10.22	1.05	82997.08
9	8.49	6.59	44.98	2.22	18.79	9.57	1.05	87526.99
10	7.81	3.03	46.04	3.06	17.87	10.00	1.05	85486.09
11	9.42	10.51	53.79	2.86	17.63	10.09	1.07	85138.79
12	9.51	5.46	52.43	4.04	17.48	10.11	1.06	84953.73
13	9.02	7.69	51.26	2.56	17.28	10.20	1.06	84355.85
14	7.33	7.82	54.94	2.34	17.33	10.34	1.05	83332.73
15	5.86	4.31	56.73	1.20	19.55	9.79	1.05	85393.00
16	10.02	8.73	49.51	1.97	17.85	9.97	1.05	84168.89
17	10.27	5.92	58.06	1.64	18.79	9.84	1.06	84621.88
18	6.19	7.41	46.07	2.84	18.34	10.09	1.07	83843.06
19	7.97	5.08	55.72	1.98	18.68	9.77	1.07	85693.51
20	9.70	3.86	65.87	1.78	17.92	9.99	1.06	84290.53
21	9.28	9.04	44.45	1.97	17.32	10.24	1.05	82928.55
22	9.40	6.93	55.95	1.40	18.39	10.02	1.06	84862.19
23	8.38	6.62	57.44	1.53	16.75	10.45	1.07	80784.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.66	6.48	53.61	2.07	18.16	10.07	1.06	84116.85
最大值	10.27	10.51	65.87	4.04	20.44	11.25	1.09	87526.99
發生時間	17	11	20	12	0	4		9
最小值	2.67	3.03	44.45	0.51	16.24	9.57	1.05	76927.35
發生時間	4	10	21	0	7	9		4
零點偏移(率)	-0.11 %	-0.17 %	-0.08 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-4.76 %	-2.04 %	-2.34 %		-0.32		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月13日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.06	5.41	61.55	0.88	16.72	10.43	1.02	78654.52
1	5.93	6.16	42.44	0.94	17.23	10.90	1.01	77851.63
2	4.59	4.15	61.22	0.75	17.57	11.12	1.02	79553.05
3	8.80	9.73	50.36	1.29	15.33	10.98	1.02	81336.70
4	8.38	8.98	55.05	0.99	16.98	10.67	1.02	82676.32
5	7.15	6.65	55.68	1.28	16.30	10.70	1.04	81985.76
6	8.67	6.77	58.09	1.35	16.45	10.74	1.04	82684.74
7	10.57	10.76	42.91	1.29	18.27	9.93	1.01	79684.37
8	9.19	5.95	50.55	1.49	17.65	10.28	1.01	81342.22
9	5.59	6.19	46.65	0.94	17.77	10.23	1.02	82800.60
10	8.19	6.10	53.39	1.05	18.24	10.09	1.04	85856.79
11	8.32	7.56	44.15	1.38	16.23	10.28	0.99	81640.26
12	8.14	5.82	56.33	1.96	15.21	10.97	0.99	76897.21
13	9.11	6.13	56.36	1.54	16.53	10.60	1.01	79839.27
14	8.50	6.72	54.62	1.95	14.86	10.92	1.02	75998.14
15	9.02	6.54	56.55	1.26	17.90	10.13	1.02	80991.39
16	9.61	6.84	53.30	1.58	16.48	10.34	0.99	79284.15
17	9.79	10.11	47.44	2.06	16.05	10.38	0.97	77614.52
18	11.05	6.26	56.58	1.96	17.83	10.08	1.00	79612.49
19	8.92	9.67	47.13	1.69	15.82	10.21	1.02	78508.39
20	8.23	10.16	45.94	1.10	16.75	10.16	0.99	75615.39
21	7.20	5.43	58.15	1.31	16.85	9.78	1.09	76743.91
22	2.17	11.23	49.55	0.78	17.30	9.71	1.08	70340.60
23	5.89	3.48	38.93	1.36	18.47	8.88	1.03	76526.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.88	7.20	51.79	1.34	16.87	10.35	1.02	79334.96
最大值	11.05	11.23	61.55	2.06	18.47	11.12	1.16	85856.79
發生時間	18	22	0	17	23	2		10
最小值	2.17	3.48	38.93	0.75	14.86	8.88	0.97	70340.60
發生時間	22	23	23	2	14	23		22
零點偏移(率)	0.00 %	0.00 %	-0.09 %	0.00 %		-0.01		0.00 %
全幅偏移(率)	0.04 %	-3.02 %	-1.43 %	-0.79 %		0.15		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								