

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月04日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月04日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.45	12.09	53.43	2.37	20.06	9.32	1.19	76462.29
1	10.88	11.43	53.33	2.33	19.88	9.71	1.18	75890.31
2	8.49	11.34	59.98	2.49	19.11	9.82	1.18	73816.40
3	8.47	12.16	50.64	2.44	18.78	10.51	1.18	69811.20
4	9.31	11.99	53.51	2.43	19.73	10.09	1.19	73954.86
5	9.42	11.13	54.43	2.82	20.11	9.65	1.20	77418.56
6	8.79	11.56	61.87	2.56	19.30	10.21	1.19	72677.99
7	9.15	11.86	48.32	2.59	19.37	9.42	1.22	67859.70
8	14.20	11.40	57.90	3.08	19.54	9.83	1.24	77418.72
9	6.66	11.60	57.56	2.65	18.73	10.25	1.25	77354.51
10	10.31	11.63	63.21	2.62	19.48	10.16	1.25	77813.41
11	9.26	11.32	57.71	2.69	18.83	9.87	1.24	76883.54
12	11.69	11.77	61.33	2.90	17.72	10.03	1.23	77940.75
13	10.67	11.84	58.46	3.47	17.65	10.52	1.24	78009.97
14	9.07	11.62	50.88	2.68	17.87	10.36	1.24	76448.23
15	9.57	12.14	58.70	2.62	17.86	10.76	1.23	72738.31
16	9.87	11.33	50.97	2.57	18.21	9.93	1.22	75802.32
17	14.57	11.61	65.42	2.80	18.23	10.31	1.24	77100.59
18	7.85	11.66	61.63	2.45	18.83	10.24	1.27	78431.20
19	10.37	11.44	64.01	2.65	19.06	10.02	1.24	78666.19
20	15.29	12.43	61.80	3.61	18.65	10.04	1.24	79588.51
21	8.08	12.66	58.91	2.82	18.83	10.06	1.23	76510.57
22	12.19	12.78	57.66	2.83	18.28	9.89	1.23	75725.09
23	7.34	12.48	57.37	2.53	18.32	9.95	1.25	75378.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.04	11.80	57.46	2.71	18.85	10.04	1.22	75820.92
最 大 值	15.29	12.78	65.42	3.61	20.11	10.76	1.27	79588.51
發生時間	20	22	17	20	5	15		20
最 小 值	6.66	11.13	48.32	2.33	17.65	9.32	1.18	67859.70
發生時間	9	5	7	1	13	0		7
零點偏移(率)	-0.03 %	0.00 %	-0.04 %	-0.01 %		-0.02	-0.01	-0.10 %
全幅偏移(率)	0.95 %	0.61 %	0.62 %	0.26 %		0.18	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								