

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.43	13.97	47.05	1.59	18.35	10.99	1.33	82510.83
1	11.87	12.28	51.17	2.14	18.36	11.37	1.32	80416.63
2	7.54	11.57	48.74	3.05	18.18	11.03	1.31	82601.86
3	9.81	11.54	52.65	3.31	16.77	11.23	1.29	82037.08
4	11.58	11.74	52.33	1.89	16.14	11.46	1.27	81157.33
5	8.55	11.52	54.70	2.33	16.87	11.24	1.33	82221.15
6	11.31	11.55	54.15	2.52	16.19	11.33	1.34	82171.48
7	8.47	11.68	52.09	2.22	16.12	11.47	1.34	81497.22
8	10.07	12.39	52.90	2.02	15.36	11.54	1.34	79573.07
9	10.89	12.98	57.09	2.21	15.35	11.41	1.33	80580.34
10	8.92	12.90	53.24	1.87	16.54	11.23	1.34	81912.69
11	11.27	12.99	52.38	2.13	16.36	11.32	1.34	81472.76
12	9.99	13.05	54.81	2.47	16.89	10.91	1.33	84192.52
13	12.12	13.93	55.64	2.45	14.92	11.94	1.30	74442.65
14	6.84	13.92	53.54	2.37	16.45	11.93	1.29	73192.73
15	9.41	13.53	52.91	2.18	17.14	11.64	1.29	74542.13
16	14.02	12.61	42.17	3.40	18.17	10.73	1.31	82680.43
17	8.79	13.06	41.73	2.43	17.63	11.01	1.34	80865.30
18	13.10	13.09	43.17	3.33	16.97	10.99	1.31	81507.75
19	3.57	12.77	43.68	3.04	15.92	11.31	1.32	79024.28
20	12.74	13.05	51.05	2.63	17.09	11.39	1.34	78372.42
21	9.14	12.80	47.87	2.46	16.72	11.28	1.34	79465.07
22	9.48	12.64	46.44	2.65	17.42	11.05	1.34	80380.14
23	11.75	12.96	54.57	2.05	17.68	11.20	1.34	80393.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.99	12.69	50.67	2.45	16.82	11.29	1.32	80300.47
最大值	14.02	13.97	57.09	3.40	18.36	11.94	1.36	84192.52
發生時間	16	0	9	16	1	13		12
最小值	3.57	11.52	41.73	1.59	14.92	10.73	1.27	73192.73
發生時間	19	5	17	0	13	16		14
零點偏移(率)	-0.01 %	-0.01 %	-0.06 %	-0.00 %		-0.07	-0.01	0.40 %
全幅偏移(率)	-0.60 %	-1.97 %	0.90 %	-0.36 %		0.16	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.23	13.11	40.97	1.02	19.72	10.00	1.06	79126.14
1	11.22	11.79	57.81	1.57	19.05	10.14	1.06	79389.58
2	6.80	11.61	58.56	2.10	17.10	10.22	1.06	77701.55
3	9.71	11.36	50.78	2.11	17.95	9.93	1.05	77688.77
4	10.39	11.63	55.29	2.31	17.25	9.96	1.03	78154.26
5	8.20	11.54	58.27	2.26	16.93	10.31	1.02	79307.98
6	14.84	11.77	54.23	1.64	17.95	10.36	1.04	84475.17
7	8.20	11.85	51.04	1.89	17.76	10.42	1.05	80606.60
8	9.37	11.17	47.82	2.79	16.59	10.62	1.07	80392.34
9	10.57	11.34	48.20	1.79	17.04	10.39	1.06	79741.69
10	8.74	11.57	47.91	2.07	17.35	10.26	1.05	81637.69
11	9.34	11.86	46.62	2.03	16.77	10.51	1.06	79786.22
12	10.45	11.76	46.12	2.51	16.41	10.41	1.06	80006.58
13	9.03	12.27	47.94	1.80	17.96	10.26	1.06	80987.94
14	7.92	11.72	46.66	1.85	17.09	10.36	1.06	80076.12
15	10.51	11.55	47.77	1.79	17.39	10.17	1.06	79546.17
16	9.87	12.26	58.11	1.15	18.43	9.89	1.06	82631.85
17	15.41	12.17	53.50	1.91	18.11	10.02	1.06	82206.63
18	7.66	11.79	39.11	1.51	17.60	10.17	1.04	79745.21
19	9.85	12.93	36.76	2.07	16.36	10.25	1.03	79478.47
20	10.00	11.47	51.31	1.36	17.85	10.12	1.05	79740.24
21	7.25	11.77	43.38	2.01	16.72	10.63	1.06	77419.71
22	12.62	11.87	49.14	1.53	17.37	10.65	1.06	77268.94
23	8.00	11.67	37.97	1.59	17.41	10.33	1.06	78893.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.76	11.83	48.97	1.86	17.51	10.27	1.05	79833.73
最大值	15.41	13.11	58.56	2.79	19.72	10.65	1.09	84475.17
發生時間	17	0	2	8	0	22		6
最小值	6.80	11.17	36.76	1.02	16.36	9.89	1.02	77268.94
發生時間	2	8	19	0	19	16		22
零點偏移(率)	-0.09 %	0.00 %	-0.03 %	-0.00 %		-0.05	-0.01	-0.10 %
全幅偏移(率)	0.47 %	-0.53 %	0.12 %	-0.26 %		0.04	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.72	11.86	56.33	0.62	17.77	9.78	1.36	69645.38
1	6.55	11.44	48.09	0.87	17.60	9.73	1.36	72685.85
2	7.48	11.90	41.68	0.85	16.13	9.69	1.37	69926.82
3	9.79	12.55	60.76	0.96	16.84	10.32	1.40	70913.23
4	5.75	12.72	58.55	1.07	15.32	10.58	1.38	72472.07
5	7.80	12.72	60.13	1.13	14.77	10.62	1.40	70202.40
6	8.46	12.88	55.55	1.13	14.94	10.44	1.39	70814.10
7	12.19	12.03	52.75	2.61	15.06	10.22	1.43	76351.25
8	8.24	12.21	55.15	2.44	15.50	10.22	1.43	74289.01
9	8.24	12.07	52.88	3.30	14.82	10.16	1.40	74265.92
10	8.07	11.79	52.46	2.03	15.67	9.87	1.40	75744.76
11	10.23	11.24	55.15	2.41	15.70	9.75	1.37	74378.14
12	9.64	11.43	57.86	2.56	15.04	9.94	1.40	73497.16
13	9.15	11.40	60.24	2.36	15.54	10.29	1.37	70984.89
14	8.56	13.07	57.24	2.81	15.82	10.21	1.36	72110.50
15	7.26	13.77	57.83	3.10	15.73	10.25	1.36	72392.70
16	6.26	13.47	58.28	2.98	15.91	10.13	1.37	73056.97
17	5.91	13.73	57.65	2.99	15.45	10.42	1.39	72176.53
18	8.18	13.53	54.15	3.15	16.48	10.00	1.36	74719.22
19	5.25	13.32	53.32	2.71	17.07	9.82	1.39	73645.05
20	8.22	13.32	49.86	2.77	16.64	9.79	1.38	71949.55
21	8.98	13.45	51.26	2.95	16.84	9.87	1.36	71781.03
22	8.66	13.35	48.88	2.83	16.52	9.69	1.36	73273.79
23	8.13	13.69	47.90	2.83	16.60	9.72	1.38	73476.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.03	12.62	54.33	2.23	15.99	10.06	1.38	72698.04
最大值	12.19	13.77	60.76	3.30	17.77	10.62	1.47	76351.25
發生時間	7	15	3	9	0	5		7
最小值	5.25	11.24	41.68	0.62	14.77	9.69	1.36	69645.38
發生時間	19	11	2	0	5	2		0
零點偏移(率)	-0.02 %	-0.00 %	-0.03 %	0.00 %		-0.07	-0.01	0.00 %
全幅偏移(率)	-0.64 %	-0.05 %	1.39 %	0.41 %		0.18	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								