

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.84	10.72	47.39	0.91	19.25	11.01	1.12	75888.95
1	8.87	10.34	46.69	1.01	20.48	10.92	1.12	74982.21
2	8.05	8.90	61.22	0.90	19.29	10.97	1.11	75338.78
3	8.80	9.06	53.19	1.30	18.24	11.10	1.10	75344.33
4	9.44	9.90	47.93	1.60	17.07	11.37	1.10	74402.14
5	8.73	11.04	63.12	1.46	17.61	11.41	1.06	70174.66
6	9.53	11.21	61.17	1.24	17.49	11.60	1.05	72151.80
7	7.50	7.18	51.58	1.13	17.07	11.46	1.05	73412.49
8	8.63	7.04	46.92	1.61	16.98	11.41	1.08	73432.44
9	7.46	6.97	57.98	1.32	16.97	11.74	1.08	70582.63
10	7.89	7.93	52.92	0.96	17.40	11.24	1.08	73829.66
11	9.25	11.06	45.70	1.41	16.92	11.00	1.05	73035.55
12	8.56	8.63	48.42	1.36	16.42	11.69	1.07	70284.25
13	4.23	9.76	62.94	0.95	17.04	11.65	1.10	71944.07
14	8.96	10.74	46.36	1.40	16.85	11.20	1.09	74423.32
15	7.28	9.02	46.46	1.00	17.43	11.17	1.09	74274.00
16	9.59	5.90	45.82	1.56	16.33	11.57	1.08	73333.32
17	4.44	5.51	54.10	1.41	16.52	11.88	1.08	70962.88
18	0.52	6.25	67.78	0.65	18.06	11.29	1.09	74394.01
19	4.49	6.53	54.69	1.28	17.56	11.17	1.08	75755.77
20	8.55	5.29	60.52	0.85	18.90	10.88	1.07	76584.60
21	4.38	6.16	55.79	0.85	18.80	11.40	1.07	72520.65
22	5.70	5.93	51.33	0.50	20.25	10.39	1.07	79501.52
23	9.65	6.30	45.32	0.61	20.48	10.24	1.09	80187.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.47	8.22	53.14	1.14	17.89	11.24	1.08	74030.89
最大值	9.65	11.21	67.78	1.61	20.48	11.88	1.16	80187.26
發生時間	23	6	18	8	1	17		23
最小值	0.52	5.29	45.32	0.50	16.33	10.24	1.05	70174.66
發生時間	18	20	23	22	16	23		5
零點偏移(率)	-0.01 %	0.00 %	-0.09 %	-0.02 %		0.02		0.00 %
全幅偏移(率)	-3.26 %	1.27 %	0.19 %	0.24 %		0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.59	7.15	49.21	1.69	17.68	10.32	0.99	85515.49
1	3.20	11.86	47.37	2.23	17.00	10.77	0.99	82720.42
2	5.56	6.65	49.49	1.92	17.58	10.21	0.99	85996.93
3	7.00	2.80	45.82	2.14	17.06	10.32	0.99	85816.61
4	8.60	2.94	49.38	2.11	17.19	10.47	1.01	84642.74
5	9.67	4.75	47.26	1.86	16.91	10.50	1.01	84275.69
6	8.25	8.95	49.16	2.31	15.31	10.76	1.04	90782.85
7	8.23	2.80	49.40	2.19	16.12	10.54	1.06	84578.49
8	9.10	2.54	51.82	1.64	17.23	10.31	1.06	85499.54
9	9.11	5.17	49.47	1.84	16.10	10.49	1.05	84354.47
10	9.70	3.29	51.13	1.69	16.27	10.21	1.06	86734.26
11	8.39	2.18	53.71	2.16	14.29	11.02	1.06	82162.95
12	11.09	3.20	60.35	2.34	14.45	11.84	1.05	77183.55
13	7.44	2.89	51.19	1.90	15.10	11.35	1.05	81344.60
14	6.86	2.37	53.51	1.41	17.18	10.79	1.05	82945.54
15	9.01	2.28	49.60	1.18	17.07	10.60	1.05	84432.43
16	9.87	4.18	56.83	1.85	16.28	10.42	1.06	85424.32
17	1.59	6.12	58.54	1.23	16.70	11.08	1.07	80246.06
18	1.23	2.00	61.63	1.31	16.09	11.59	1.06	76566.92
19	0.66	1.77	49.31	1.00	18.02	10.67	1.05	82067.79
20	2.14	4.90	51.73	1.90	16.82	10.66	1.05	83517.11
21	0.82	1.67	59.06	1.25	17.70	11.07	1.05	79050.27
22	1.11	4.00	57.08	1.21	18.07	10.55	1.04	83186.07
23	2.66	11.47	52.53	1.95	17.10	10.65	1.02	82706.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.24	4.50	52.27	1.76	16.64	10.72	1.04	83406.30
最大值	11.09	11.86	61.63	2.34	18.07	11.84	1.10	90782.85
發生時間	12	1	18	12	22	12		6
最小值	0.66	1.67	45.82	1.00	14.29	10.21	0.98	76566.92
發生時間	19	21	3	19	11	2		18
零點偏移(率)	-0.04 %	-0.03 %	-0.02 %	0.00 %		0.04		-0.20 %
全幅偏移(率)	0.02 %	0.32 %	-0.10 %	0.19 %		-0.25		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.21	2.40	45.32	1.42	15.62	10.85	0.94	75692.44
1	8.30	7.94	43.81	1.26	16.95	10.47	0.94	79162.35
2	5.02	4.17	50.18	1.22	15.58	11.12	0.94	77086.43
3	8.78	8.21	49.30	1.70	15.96	10.14	0.92	83427.51
4	4.27	8.02	41.25	1.61	14.35	11.02	0.93	74458.56
5	9.41	3.50	62.16	1.64	15.96	10.88	0.94	79764.26
6	8.92	12.81	46.67	1.81	15.51	10.52	0.92	76404.59
7	9.01	4.18	47.71	1.43	16.24	10.02	0.94	77113.48
8	9.66	3.32	47.72	1.89	14.65	10.79	0.95	74146.79
9	5.69	5.22	39.82	1.11	15.39	10.39	0.96	77174.70
10	7.87	3.86	48.19	1.75	14.22	11.00	0.96	74456.09
11	8.41	5.14	46.75	2.62	12.37	10.96	0.94	72156.88
12	2.55	2.94	61.48	1.76	13.51	11.83	0.98	69708.61
13	6.12	2.76	64.87	1.09	15.13	11.07	0.98	75241.14
14	8.85	3.98	47.34	1.02	16.11	10.15	0.98	75981.11
15	8.58	4.61	54.48	1.27	14.95	10.65	0.98	75625.59
16	1.92	6.91	51.39	0.88	16.13	9.83	0.92	73746.04
17	8.37	4.85	64.69	2.06	14.08	10.66	0.95	76055.93
18	9.18	6.73	37.87	1.55	14.92	10.60	0.94	77398.13
19	4.20	1.98	63.84	0.95	15.60	10.93	0.95	74474.80
20	2.19	5.11	58.56	0.76	16.30	11.28	0.95	71065.02
21	0.41	5.81	34.34	0.64	17.95	10.35	0.94	79659.43
22	0.97	8.42	44.47	1.05	15.70	10.87	0.94	78415.63
23	1.96	0.83	55.08	0.78	16.74	11.21	0.95	74716.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.16	5.15	50.30	1.39	15.41	10.73	0.95	75963.84
最大值	9.66	12.81	64.87	2.62	17.95	11.83	0.99	83427.51
發生時間	8	6	13	11	21	12		3
最小值	0.41	0.83	34.34	0.64	12.37	9.83	0.90	69708.61
發生時間	21	23	21	21	11	16		12
零點偏移(率)	0.00 %	0.00 %	-0.38 %	-0.03 %		0.01		0.00 %
全幅偏移(率)	0.02 %	0.29 %	-0.34 %	0.03 %		0.05		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								