

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月11日

報表日期: 114年07月11日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.26	10.14	60.43	1.43	17.30	12.03	1.25	76941.33
1	1.68	10.43	56.16	1.73	18.07	11.75	1.26	78322.85
2	2.68	9.51	53.01	1.25	18.16	11.31	1.25	82064.31
3	2.61	9.44	60.12	0.83	18.76	10.99	1.27	84146.27
4	2.51	10.65	42.98	1.71	17.78	10.76	1.26	86799.32
5	0.12	8.56	63.59	1.43	17.41	11.54	1.27	79340.37
6	0.14	7.53	50.65	1.79	16.35	11.62	1.28	80331.89
7	2.47	9.04	57.37	2.15	15.77	11.66	1.28	81093.78
8	2.65	10.31	50.21	1.16	17.89	11.32	1.29	82263.98
9	2.66	8.97	52.76	1.06	17.66	11.40	1.29	81357.75
10	2.67	8.85	62.88	1.44	17.22	11.48	1.29	80722.55
11	2.50	9.41	59.74	1.64	16.76	11.75	1.29	79575.44
12	1.45	12.03	55.98	1.88	16.36	11.91	1.29	78562.86
13	1.46	13.81	56.54	2.03	16.29	11.93	1.30	78413.59
14	1.44	15.13	49.62	2.67	15.36	12.04	1.30	77927.68
15	1.48	12.93	55.32	2.74	15.39	12.10	1.30	77812.34
16	1.53	12.12	59.10	2.74	14.89	12.52	1.29	74001.89
17	1.49	11.29	63.35	1.54	16.18	12.22	1.29	75516.57
18	1.33	11.85	61.43	1.15	16.68	11.92	1.29	76917.25
19	1.31	10.16	51.34	1.11	18.23	10.80	1.30	85860.21
20	1.41	7.84	52.59	1.21	18.29	10.79	1.29	86336.14
21	2.16	9.53	54.47	1.67	17.23	11.10	1.29	84299.59
22	4.16	9.57	52.35	2.03	15.47	11.77	1.29	79977.74
23	4.13	8.99	57.22	1.58	16.46	11.78	1.29	78764.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	1.97	10.34	55.80	1.67	16.92	11.60	1.28	80306.27
最 大 值	4.16	15.13	63.59	2.74	18.76	12.52	1.31	86799.32
發生時間	22	14	5	15	3	16		4
最 小 值	0.12	7.53	42.98	0.83	14.89	10.76	1.25	74001.89
發生時間	5	6	4	3	16	4		16
零點偏移(率)	-0.01 %	0.01 %	-0.10 %	-0.05 %		-0.02		0.10 %
全幅偏移(率)	0.00 %	1.08 %	0.75 %	0.64 %		-0.13		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 114年07月11日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.92	8.53	50.03	1.38	19.13	10.82	1.00	80784.42
1	4.27	8.68	54.19	2.37	19.07	10.93	0.99	80184.37
2	7.06	9.95	58.25	3.15	18.33	10.88	0.99	82205.26
3	5.83	8.94	59.61	2.40	18.28	11.07	1.01	80207.90
4	11.96	8.76	54.62	3.83	17.30	10.53	1.01	86183.87
5	8.19	12.35	51.41	3.97	16.55	10.84	1.01	83151.56
6	11.88	9.13	57.08	3.18	16.82	11.29	0.99	81598.81
7	8.60	5.87	54.40	1.98	18.27	10.80	0.99	81427.42
8	11.50	7.93	60.59	2.09	18.30	10.77	0.99	81841.85
9	5.94	8.18	58.29	1.58	18.67	10.69	0.98	81221.03
10	6.08	8.01	49.85	1.89	17.88	10.75	0.97	79066.26
11	9.94	8.14	49.93	1.99	18.10	10.65	0.99	79926.02
12	9.11	10.12	46.53	3.33	16.46	11.16	0.99	79330.80
13	10.49	7.08	53.67	2.22	17.85	11.00	0.99	81211.67
14	13.14	12.17	56.02	3.42	16.35	11.57	0.99	78936.97
15	10.33	8.04	59.02	2.55	17.88	11.11	0.98	80873.53
16	7.86	7.50	51.53	1.81	18.59	10.63	0.99	83742.44
17	7.91	10.02	40.23	2.40	16.94	10.38	0.99	78197.59
18	9.72	7.57	45.95	2.93	17.85	10.64	0.97	79827.52
19	7.87	8.63	41.40	1.98	18.59	9.98	0.98	81738.24
20	7.75	7.17	36.56	2.07	18.33	10.34	1.01	80750.15
21	8.88	6.76	46.56	1.86	18.29	10.56	1.01	83603.24
22	9.75	8.81	53.80	2.10	17.86	11.02	1.00	80662.01
23	8.60	8.90	51.88	1.41	18.92	10.82	0.99	79481.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.69	8.63	51.72	2.41	17.94	10.80	0.99	81089.78
最 大 值	13.14	12.35	60.59	3.97	19.13	11.57	1.09	86183.87
發生時間	14	5	8	5	0	14		4
最 小 值	4.27	5.87	36.56	1.38	16.35	9.98	0.97	78197.59
發生時間	1	7	20	0	14	19		17
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	-0.05 %		-0.04		-0.10 %
全幅偏移(率)	0.13 %	0.30 %	0.86 %	0.51 %		-0.37		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月11日

報表日期: 114年07月11日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO ₂ _C	#3-H ₂ O	#3-O ₂ _C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.82	9.29	63.22	1.54	18.77	9.79	1.43	74750.10
1	1.61	8.75	60.22	1.34	20.70	9.61	1.43	78602.91
2	2.53	8.70	56.04	1.67	19.11	9.89	1.43	77231.60
3	3.64	9.46	49.12	1.79	19.49	9.24	1.41	84978.63
4	3.88	8.37	52.34	1.74	18.84	9.44	1.41	83468.74
5	4.91	8.65	51.91	1.90	17.83	9.80	1.41	80738.25
6	3.61	8.61	51.73	1.73	18.37	9.57	1.41	78336.54
7	3.36	10.63	58.28	1.95	18.13	9.30	1.41	80134.43
8	0.58	8.07	59.02	1.37	18.93	9.46	1.44	79586.27
9	0.80	7.59	59.71	1.45	19.23	9.43	1.45	81202.43
10	2.62	7.56	59.28	1.67	18.59	9.29	1.43	79488.00
11	0.74	9.42	57.62	1.54	17.28	9.67	1.40	75584.15
12	0.58	9.70	59.46	1.61	16.58	9.84	1.40	74022.48
13	5.71	8.75	61.35	2.03	17.21	9.46	1.39	73785.11
14	9.49	10.61	59.67	3.09	18.33	9.24	1.40	74530.54
15	8.73	8.73	59.64	3.43	17.12	9.31	1.41	74732.01
16	2.30	10.16	56.63	1.55	18.23	8.81	1.43	76196.21
17	0.78	12.04	57.25	1.60	18.82	8.74	1.43	75891.17
18	2.14	8.45	59.49	1.58	19.28	8.88	1.41	80102.16
19	2.80	8.48	44.16	1.24	20.55	7.69	1.38	76168.21
20	1.92	7.58	43.03	1.22	19.67	7.71	1.38	73995.75
21	2.41	8.14	45.81	1.71	18.70	7.97	1.37	71862.18
22	3.47	8.43	50.65	1.38	17.95	8.57	1.38	69955.41
23	3.24	7.44	61.11	1.53	18.90	9.44	1.41	77949.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.07	8.90	55.70	1.74	18.61	9.17	1.41	77220.52
最 大 值	9.49	12.04	63.22	3.43	20.70	9.89	1.48	84978.63
發生時間	14	17	0	15	1	2		3
最 小 值	0.58	7.44	43.03	1.22	16.58	7.69	1.37	69955.41
發生時間	8	23	20	20	12	19		22
零點偏移(率)	-0.05 %	-0.02 %	-0.08 %	-0.03 %		-0.05		-0.10 %
全幅偏移(率)	0.02 %	0.53 %	-0.52 %	0.26 %		0.17		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								