

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月23日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.64	9.71	56.64	1.99	13.80	12.22	1.04	80511.96
1	9.36	7.20	49.30	1.13	15.76	11.53	1.02	84737.68
2	7.94	6.12	67.03	0.79	16.00	11.32	1.04	86546.32
3	8.32	6.60	44.85	1.57	14.51	11.54	1.04	85873.39
4	5.42	7.16	60.21	0.73	16.03	11.44	1.06	85147.53
5	10.77	9.89	40.70	1.86	14.60	11.79	1.08	84055.36
6	5.78	10.43	53.97	0.68	15.55	11.99	1.09	80546.53
7	8.60	7.66	55.82	0.37	16.12	10.91	1.08	88493.98
8	9.20	12.07	48.27	1.57	14.24	11.79	1.06	82482.93
9	8.69	11.95	49.20	0.63	16.40	11.56	1.06	83517.45
10	9.10	11.44	52.63	0.84	15.79	11.55	1.07	83662.12
11	8.78	11.69	56.92	1.22	15.05	11.68	1.09	83472.46
12	9.18	7.69	43.75	2.22	14.06	11.95	1.09	81417.04
13	9.23	5.49	40.01	1.85	14.16	12.02	1.10	81320.78
14	3.94	6.24	39.32	2.69	16.46	11.11	1.10	82606.41
15	8.70	2.12	58.06	0.59	16.95	10.88	1.07	86535.54
16	10.08	3.01	26.02	1.41	15.79	11.60	1.07	83390.67
17	8.07	2.60	31.11	0.69	16.06	11.63	1.06	82740.61
18	9.98	3.34	33.71	1.14	15.00	11.90	1.06	81523.38
19	9.07	7.23	55.18	0.47	16.63	11.59	1.07	83054.98
20	9.26	7.38	41.85	0.89	15.69	11.42	1.08	85092.06
21	8.96	6.89	47.56	1.08	15.02	11.85	1.10	82207.37
22	9.36	7.13	48.98	0.74	15.02	11.65	1.09	83728.87
23	8.94	6.87	47.85	0.76	15.48	11.63	1.09	83904.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.52	7.41	47.87	1.16	15.42	11.61	1.07	83607.07
最 大 值	10.77	12.07	67.03	2.69	16.95	12.22	1.12	88493.98
發生時間	5	8	2	14	15	0		7
最 小 值	3.94	2.12	26.02	0.37	13.80	10.88	1.02	80511.96
發生時間	14	15	16	7	0	15		0
零點偏移(率)	-0.19 %	0.01 %	-0.22 %	-0.05 %		0.02		0.30 %
全幅偏移(率)	0.01 %	1.19 %	0.93 %	0.17 %		0.22		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月23日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.66	4.65	45.20	0.29	17.22	10.07	1.06	81602.53
1	3.68	7.13	37.99	0.34	18.17	9.33	1.07	85490.86
2	1.13	4.70	37.67	0.68	15.65	10.11	1.10	79539.28
3	0.14	5.47	49.28	0.66	15.76	10.46	1.10	79160.92
4	0.10	7.79	48.25	0.27	16.10	10.19	1.10	80574.68
5	0.23	8.49	47.48	0.81	14.51	10.42	1.09	78204.92
6	0.48	7.91	47.69	0.27	16.26	9.95	1.09	80798.23
7	0.09	9.59	44.16	0.93	12.95	11.03	1.11	76349.38
8	1.48	9.43	42.38	0.30	15.48	9.84	1.11	77558.96
9	3.24	8.29	45.97	0.19	15.31	10.08	1.12	75832.94
10	3.28	8.31	55.58	0.13	17.50	9.68	1.10	83703.41
11	3.62	4.03	37.44	0.28	16.11	9.57	1.09	79221.61
12	3.51	4.16	39.27	0.46	14.69	10.48	1.09	73904.12
13	3.35	3.35	41.64	0.48	14.49	10.49	1.10	76480.54
14	3.40	2.65	50.53	0.37	15.55	10.41	1.10	79685.70
15	3.59	3.05	49.86	0.37	15.98	10.35	1.10	80659.40
16	3.63	2.93	46.97	0.38	15.86	10.28	1.10	80747.25
17	3.48	2.73	48.44	0.30	15.50	10.43	1.10	79156.74
18	3.28	2.84	50.48	0.33	15.04	10.67	1.11	80507.16
19	2.90	3.17	53.19	0.45	15.18	10.52	1.10	80709.62
20	4.41	3.69	51.57	0.67	14.80	10.40	1.11	81119.47
21	2.89	2.46	46.08	0.37	14.77	10.37	1.10	77818.43
22	2.37	3.39	49.44	0.80	13.53	11.01	1.10	74797.20
23	3.37	4.41	51.77	0.67	14.74	10.29	1.10	80666.14
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.60	5.19	46.60	0.45	15.46	10.27	1.10	79345.40
最 大 值	4.66	9.59	55.58	0.93	18.17	11.03	1.14	85490.86
發生時間	0	7	10	7	1	7		1
最 小 值	0.09	2.46	37.44	0.13	12.95	9.33	1.05	73904.12
發生時間	7	21	11	10	7	1		12
零點偏移(率)	-0.04 %	-0.00 %	-0.31 %	-0.01 %		0.07		0.10 %
全幅偏移(率)	0.94 %	0.11 %	0.12 %	-0.06 %		0.09		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								