

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年03月06日

報表日期: 113年03月06日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.20	6.42	45.21	0.87	18.09	11.19	1.08	83584.93
1	8.67	6.47	41.27	1.95	17.04	11.10	1.08	80915.40
2	8.49	5.67	38.44	2.12	16.47	10.94	1.07	80179.35
3	8.54	4.18	55.31	1.26	17.31	11.31	1.08	81694.32
4	8.99	4.87	37.56	2.57	15.16	11.24	1.07	79999.07
5	9.63	5.20	46.34	3.40	15.56	11.23	1.05	78414.34
6	9.83	4.42	45.12	2.90	14.85	11.27	1.02	80159.96
7	9.02	4.58	48.51	3.31	14.35	11.48	1.03	78097.36
8	8.76	5.04	44.64	3.13	14.34	11.50	1.03	78071.77
9	7.33	5.36	50.59	3.20	14.16	11.99	1.05	73428.81
10	2.70	6.74	54.32	2.27	14.91	12.24	1.02	75348.13
11	6.85	5.82	47.73	3.15	14.03	11.60	0.98	80497.91
12	11.20	4.93	47.44	4.25	13.51	11.59	1.01	78494.52
13	7.60	1.36	43.30	3.82	12.99	11.58	1.03	77577.19
14	4.91	4.02	48.37	2.67	14.50	11.53	1.05	77153.98
15	9.61	5.92	48.18	2.83	14.73	11.46	1.04	78829.08
16	7.19	4.01	56.28	2.03	15.48	11.38	1.04	79803.50
17	5.79	4.53	52.92	1.61	16.61	11.31	1.04	79863.61
18	7.06	4.36	49.89	1.48	17.27	11.22	1.03	83077.31
19	10.41	6.84	40.75	2.18	16.38	11.12	1.02	86712.79
20	10.17	2.31	34.13	2.54	16.65	10.96	1.02	87766.69
21	9.11	3.36	35.21	2.16	16.42	11.12	1.02	85407.13
22	9.59	4.64	48.27	2.60	16.48	11.61	1.02	81744.67
23	8.67	4.91	55.90	1.15	18.12	11.17	1.02	85049.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.30	4.83	46.49	2.48	15.64	11.38	1.04	80494.65
最 大 值	11.20	6.84	56.28	4.25	18.12	12.24	1.09	87766.69
發生時間	12	19	16	12	23	10		20
最 小 值	2.70	1.36	34.13	0.87	12.99	10.94	0.97	73428.81
發生時間	10	13	20	0	13	2		9
零點偏移(率)	-0.09 %	-0.02 %	-0.04 %	0.00 %		-0.06		0.00 %
全幅偏移(率)	-1.75 %	-0.76 %	-0.99 %	0.10 %		-0.08		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月06日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.17	4.02	37.37	2.65	18.29	10.47	1.05	82339.05
1	9.67	3.26	53.36	3.22	17.01	11.27	1.05	78292.30
2	9.38	4.29	68.17	1.84	15.21	12.08	1.05	73441.39
3	8.53	3.82	53.72	2.38	14.68	11.65	1.04	77201.26
4	9.62	3.96	56.87	3.56	15.26	11.60	1.05	76519.93
5	8.73	3.32	56.32	3.24	14.68	11.69	1.03	77133.18
6	12.44	4.85	53.84	2.51	13.47	11.72	1.03	78271.44
7	10.59	4.35	51.78	2.36	15.80	11.55	1.02	77588.44
8	8.07	11.10	50.60	3.42	14.80	11.54	1.01	77228.01
9	10.12	2.77	47.10	2.81	15.96	11.36	1.00	79385.98
10	9.03	2.75	46.78	2.76	15.12	11.51	1.03	78390.57
11	8.78	2.50	46.53	2.99	15.38	11.35	1.01	80111.34
12	8.78	2.85	45.55	3.63	13.71	11.80	0.99	77226.40
13	4.34	2.55	54.03	2.56	14.56	11.86	1.01	76580.16
14	6.61	4.62	45.31	3.53	13.79	11.67	1.01	78186.76
15	9.51	4.90	48.40	3.46	13.55	11.90	1.01	76943.64
16	5.64	2.30	56.04	2.13	14.86	11.74	1.02	76998.88
17	2.02	3.03	50.65	1.90	15.62	11.73	1.02	75920.44
18	2.01	3.24	52.23	1.64	19.05	10.29	1.04	84571.46
19	5.89	3.17	43.99	2.66	17.77	10.57	1.04	83826.08
20	11.33	3.07	35.55	2.49	17.73	10.48	1.03	84781.57
21	8.14	3.03	34.59	2.64	16.14	11.16	1.02	81264.99
22	7.83	3.27	39.52	2.67	16.05	11.30	1.02	79752.80
23	5.10	2.65	54.60	1.63	17.33	11.26	1.02	78957.46
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.93	3.74	49.29	2.70	15.66	11.40	1.03	78788.06
最 大 值	12.44	11.10	68.17	3.63	19.05	12.08	1.06	84781.57
發生時間	6	8	2	12	18	2		20
最 小 值	2.01	2.30	34.59	1.63	13.47	10.29	0.99	73441.39
發生時間	18	16	21	23	6	18		2
零點偏移(率)	-0.14 %	-0.01 %	-0.03 %	-0.01 %		-0.07		-0.20 %
全幅偏移(率)	-0.07 %	1.01 %	-0.51 %	0.34 %		-0.14		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月06日

[illegible]