

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月27日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.57	13.23	42.22	1.84	17.67	10.83	1.25	86658.53
1	13.80	12.55	49.78	2.09	18.41	11.39	1.26	80850.83
2	8.75	12.12	63.09	1.86	16.62	11.60	1.27	80894.24
3	9.29	12.41	37.19	2.45	15.57	11.55	1.27	82723.27
4	11.16	13.13	42.65	4.17	16.68	11.72	1.27	80115.81
5	9.03	15.69	58.00	3.60	15.73	11.94	1.30	81039.66
6	7.71	13.44	56.73	2.97	16.56	11.86	1.30	78946.53
7	14.27	13.20	45.84	3.89	16.41	11.57	1.30	81154.30
8	10.75	13.39	53.74	3.26	17.68	11.08	1.30	84314.63
9	9.70	11.09	51.14	3.45	17.41	10.75	1.31	87206.76
10	6.90	11.21	48.64	2.99	16.56	11.12	1.30	84637.56
11	5.11	11.51	51.54	2.59	15.96	11.46	1.28	82445.04
12	3.54	11.42	47.68	2.02	16.06	11.40	1.29	82868.03
13	3.75	11.44	51.08	2.37	15.84	11.39	1.30	82763.67
14	9.26	11.67	50.48	2.21	16.08	11.52	1.29	81489.46
15	2.02	11.22	55.99	1.25	16.65	11.16	1.28	84285.32
16	2.76	11.82	42.10	2.00	15.94	11.42	1.26	83203.29
17	6.87	12.40	54.15	1.65	16.09	12.13	1.28	77249.30
18	6.31	11.93	40.30	1.29	16.85	11.25	1.29	84034.39
19	6.46	11.66	43.54	1.46	16.30	11.51	1.28	82514.48
20	7.58	11.93	46.74	1.23	17.24	11.46	1.27	81438.76
21	9.95	13.01	54.45	1.13	16.81	11.18	1.27	84811.72
22	9.40	14.16	47.57	2.30	14.23	11.72	1.28	82480.83
23	3.26	13.16	50.00	2.38	14.63	12.21	1.29	78100.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.93	12.45	49.36	2.35	16.42	11.47	1.28	82342.77
最 大 值	14.27	15.69	63.09	4.17	18.41	12.21	1.31	87206.76
發生時間	7	5	2	4	1	23		9
最 小 值	2.02	11.09	37.19	1.13	14.23	10.75	1.25	77249.30
發生時間	15	9	3	21	22	9		17
零點偏移(率)	-0.02 %	0.01 %	-0.03 %	0.00 %		-0.05	-0.01	0.40 %
全幅偏移(率)	-0.94 %	1.39 %	-0.82 %	-0.69 %		0.00	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年12月27日

報表日期: 114年12月27日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	10.88	11.63	53.05	2.21	17.39	10.30	1.32	73077.37
1	12.36	11.87	50.10	2.33	18.98	10.01	1.31	76670.16
2	11.86	11.37	45.44	2.60	17.04	10.11	1.31	77122.29
3	12.52	11.68	48.65	2.94	16.63	10.32	1.31	73796.42
4	11.48	11.91	36.64	2.93	16.30	9.97	1.31	74244.52
5	12.05	12.57	38.45	3.26	16.16	10.06	1.31	72177.07
6	9.77	13.08	36.07	3.52	15.64	10.14	1.29	69590.81
7	11.18	11.09	49.82	2.31	16.35	10.09	1.32	69566.66
8	12.29	11.48	47.88	3.35	16.22	9.99	1.33	72772.20
9	12.68	12.95	45.74	1.95	16.73	10.00	1.34	73607.74
10	11.43	11.36	46.44	1.32	15.66	10.24	1.36	70687.99
11	11.81	11.43	46.55	1.45	14.78	10.41	1.36	71974.99
12	12.06	11.51	46.76	1.41	15.90	10.24	1.36	72527.42
13	12.45	11.48	43.59	1.36	15.85	10.08	1.36	73846.08
14	11.22	12.17	43.35	1.61	15.53	10.27	1.35	70691.32
15	7.44	12.76	41.00	1.60	16.41	9.94	1.35	71453.80
16	12.17	10.84	38.06	2.57	16.84	9.43	1.35	75790.45
17	12.64	11.04	40.19	2.94	16.96	9.40	1.35	75980.51
18	11.20	10.76	43.71	3.08	15.83	9.56	1.35	73220.49
19	12.61	11.24	45.64	4.05	16.79	9.41	1.36	74274.92
20	11.76	11.92	54.17	2.55	18.25	9.56	1.36	71991.22
21	12.41	13.93	38.73	2.50	17.96	9.00	1.35	73188.37
22	11.77	10.82	44.48	0.71	18.02	9.19	1.34	73532.04
23	12.08	10.98	58.77	2.39	17.99	9.72	1.34	73103.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.67	11.74	45.14	2.37	16.68	9.89	1.34	73120.35
最 大 值	12.68	13.93	58.77	4.05	18.98	10.41	1.36	77122.29
發生時間	9	21	23	19	1	11		2
最 小 值	7.44	10.76	36.07	0.71	14.78	9.00	1.29	69566.66
發生時間	15	18	6	22	11	21		7
零點偏移(率)	-0.13 %	0.00 %	-0.03 %	0.00 %		-0.06	-0.01	0.20 %
全幅偏移(率)	-0.58 %	-1.40 %	0.42 %	-0.69 %		0.08	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								