

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.56	19.22	58.09	1.81	19.42	10.97	1.06	70081.98
1	9.21	17.10	49.41	2.40	18.72	10.75	1.04	73005.28
2	10.00	17.20	50.23	3.36	16.54	11.52	1.02	70472.87
3	7.91	14.02	54.71	2.93	16.84	11.73	1.03	66935.56
4	9.20	18.47	50.71	2.53	17.65	11.29	1.05	70138.94
5	11.06	18.27	49.98	2.75	17.86	10.90	1.06	70490.18
6	8.17	17.90	55.87	2.51	17.52	11.13	1.07	71728.36
7	11.87	18.11	54.02	2.76	18.48	10.75	1.07	73743.69
8	7.24	17.97	54.29	2.18	18.95	10.71	1.07	73450.47
9	9.05	15.53	42.43	2.93	16.34	11.27	1.07	71236.67
10	7.26	16.10	49.29	3.24	15.60	11.79	1.05	67467.53
11	4.74	14.62	57.25	2.29	17.77	11.08	1.06	71598.34
12	7.08	18.55	48.95	2.48	17.48	11.26	1.05	68688.22
13	9.07	13.66	47.67	2.76	17.21	11.28	1.04	69846.65
14	6.76	19.27	49.21	3.12	16.50	11.82	1.03	66262.89
15	8.89	13.21	46.98	2.46	18.33	10.73	1.05	73220.16
16	6.10	無效	48.45	2.74	17.46	11.29	1.06	69187.38
17	2.88	16.01	64.43	1.92	19.52	11.00	1.07	70370.21
18	6.82	16.53	51.35	1.93	19.70	10.59	1.06	73499.05
19	3.16	17.46	66.42	1.75	19.43	11.04	1.06	70178.04
20	5.04	18.54	45.89	2.15	17.71	10.94	1.05	71955.36
21	6.68	無效	66.75	2.27	18.10	11.42	1.05	68831.73
22	7.92	15.24	54.43	1.82	20.33	10.38	1.03	73746.20
23	7.08	6.57	51.77	2.13	18.90	11.05	1.02	70156.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	22	24	24	24	24	24	24
平均值	7.41	16.34	52.86	2.47	18.01	11.11	1.05	70678.83
最大值	11.87	19.27	66.75	3.36	20.33	11.82	1.07	73746.20
發生時間	7	14	21	2	22	14		22
最小值	2.88	6.57	42.43	1.75	15.60	10.38	1.02	66262.89
發生時間	17	23	9	19	10	22		14
零點偏移(率)	-0.08 %	-0.02 %	-0.02 %	-0.01 %		0.04		0.00 %
全幅偏移(率)	0.02 %	0.10 %	0.02 %	0.03 %		-0.03		0.20 %
有效比率	100.00 %	91.67%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.04	13.84	71.27	0.88	20.45	9.33	1.15	82913.62
1	5.03	14.19	53.23	1.64	18.01	10.08	1.13	83577.02
2	10.34	14.40	61.74	2.73	15.93	10.35	1.14	81085.21
3	9.18	11.59	63.65	2.67	16.29	10.49	1.12	79338.24
4	9.55	15.90	52.97	2.11	18.03	10.06	1.14	79876.58
5	10.11	18.44	62.61	2.70	16.59	10.34	1.15	79596.04
6	8.64	15.26	59.25	1.97	17.23	10.57	1.18	82262.60
7	9.52	16.07	64.04	2.02	18.09	9.90	1.18	79846.76
8	9.68	17.48	53.39	2.19	17.42	9.61	1.17	79591.74
9	8.67	12.00	57.70	2.41	16.59	9.68	1.19	77667.45
10	9.37	14.97	59.68	2.97	14.42	10.39	1.19	73519.26
11	9.99	15.26	59.90	2.41	17.05	9.86	1.19	77050.47
12	9.02	17.97	50.02	2.19	16.88	9.79	1.18	75003.04
13	2.76	13.31	52.56	1.19	19.25	9.08	1.18	76857.87
14	1.83	17.68	50.52	1.48	19.34	9.04	1.18	75730.63
15	7.62	無效	42.82	2.17	19.11	8.83	1.18	75526.91
16	7.27	12.62	45.78	1.88	17.90	9.72	1.18	77876.43
17	6.86	17.65	53.78	1.32	19.18	9.50	1.19	76277.29
18	3.17	6.37	52.04	0.77	20.73	8.86	1.18	78902.92
19	5.08	2.52	55.21	0.98	19.73	9.60	1.18	78859.02
20	6.68	5.93	45.88	1.38	18.49	9.52	1.18	77666.76
21	9.80	7.69	46.24	1.95	17.76	9.60	1.18	79493.86
22	6.78	15.24	48.32	1.52	18.06	9.99	1.18	76194.14
23	0.69	14.38	62.30	1.18	17.90	10.74	1.16	70929.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	23	24	24	24	24	24	24
平均值	7.15	13.51	55.20	1.86	17.93	9.79	1.17	78151.81
最大值	10.34	18.44	71.27	2.97	20.73	10.74	1.19	83577.02
發生時間	2	5	0	10	18	23		1
最小值	0.69	2.52	42.82	0.77	14.42	8.83	1.12	70929.48
發生時間	23	19	15	18	10	15		23
零點偏移(率)	-0.02 %	-0.00 %	-0.16 %	-0.08 %		0.00		0.00 %
全幅偏移(率)	0.04 %	2.17 %	0.79 %	0.80 %		0.07		0.00 %
有效比率	100.00 %	95.83 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.36	17.51	57.88	2.56	17.06	10.38	1.07	83160.93
1	8.73	19.74	59.73	3.21	16.98	10.71	1.08	83422.46
2	9.14	14.83	61.71	3.41	16.18	10.83	1.06	81000.63
3	9.39	17.12	59.80	3.43	16.38	10.58	1.08	83442.18
4	7.68	14.39	60.22	2.91	16.65	10.69	1.07	81305.18
5	9.11	18.34	57.14	3.23	15.65	10.76	1.07	80952.99
6	9.37	18.39	58.69	3.11	16.34	10.49	1.07	85210.32
7	5.94	15.38	62.66	2.93	14.88	11.12	1.03	79139.61
8	9.97	14.05	59.35	2.83	16.40	10.70	1.07	79952.23
9	8.28	17.71	56.08	2.70	16.43	10.54	1.04	80749.51
10	8.48	14.74	57.54	3.42	14.36	10.88	1.02	79404.17
11	4.75	16.87	57.32	3.20	14.87	11.05	1.06	76797.08
12	2.45	無效	57.60	2.86	15.98	10.74	1.06	77140.91
13	6.16	14.23	55.29	3.33	15.91	10.69	1.01	77925.12
14	5.82	12.73	59.92	3.08	16.12	10.59	1.00	78184.86
15	7.61	10.74	55.82	3.06	16.11	10.58	1.03	76901.22
16	6.19	11.40	51.79	3.26	14.85	10.72	1.06	75711.44
17	2.53	10.08	59.19	2.61	17.04	10.51	1.06	76788.16
18	3.05	10.65	51.87	2.51	16.20	10.57	1.03	75182.45
19	1.89	11.54	63.14	2.58	16.07	10.99	1.00	72951.23
20	2.70	10.82	58.79	2.29	17.79	10.39	1.00	80432.51
21	5.56	15.54	56.54	2.42	16.78	10.39	1.04	79716.33
22	4.56	11.94	62.31	2.53	17.07	10.44	1.04	79257.04
23	3.24	13.52	56.79	2.33	16.81	10.79	0.99	75612.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	23	24	24	24	24	24	24
平均值	6.12	14.45	58.22	2.91	16.20	10.67	1.04	79180.89
最大值	9.97	19.74	63.14	3.43	17.79	11.12	1.08	85210.32
發生時間	8	1	19	3	20	7		6
最小值	1.89	10.08	51.79	2.29	14.36	10.38	0.99	72951.23
發生時間	19	17	16	20	10	0		19
零點偏移(率)	-0.13 %	0.00 %	-0.07 %	-0.06 %		0.02		0.00 %
全幅偏移(率)	0.04 %	1.02 %	-0.38 %	0.68 %		0.28		0.00 %
有效比率	100.00 %	95.83%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								