

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月28日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	9.20	13.41	61.73	1.65	18.02	10.90	1.18	74057.60
1	6.88	12.27	61.78	1.63	19.70	10.61	1.16	75756.85
2	7.91	12.04	57.46	2.07	19.59	10.50	1.15	76872.27
3	10.62	12.32	61.25	2.01	18.96	10.75	1.15	76133.84
4	7.00	12.66	64.89	1.76	19.48	11.04	1.16	73153.01
5	12.28	11.42	52.81	2.22	19.72	10.39	1.16	79038.55
6	7.91	11.84	52.73	2.54	18.73	10.84	1.15	74731.20
7	9.30	11.55	59.32	2.63	18.25	11.13	1.15	73090.44
8	9.87	11.41	59.68	2.23	19.57	10.88	1.16	74044.66
9	7.29	11.24	58.74	1.76	19.97	10.67	1.18	74888.27
10	9.02	12.62	57.09	2.90	18.51	11.20	1.18	72413.74
11	9.11	12.74	54.46	2.45	19.06	10.99	1.17	73766.30
12	10.11	12.48	63.40	2.61	19.63	10.72	1.16	75042.28
13	10.27	13.19	48.50	2.96	18.50	11.03	1.16	73135.28
14	8.06	13.85	57.75	1.80	18.98	11.06	1.15	72454.74
15	9.93	13.52	54.07	2.94	18.57	11.33	1.18	70512.50
16	10.13	12.92	58.21	2.85	18.96	11.13	1.16	72742.02
17	9.38	13.28	62.28	3.06	17.50	11.48	1.14	71100.99
18	8.22	13.11	59.40	1.43	21.29	10.39	1.16	75626.58
19	10.48	12.72	60.97	1.78	20.88	10.38	1.15	76173.40
20	7.59	12.59	58.59	2.09	19.23	10.75	1.18	75047.26
21	10.31	13.16	60.75	3.12	18.03	11.08	1.17	73717.00
22	10.54	13.23	62.28	3.42	17.32	11.43	1.16	71599.33
23	7.54	12.87	64.95	2.31	19.56	10.91	1.15	73502.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.12	12.60	58.88	2.34	19.08	10.90	1.16	74108.36
最 大 值	12.28	13.85	64.95	3.42	21.29	11.48	1.18	79038.55
發生時間	5	14	23	22	18	17		5
最 小 值	6.88	11.24	48.50	1.43	17.32	10.38	1.13	70512.50
發生時間	1	9	13	18	22	19		15
零點偏移(率)	-0.10 %	0.01 %	-0.04 %	-0.02 %		-0.03	-0.01	0.20 %
全幅偏移(率)	0.27 %	-0.92 %	0.44 %	-0.53 %		-0.04	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月28日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.04	13.13	59.95	1.55	17.95	10.63	0.97	85304.60
1	5.57	12.83	59.59	2.69	17.64	11.05	0.98	82771.62
2	8.27	12.57	64.57	1.71	17.61	11.11	0.98	81783.21
3	8.71	13.31	61.76	1.77	17.31	11.60	0.99	78206.61
4	7.46	12.26	52.74	1.28	18.92	10.26	0.97	87692.18
5	10.90	13.01	51.45	1.36	18.63	10.24	0.97	87625.34
6	2.40	12.55	47.41	1.58	19.10	10.42	0.96	83618.82
7	5.37	12.39	59.11	1.65	17.90	10.92	0.96	83282.17
8	7.09	12.37	55.08	1.18	18.88	10.69	0.96	84035.86
9	6.73	12.32	57.72	1.01	18.90	10.64	0.96	84450.22
10	4.03	12.38	55.61	1.08	17.49	11.00	0.96	82328.71
11	4.70	12.54	55.47	1.56	17.43	11.12	0.97	81591.72
12	7.09	12.72	57.64	1.39	17.47	10.90	0.94	83132.31
13	10.38	12.57	52.33	1.38	17.96	10.68	0.94	84204.64
14	3.83	12.75	58.34	1.60	16.81	11.08	0.97	82037.75
15	5.79	13.15	62.95	1.11	19.60	10.33	1.00	85579.10
16	2.94	12.62	47.49	1.11	18.20	10.86	0.95	82902.59
17	7.87	12.55	52.07	1.26	18.42	10.83	0.94	82697.23
18	6.53	12.48	56.32	1.50	18.14	10.94	0.95	82010.44
19	9.44	12.21	58.73	1.57	19.05	10.61	0.96	84409.48
20	11.80	12.42	57.98	1.43	18.92	10.75	0.97	83362.16
21	8.35	12.91	51.88	2.20	17.74	10.98	0.94	83004.83
22	14.82	13.12	56.84	2.57	18.39	10.79	0.94	83841.98
23	10.16	11.94	64.44	1.13	18.93	10.52	0.94	85240.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.39	12.63	56.56	1.53	18.22	10.79	0.96	83546.42
最 大 值	14.82	13.31	64.57	2.69	19.60	11.60	1.04	87692.18
發生時間	22	3	2	1	15	3		4
最 小 值	2.40	11.94	47.41	1.01	16.81	10.24	0.94	78206.61
發生時間	6	23	6	9	14	5		3
零點偏移(率)	-0.10 %	0.01 %	-0.03 %	-0.01 %		0.02	-0.01	-0.10 %
全幅偏移(率)	1.44 %	-1.53 %	0.76 %	-0.43 %		0.06	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月28日

[illegible]