

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年04月29日

報表日期: 113年04月29日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.89	7.10	61.18	0.58	18.99	11.12	0.97	84239.55
1	9.38	7.06	56.55	0.44	20.22	10.58	0.97	87941.59
2	6.17	7.45	43.71	0.64	17.89	11.41	0.97	82998.48
3	0.48	9.18	61.38	0.32	17.73	12.58	1.01	73048.74
4	3.01	7.87	52.53	0.34	18.63	11.34	1.00	82903.79
5	6.42	4.64	53.11	0.64	18.94	10.80	1.02	87373.64
6	8.77	3.88	47.11	0.76	18.39	11.24	1.02	84301.69
7	9.05	3.79	50.66	1.17	16.18	12.15	1.02	77898.39
8	6.85	4.40	73.22	0.47	16.41	12.75	1.02	72690.13
9	6.57	3.61	57.84	0.43	16.46	12.06	1.03	78589.73
10	11.91	3.72	48.03	1.03	16.85	11.40	0.99	83836.69
11	9.21	3.22	49.86	0.71	17.24	11.42	1.02	82889.32
12	9.75	3.60	42.56	1.10	16.38	11.87	0.98	80050.14
13	8.63	3.51	54.45	0.59	17.54	11.75	0.98	79998.52
14	9.07	4.11	58.56	0.81	16.85	11.98	1.00	78725.68
15	9.71	3.97	50.51	1.06	17.87	11.61	0.99	81088.79
16	9.96	3.35	49.12	0.48	18.16	11.21	0.97	84633.15
17	13.63	3.58	45.91	1.05	17.94	11.13	0.97	85009.79
18	9.77	4.09	47.89	1.41	17.03	11.29	0.97	84491.05
19	8.61	4.08	49.15	1.07	16.86	11.27	0.98	84969.47
20	7.36	4.37	49.57	0.97	16.94	11.63	1.00	81765.43
21	8.86	5.27	52.26	0.86	17.32	11.76	0.99	80440.60
22	9.52	4.75	48.38	1.16	17.20	11.49	0.97	82517.04
23	7.91	5.74	63.17	0.68	16.76	11.81	0.97	80734.96
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.31	4.85	52.78	0.78	17.53	11.57	0.99	81797.35
最 大 值	13.63	9.18	73.22	1.41	20.22	12.75	1.12	87941.59
發生時間	17	3	8	18	1	8		1
最 小 值	0.48	3.22	42.56	0.32	16.18	10.58	0.95	72690.13
發生時間	3	11	12	3	7	1		8
零點偏移(率)	-0.02 %	-0.01 %	-0.03 %	-0.01 %		-0.15		0.00 %
全幅偏移(率)	0.00 %	-0.02 %	0.15 %	0.62 %		-0.07		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 113年04月29日

報表日期: 113年04月29日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	5.57	5.16	52.58	1.10	19.92	10.32	1.02	84113.23
1	6.79	5.79	46.48	1.41	19.92	10.13	1.02	85270.72
2	5.74	3.05	60.42	0.77	19.63	10.74	1.01	80980.73
3	6.11	3.56	44.67	0.75	19.96	10.31	1.02	84023.60
4	5.73	3.75	51.63	0.56	20.19	10.03	1.02	85946.62
5	7.73	3.87	61.02	1.83	16.58	10.96	1.02	81422.06
6	9.45	2.65	51.10	1.58	18.04	10.76	1.03	66734.92
7	7.61	4.51	57.03	1.62	17.52	11.00	1.03	80527.08
8	5.92	4.67	62.97	0.97	18.51	11.12	1.05	79219.08
9	9.21	4.52	31.58	0.88	19.75	10.33	1.06	84307.27
10	9.30	5.27	39.58	2.53	16.78	10.93	1.05	82004.88
11	5.63	5.39	51.83	2.86	15.01	11.72	1.05	77265.55
12	4.07	5.14	63.13	2.66	13.95	12.04	1.06	75578.11
13	2.53	4.11	69.55	1.42	16.88	11.51	1.06	76986.69
14	1.47	5.45	67.51	1.40	17.47	11.77	1.06	74384.00
15	5.67	5.46	54.32	2.50	16.75	11.37	1.06	78635.09
16	9.47	2.64	53.71	2.44	16.40	11.19	1.06	80431.51
17	7.85	2.59	56.42	2.85	15.54	11.51	1.04	78188.78
18	5.04	2.80	58.37	2.51	17.19	10.95	1.04	81483.55
19	7.90	3.23	50.67	1.14	19.38	10.08	1.04	86080.35
20	5.05	3.24	47.69	2.15	16.97	10.94	1.02	81961.89
21	6.35	3.27	52.68	1.61	18.01	10.67	1.04	83399.94
22	3.27	3.00	68.43	1.32	17.68	11.46	1.04	77229.12
23	1.03	4.27	66.33	1.37	17.27	11.84	1.05	74728.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.02	4.06	54.99	1.68	17.72	10.99	1.04	80037.63
最 大 值	9.47	5.79	69.55	2.86	20.19	12.04	1.06	86080.35
發生時間	16	1	13	11	4	12		19
最 小 值	1.03	2.59	31.58	0.56	13.95	10.03	1.00	66734.92
發生時間	23	17	9	4	12	4		6
零點偏移(率)	-0.13 %	-0.06 %	-0.06 %	-0.02 %		-0.08		-0.10 %
全幅偏移(率)	0.14 %	1.20 %	0.05 %	0.16 %		-0.35		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月29日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.90	7.20	46.49	0.22	19.71	9.98	0.94	81153.56
1	3.30	8.86	46.33	0.21	20.20	9.69	0.96	83301.16
2	0.14	5.10	51.83	0.25	20.89	10.23	0.95	79007.50
3	0.61	6.94	37.25	0.26	21.42	9.02	0.97	89092.07
4	4.93	6.16	42.69	0.20	19.53	9.87	0.99	84185.39
5	0.89	3.54	53.83	0.33	18.23	10.29	0.98	80029.10
6	0.49	6.26	38.52	1.43	18.59	9.57	0.97	77714.51
7	0.25	6.02	38.29	0.22	18.86	10.24	0.98	76628.14
8	1.66	10.44	55.62	2.30	22.14	9.13	0.98	78251.23
9	1.50	7.54	37.13	4.21	22.05	7.51	0.99	82102.15
10	1.65	13.08	51.07	1.46	20.42	8.19	0.96	77827.72
11	3.45	4.29	48.89	0.09	19.41	8.86	0.99	75255.30
12	1.59	2.68	42.16	0.20	18.26	9.23	0.97	76021.87
13	1.67	1.25	45.28	0.19	17.52	10.05	0.94	75671.58
14	1.72	3.01	51.29	0.18	19.22	10.17	0.94	75326.43
15	1.66	3.99	32.74	0.20	18.65	9.77	0.99	80568.23
16	3.41	2.22	40.22	0.22	17.40	10.07	1.02	81052.86
17	5.25	2.58	51.38	0.23	17.89	10.00	1.01	82746.16
18	3.92	5.96	53.27	0.26	17.97	9.96	0.99	83787.88
19	6.57	4.42	51.22	0.26	18.33	9.90	0.96	83441.46
20	1.21	2.87	48.43	0.17	18.09	9.77	0.98	80633.22
21	7.78	2.94	53.67	0.23	18.32	9.84	0.99	81948.74
22	3.70	3.10	59.51	0.22	17.77	10.58	0.96	76731.81
23	0.85	5.17	57.32	0.19	17.74	10.46	0.94	77368.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.50	5.23	47.27	0.57	19.11	9.68	0.97	79993.63
最 大 值	7.78	13.08	59.51	4.21	22.14	10.58	1.03	89092.07
發生時間	21	10	22	9	8	22		3
最 小 值	0.14	1.25	32.74	0.09	17.40	7.51	0.92	75255.30
發生時間	2	13	15	11	16	9		11
零點偏移(率)	-0.10 %	0.01 %	-0.04 %	-0.02 %		-0.21		0.00 %
全幅偏移(率)	0.02 %	0.02 %	-0.01 %	0.02 %		-0.24		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								