

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.85	9.96	48.28	0.60	17.87	10.57	1.04	78024.17
1	7.97	3.48	57.01	1.38	16.14	11.57	1.04	73713.17
2	5.04	2.97	36.71	1.38	18.25	11.45	1.04	73327.59
3	4.39	4.49	46.33	0.62	19.04	11.39	1.05	73044.43
4	0.10	6.49	48.29	0.25	20.38	11.40	1.06	72008.62
5	0.13	11.83	58.20	0.54	17.95	12.13	1.05	69566.30
6	0.13	7.14	42.36	1.15	17.19	12.31	1.10	67803.18
7	0.60	2.49	51.49	0.68	19.15	10.78	1.02	77956.74
8	5.32	6.66	42.43	1.18	17.17	11.45	1.02	74537.05
9	5.05	7.15	41.37	1.20	17.32	11.62	1.02	71921.07
10	6.78	11.07	46.11	1.08	18.03	11.52	1.02	72816.83
11	4.31	9.92	45.93	1.17	16.98	11.93	1.02	70322.34
12	3.21	11.63	47.10	1.31	16.41	12.36	1.02	67916.03
13	0.76	10.68	51.74	0.85	17.22	12.22	1.02	68449.81
14	0.46	8.31	50.20	1.29	16.55	12.35	1.02	68513.89
15	0.46	10.23	56.22	1.27	16.93	12.36	1.01	67665.17
16	0.29	9.83	49.45	0.74	17.86	11.38	0.99	74390.65
17	1.42	10.76	39.62	1.55	16.48	11.44	1.00	74807.81
18	2.45	10.22	44.10	1.14	17.18	11.47	1.02	74169.91
19	4.54	10.05	50.46	1.05	17.65	11.41	1.01	73901.18
20	6.41	9.94	52.21	0.97	18.16	11.27	0.99	74703.14
21	5.58	11.16	48.74	1.14	17.24	11.78	0.99	70931.09
22	4.18	11.76	56.81	0.64	17.98	11.89	0.99	69933.17
23	1.41	9.87	56.32	0.61	18.19	11.93	0.99	69911.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.29	8.67	48.65	0.99	17.64	11.67	1.02	72097.30
最大值	7.97	11.83	58.20	1.55	20.38	12.36	1.27	78024.17
發生時間	1	5	5	17	4	12		0
最小值	0.10	2.49	36.71	0.25	16.14	10.57	0.97	67665.17
發生時間	4	7	2	4	1	0		15
零點偏移(率)	-0.04 %	-0.02 %	-0.04 %	-0.00 %		-0.05		0.00 %
全幅偏移(率)	0.02 %	0.22 %	0.26 %	0.02 %		0.08		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.25	3.87	61.84	1.08	16.60	10.28	1.03	86430.84
1	6.53	4.69	57.02	1.89	15.76	10.80	1.02	82305.74
2	9.26	1.32	51.06	2.00	18.16	9.78	1.02	88456.62
3	7.25	4.24	58.35	1.08	18.40	10.06	1.02	87005.07
4	6.59	3.90	46.49	0.49	21.30	9.36	1.02	88646.07
5	9.90	6.39	59.30	1.23	20.51	9.36	1.02	89355.41
6	9.68	4.65	48.03	1.21	18.63	10.15	1.01	84081.39
7	8.50	4.37	39.50	1.36	18.93	9.91	1.01	86598.23
8	7.20	5.05	47.30	1.20	17.94	10.46	1.02	84088.40
9	6.87	2.90	58.48	1.02	18.14	9.87	1.02	88541.04
10	8.78	4.94	43.38	1.78	16.82	10.46	1.02	83157.00
11	8.44	8.13	40.49	2.03	16.63	10.46	1.02	84369.47
12	8.28	10.80	47.62	1.38	17.48	10.43	1.02	84745.65
13	6.02	10.65	48.42	1.46	17.31	10.56	1.02	83844.15
14	6.32	8.59	54.48	1.22	17.73	10.46	1.02	83543.39
15	8.32	11.20	57.07	1.62	17.66	10.23	1.02	85952.22
16	8.34	4.60	50.80	1.59	17.17	10.17	1.01	87170.93
17	3.75	2.43	51.94	1.18	17.05	10.28	1.02	85603.63
18	1.28	7.96	46.74	0.78	17.96	10.18	1.02	85854.66
19	4.66	7.34	38.14	1.37	18.54	9.79	1.00	87559.44
20	4.88	4.60	49.85	1.05	18.66	9.61	0.99	89992.89
21	6.16	8.82	43.64	1.59	17.82	9.94	1.00	87701.38
22	5.52	5.50	56.07	1.27	17.98	10.55	1.00	82089.16
23	1.82	6.78	51.78	0.83	19.18	10.92	1.02	78492.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.73	5.99	50.32	1.32	18.02	10.17	1.02	85649.39
最大值	9.90	11.20	61.84	2.03	21.30	10.92	1.04	89992.89
發生時間	5	15	0	11	4	23		20
最小值	1.28	1.32	38.14	0.49	15.76	9.36	0.99	78492.52
發生時間	18	2	19	4	1	4		23
零點偏移(率)	-0.01 %	-0.03 %	-0.03 %	-0.01 %		0.01		-0.10 %
全幅偏移(率)	0.04 %	-0.48 %	-1.00 %	-0.74 %		-0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.33	7.42	43.91	2.34	15.04	9.46	0.91	75919.25
1	9.11	5.28	49.91	2.17	14.73	10.00	0.91	77252.63
2	7.55	5.86	49.68	1.42	16.30	10.43	0.91	76925.85
3	7.70	2.36	43.35	2.36	14.07	10.76	0.91	75544.18
4	3.53	1.59	64.23	1.20	15.51	10.79	0.94	76420.60
5	6.27	1.86	49.30	1.62	15.89	10.52	0.94	81908.95
6	3.54	4.42	66.58	1.58	15.15	11.25	0.95	74921.30
7	7.21	8.76	46.88	2.06	14.34	11.12	0.94	73303.94
8	2.11	5.13	63.97	1.12	15.36	11.13	0.94	75234.79
9	4.61	3.96	49.61	1.29	15.56	10.78	0.95	80184.55
10	3.22	4.43	52.62	1.78	14.03	11.39	0.96	75924.16
11	4.57	3.70	54.60	1.45	14.97	11.19	0.95	76870.69
12	4.47	3.10	54.55	1.47	14.82	11.18	0.97	76966.48
13	0.50	3.00	61.10	1.07	15.22	11.44	0.97	76417.19
14	0.75	4.26	52.79	1.33	14.47	11.53	0.98	75993.87
15	0.32	3.45	55.25	1.53	14.18	11.79	0.98	74849.47
16	0.13	2.74	56.39	0.97	15.59	11.05	0.96	79546.33
17	0.57	4.80	46.79	0.96	15.82	10.27	0.97	78972.99
18	1.14	6.08	53.33	1.21	14.80	10.85	0.94	74599.46
19	3.58	4.55	47.87	0.80	16.04	10.67	0.94	81092.57
20	3.81	6.91	50.96	0.83	16.33	10.53	0.95	80270.76
21	3.71	8.53	51.46	0.89	16.33	10.15	0.96	81375.46
22	4.30	7.26	43.22	1.29	14.76	10.50	0.95	79061.36
23	1.65	5.99	57.46	0.86	16.19	10.82	0.95	76802.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.86	4.81	52.74	1.40	15.23	10.82	0.95	77348.32
最大值	9.11	8.76	66.58	2.36	16.33	11.79	0.99	81908.95
發生時間	1	7	6	3	20	15		5
最小值	0.13	1.59	43.22	0.80	14.03	9.46	0.90	73303.94
發生時間	16	4	22	19	10	0		7
零點偏移(率)	0.00 %	-0.05 %	-0.00 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.00 %	-0.42 %	0.37 %		0.46		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								