

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年07月31日

報表日期: 113年07月31日

[illegible]

報表日期: 113年07月31日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.11	2.37	60.25	0.87	19.15	10.36	0.94	84881.30
1	6.47	2.93	57.10	1.66	18.90	10.69	0.94	82274.36
2	8.67	3.58	50.26	2.13	16.86	10.86	0.94	83381.58
3	7.49	3.43	53.87	2.27	16.53	11.11	0.94	81109.46
4	8.15	2.00	52.29	2.23	17.10	10.89	0.94	82933.19
5	6.11	2.51	57.35	2.42	16.69	11.32	0.94	79738.32
6	11.64	1.52	58.98	2.36	18.22	10.71	0.99	79266.28
7	12.53	2.86	46.20	2.84	16.28	11.16	1.00	82745.87
8	13.41	2.40	50.04	1.62	16.63	11.19	0.98	80872.48
9	9.08	2.97	50.94	2.10	16.53	11.23	0.99	80125.15
10	5.64	2.02	48.31	2.58	16.38	11.08	1.01	81224.55
11	5.58	3.25	52.25	2.53	15.85	11.18	1.01	81188.22
12	3.94	4.03	47.84	1.84	15.75	11.36	1.02	79706.50
13	5.34	8.11	51.31	2.61	16.02	10.95	1.01	82442.08
14	12.08	4.39	49.33	2.71	15.97	11.15	1.00	81552.92
15	10.86	2.42	48.86	2.54	16.77	11.12	0.98	80562.12
16	13.44	1.85	57.96	1.26	18.72	10.52	0.99	83749.88
17	9.94	2.75	39.02	1.32	18.15	10.79	0.98	81416.44
18	15.50	2.45	41.38	1.82	17.21	10.78	0.99	83161.55
19	16.10	2.30	43.64	1.73	17.62	10.76	0.99	83131.17
20	9.68	2.55	42.98	1.61	17.11	10.86	0.99	82401.69
21	9.48	1.71	47.91	1.32	17.91	10.67	0.99	83302.60
22	10.75	2.35	47.99	2.07	17.00	10.98	0.99	81600.39
23	13.42	1.83	61.60	1.48	18.28	10.53	0.99	83610.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.77	2.86	50.74	2.00	17.15	10.93	0.98	81932.43
最 大 值	16.10	8.11	61.60	2.84	19.15	11.36	1.02	84881.30
發生時間	19	13	23	7	0	12		0
最 小 值	3.94	1.52	39.02	0.87	15.75	10.36	0.94	79266.28
發生時間	12	6	17	0	12	0		6
零點偏移(率)	-0.06 %	-0.01 %	-0.02 %	-0.04 %		-0.06		-0.10 %
全幅偏移(率)	0.13 %	-0.13 %	0.13 %	0.54 %		-0.08		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

