

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年06月28日

報表日期: 113年06月28日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.35	5.02	52.54	1.43	17.93	11.70	1.02	80290.74
1	8.74	5.10	54.37	1.37	20.63	10.60	1.02	86556.31
2	9.46	5.49	51.70	2.22	18.77	11.04	1.02	84811.16
3	14.50	5.50	66.71	3.48	18.40	11.62	1.02	80236.44
4	8.53	5.95	62.95	0.46	17.61	11.74	1.01	80283.44
5	11.10	5.05	58.66	1.79	18.40	11.45	1.02	75730.31
6	8.68	3.10	49.22	1.48	18.35	11.09	1.02	84989.93
7	10.91	3.24	46.31	2.06	17.29	11.41	1.02	83274.38
8	10.91	2.73	48.93	2.14	18.05	11.05	1.00	85328.40
9	10.85	3.05	44.77	3.16	17.03	11.32	0.99	84181.80
10	12.94	3.32	49.20	3.32	15.72	11.79	1.02	81421.66
11	11.46	4.20	48.79	2.74	16.34	11.48	1.00	83055.11
12	10.42	3.30	51.36	2.58	16.52	11.61	0.98	81714.67
13	9.67	2.82	49.23	2.53	16.31	11.59	0.99	82021.30
14	11.57	5.74	47.03	3.25	14.40	12.32	1.01	75503.18
15	6.86	1.42	47.10	0.93	13.45	12.73	0.98	75499.19
16	8.38	1.23	49.78	0.94	16.36	11.63	0.98	81814.64
17	9.26	5.69	51.92	2.76	16.54	11.27	0.98	84749.04
18	5.78	3.72	49.30	2.14	16.41	11.92	0.97	77630.12
19	11.81	3.13	58.06	1.91	20.33	10.38	0.99	89067.31
20	9.80	2.96	53.92	1.89	19.14	10.78	0.99	86837.67
21	12.51	2.87	43.99	3.26	16.67	11.57	1.04	83868.90
22	10.73	2.94	52.49	3.36	16.38	11.84	0.98	81712.84
23	11.03	3.33	64.76	3.00	16.38	12.27	0.97	76948.22
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.18	3.79	52.21	2.26	17.23	11.51	1.00	81980.28
最 大 值	14.50	5.95	66.71	3.48	20.63	12.73	1.08	89067.31
發生時間	3	4	3	3	1	15		19
最 小 值	5.78	1.23	43.99	0.46	13.45	10.38	0.97	75499.19
發生時間	18	16	21	4	15	19		15
零點偏移(率)	-0.20 %	-0.05 %	-0.00 %	-0.02 %		-0.06		0.00 %
全幅偏移(率)	0.00 %	-0.15 %	0.24 %	0.24 %		0.20		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 113年06月28日

報表日期: 113年06月28日

項目 單位	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.12	1.94	46.68	0.91	17.82	11.35	0.94	78236.07
1	0.57	2.55	56.00	1.93	17.12	12.00	0.94	73892.80
2	1.56	2.19	46.56	0.95	18.82	10.66	0.94	82929.23
3	1.60	2.11	45.62	1.53	17.52	11.15	0.94	79948.68
4	1.55	1.91	47.81	1.95	17.20	11.14	0.94	80564.36
5	1.34	2.83	50.69	1.79	17.36	11.19	0.94	80220.04
6	0.81	2.01	51.41	0.61	18.41	10.66	0.96	79109.08
7	1.06	5.84	43.56	1.56	17.27	10.99	0.96	81234.71
8	0.72	1.67	47.80	1.70	17.15	10.97	0.98	81613.90
9	4.13	1.78	51.09	1.72	16.71	11.33	0.97	79020.64
10	7.68	6.72	53.54	2.73	14.68	11.71	0.99	77340.66
11	0.95	2.32	53.20	2.10	15.37	11.60	0.99	77854.34
12	0.38	2.31	54.98	2.60	14.85	11.85	0.98	76231.04
13	0.61	7.24	60.84	1.98	16.43	11.40	0.99	78609.02
14	2.25	14.04	64.19	2.87	14.73	11.85	1.01	77500.36
15	8.08	2.74	54.43	0.83	15.07	12.02	0.97	73929.75
16	5.60	1.79	51.44	1.30	15.00	11.78	0.98	76902.67
17	1.04	2.11	47.60	2.31	15.48	11.40	0.98	79994.67
18	0.43	2.29	54.17	2.17	16.37	11.48	0.97	78033.01
19	0.13	2.01	63.46	0.60	18.84	11.32	0.98	77704.90
20	0.19	2.71	47.81	0.66	19.14	10.33	0.97	84480.83
21	3.86	4.18	40.29	1.97	17.13	10.74	0.98	83714.27
22	1.93	2.79	60.23	2.09	16.04	11.90	0.99	75357.88
23	0.12	2.56	49.69	0.94	15.96	10.03	1.14	90660.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	1.95	3.36	51.80	1.66	16.69	11.29	0.98	79378.46
最 大 值	8.08	14.04	64.19	2.87	19.14	12.02	1.51	90660.04
發生時間	15	14	14	14	20	15		23
最 小 值	0.12	1.67	40.29	0.60	14.68	10.03	0.94	73892.80
發生時間	0	8	21	19	10	23		1
零點偏移(率)	-0.07 %	-0.01 %	-0.01 %	-0.00 %		-0.04		-0.20 %
全幅偏移(率)	0.13 %	-0.18 %	0.74 %	0.03 %		-0.10		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月28日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.02	1.47	61.44	1.40	18.56	9.84	1.00	83061.78
1	0.47	3.56	53.12	1.32	18.36	10.28	0.99	78714.10
2	1.92	1.64	65.70	1.47	17.02	11.24	0.99	73527.54
3	1.28	1.95	64.23	1.48	18.01	10.90	0.99	78066.09
4	1.28	4.05	53.94	1.48	17.16	11.03	0.99	77737.98
5	1.83	4.03	49.57	1.44	17.81	10.12	0.99	84242.31
6	2.20	8.28	47.08	1.49	17.31	10.35	0.99	82286.12
7	0.95	4.78	65.61	1.62	16.40	11.72	1.01	77390.29
8	0.48	3.51	51.91	1.53	17.83	10.63	1.04	79719.01
9	4.56	2.47	41.48	1.62	16.99	10.66	0.99	80777.89
10	1.49	3.97	50.04	1.85	15.40	11.10	1.03	78944.74
11	3.59	3.87	59.09	2.16	15.15	11.13	1.03	79467.66
12	0.95	2.98	62.31	2.16	14.77	11.43	0.99	75862.38
13	1.13	2.22	58.77	1.62	16.44	11.29	1.00	75059.34
14	1.42	2.03	49.86	1.57	16.06	11.15	0.99	73808.50
15	2.85	7.69	40.69	2.28	14.36	11.47	0.97	69962.58
16	2.92	2.52	48.27	1.84	15.78	11.04	0.99	76333.07
17	0.79	2.20	48.05	1.70	16.10	10.38	1.01	84841.38
18	2.69	2.73	51.66	1.81	16.33	11.04	1.04	78981.28
19	0.03	4.23	62.56	1.53	17.89	11.16	1.26	76328.93
20	0.03	5.91	54.35	1.58	20.24	10.09	1.04	82517.07
21	0.19	4.97	47.92	1.56	16.55	10.03	1.02	84366.07
22	2.48	2.36	51.59	1.75	16.15	10.50	1.02	80696.66
23	0.96	1.37	57.59	1.60	16.78	10.57	1.01	81103.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	1.60	3.53	54.03	1.66	16.81	10.80	1.02	78908.17
最 大 值	4.56	8.28	65.70	2.28	20.24	11.72	2.04	84841.38
發生時間	9	6	2	15	20	7		17
最 小 值	0.03	1.37	40.69	1.32	14.36	9.84	0.92	69962.58
發生時間	19	23	15	1	15	0		15
零點偏移(率)	-0.28 %	-0.01 %	-0.03 %	-0.05 %		-0.03		0.00 %
全幅偏移(率)	0.02 %	0.37 %	-0.45 %	0.13 %		0.41		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								