

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.44	6.09	55.22	0.53	20.23	10.76	1.04	77401.12
1	9.90	5.85	45.59	0.64	20.61	10.11	1.05	81684.52
2	12.68	5.90	47.19	2.03	17.93	11.07	1.05	76357.21
3	8.42	9.06	50.57	2.02	16.89	11.52	1.07	74929.92
4	8.86	7.82	48.05	1.38	17.41	11.46	1.06	74716.97
5	6.31	8.80	53.12	0.92	16.90	11.92	1.05	72196.11
6	7.00	6.16	61.76	0.54	18.69	11.20	1.05	76095.78
7	3.33	7.84	62.12	0.51	17.91	11.47	1.06	74402.22
8	6.88	8.65	46.10	1.19	18.16	11.10	1.06	75076.69
9	2.46	4.52	44.27	1.06	16.60	11.78	1.06	73531.74
10	8.22	7.89	42.84	1.36	16.79	11.63	1.05	73775.92
11	10.53	7.71	40.25	1.84	16.63	11.12	1.05	75733.27
12	9.49	4.63	43.38	1.60	16.13	11.59	1.05	73155.23
13	8.09	2.96	54.86	0.63	17.87	11.36	1.05	74577.72
14	5.81	5.26	51.51	0.90	17.35	12.07	1.06	69248.33
15	7.15	3.87	44.58	0.59	18.28	11.04	1.05	76060.22
16	8.80	9.39	45.23	1.28	16.68	11.78	1.04	72121.11
17	9.21	9.10	44.15	1.24	18.29	11.23	1.03	75845.73
18	8.74	10.34	53.28	0.97	19.09	11.08	1.04	76292.81
19	7.43	9.95	56.58	0.40	19.73	10.93	1.04	77098.69
20	8.38	10.12	48.10	0.80	18.89	10.80	1.05	78485.37
21	9.42	9.36	54.74	0.66	19.03	10.98	1.05	77395.47
22	4.13	11.14	58.39	0.67	18.41	11.73	1.05	71689.74
23	5.49	8.00	63.66	0.42	19.48	11.56	1.05	72485.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.72	7.52	50.65	1.01	18.08	11.30	1.05	75014.89
最大值	12.68	11.14	63.66	2.03	20.61	12.07	1.12	81684.52
發生時間	2	22	23	2	1	14		1
最小值	2.46	2.96	40.25	0.40	16.13	10.11	1.03	69248.33
發生時間	9	13	11	19	12	1		14
零點偏移(率)	-0.07 %	-0.01 %	-0.01 %	0.00 %		-0.11		0.00 %
全幅偏移(率)	0.00 %	-1.15 %	0.25 %	0.23 %		0.11		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.10	3.50	59.31	2.44	16.00	10.77	0.99	82843.97
1	3.88	4.80	61.83	2.99	17.03	10.64	0.99	83339.36
2	9.63	3.39	57.07	3.68	15.17	10.81	0.99	84165.43
3	7.04	2.77	62.29	3.08	15.07	10.93	0.99	83356.13
4	3.09	2.85	60.93	2.51	16.24	10.70	1.00	83883.66
5	2.84	8.32	56.76	1.94	17.44	10.17	1.00	86841.84
6	4.16	5.53	56.48	3.61	15.09	10.90	0.99	76298.77
7	6.77	6.86	54.03	2.74	16.57	10.37	0.99	86346.75
8	6.34	3.83	64.87	3.44	16.03	10.42	0.99	86489.99
9	3.82	5.49	44.38	2.20	17.14	10.33	0.99	85801.18
10	1.20	3.84	54.39	1.56	18.50	10.12	1.01	86157.92
11	0.56	4.06	57.72	1.96	17.79	10.27	1.01	85458.84
12	0.62	8.54	63.26	1.99	17.71	10.34	1.00	84978.63
13	2.46	5.02	57.24	2.07	17.09	10.33	1.01	85726.47
14	4.92	12.91	57.65	3.08	15.88	10.63	1.00	83896.28
15	11.97	2.14	56.69	4.54	15.20	11.16	0.99	79235.45
16	9.52	4.98	66.04	1.49	17.11	10.70	0.99	83710.98
17	7.04	6.48	51.35	1.68	18.10	10.04	0.99	87782.97
18	1.78	6.58	50.31	1.13	18.74	9.90	0.99	87178.96
19	3.02	8.68	54.96	2.44	15.58	10.55	0.99	85549.50
20	2.19	4.06	58.08	1.92	16.15	10.39	1.00	86601.71
21	5.99	3.82	57.94	1.89	16.72	10.37	1.00	85617.14
22	2.89	3.93	60.63	1.49	17.09	10.77	1.01	82214.24
23	0.42	4.99	52.88	1.76	16.53	11.16	1.03	79203.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.39	5.31	57.38	2.40	16.67	10.53	1.00	84278.34
最大值	11.97	12.91	66.04	4.54	18.74	11.16	1.04	87782.97
發生時間	15	14	16	15	18	15		17
最小值	0.42	2.14	44.38	1.13	15.07	9.90	0.99	76298.77
發生時間	23	15	9	18	3	18		6
零點偏移(率)	-0.02 %	-0.04 %	-0.01 %	-0.00 %		-0.01		-0.20 %
全幅偏移(率)	-0.04 %	-0.74 %	0.23 %	-0.01 %		0.05		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.79	5.69	54.99	1.47	15.21	11.32	1.00	78402.48
1	9.11	5.96	55.11	1.63	15.53	11.16	1.00	80505.54
2	10.87	11.54	54.82	3.25	13.60	11.17	1.01	80659.11
3	14.44	9.40	53.48	5.67	11.96	11.62	1.01	73402.62
4	6.49	2.64	57.18	1.91	14.92	10.81	0.99	77472.54
5	7.51	10.31	50.93	1.34	15.75	10.71	0.99	79421.99
6	8.58	11.70	48.62	1.93	14.65	10.76	0.99	79730.73
7	5.42	10.34	52.22	0.91	16.12	10.84	0.99	75572.16
8	5.87	6.10	45.89	1.00	16.27	10.72	0.99	79542.00
9	5.09	7.09	44.51	1.23	16.32	10.47	0.98	78750.70
10	2.84	4.78	55.14	0.75	18.02	9.89	0.98	80370.15
11	2.17	6.89	46.98	0.89	16.12	10.58	0.99	78045.05
12	1.19	6.16	46.30	0.85	15.55	10.88	0.99	76927.39
13	1.18	11.34	43.91	1.21	15.29	10.75	0.98	77025.86
14	2.33	6.23	45.99	1.11	15.73	10.54	0.99	77907.95
15	1.99	9.72	54.31	1.97	14.00	11.32	0.99	74959.99
16	0.64	5.04	48.36	1.18	15.63	11.06	0.99	75408.32
17	4.85	6.29	55.47	1.04	15.95	10.95	0.99	79391.20
18	5.71	8.77	51.26	1.40	14.97	11.03	0.99	79480.76
19	8.27	9.36	50.87	2.72	13.96	10.86	1.01	77916.89
20	6.69	4.41	49.60	2.03	14.21	10.96	1.03	76995.37
21	5.99	7.76	45.14	1.62	14.57	10.73	0.99	77392.41
22	7.96	5.45	46.84	1.59	15.52	10.59	0.99	77911.24
23	5.16	6.89	46.86	0.89	16.68	10.44	0.99	76717.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.76	7.49	50.20	1.65	15.27	10.84	0.99	77912.91
最大值	14.44	11.70	57.18	5.67	18.02	11.62	1.13	80659.11
發生時間	3	6	4	3	10	3		2
最小值	0.64	2.64	43.91	0.75	11.96	9.89	0.97	73402.62
發生時間	16	4	13	10	3	10		3
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	-0.39 %	-0.13 %	-0.44 %	0.04 %		0.46		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								