

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.02	5.57	45.37	0.65	16.95	12.14	1.01	77475.31
1	9.30	5.61	45.70	0.91	18.78	11.46	1.02	82044.05
2	9.79	7.34	50.66	0.91	17.60	11.65	1.02	81374.92
3	9.60	7.94	42.95	1.41	17.65	11.42	1.02	83217.69
4	9.45	7.38	52.73	0.89	17.63	11.48	1.02	82459.83
5	9.78	12.47	60.17	2.10	16.60	11.63	1.02	85576.59
6	10.11	6.58	54.87	2.20	16.01	11.95	1.02	79926.41
7	10.40	6.34	59.68	1.51	17.01	11.76	1.02	81079.84
8	9.19	6.63	64.56	1.19	16.78	12.15	1.01	78041.54
9	9.48	6.64	46.91	1.82	16.70	11.41	1.00	83814.09
10	9.46	6.39	44.75	1.90	16.03	11.77	1.00	80990.85
11	5.35	6.96	52.83	1.44	16.72	11.97	0.97	78812.82
12	7.02	7.16	57.52	1.25	16.61	11.97	1.00	79047.20
13	7.75	7.45	43.90	2.42	15.23	11.97	1.02	80365.59
14	6.81	11.46	42.39	3.19	14.16	12.11	1.02	80138.87
15	7.23	3.11	60.02	1.94	15.81	12.45	1.00	75624.03
16	9.20	1.23	50.08	1.45	16.39	11.84	0.98	80242.95
17	8.51	1.45	35.97	3.11	15.61	11.72	0.99	81998.74
18	6.48	2.09	47.06	0.95	17.23	11.90	0.99	78688.90
19	7.93	5.46	31.72	1.51	16.77	11.47	0.98	83050.91
20	7.28	5.31	38.26	1.32	17.21	11.76	0.99	80393.24
21	7.48	5.64	38.42	1.41	17.31	11.69	1.00	80691.67
22	5.81	5.11	39.98	1.04	17.99	11.58	1.00	80999.63
23	4.30	5.12	42.70	0.88	17.55	11.80	0.99	79838.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.16	6.10	47.88	1.56	16.76	11.79	1.00	80662.24
最大值	10.40	12.47	64.56	3.19	18.78	12.45	1.03	85576.59
發生時間	7	5	8	14	1	15		5
最小值	4.30	1.23	31.72	0.65	14.16	11.41	0.97	75624.03
發生時間	23	16	19	0	14	9		15
零點偏移(率)	-0.13 %	-0.05 %	-0.06 %	-0.01 %		-0.06		0.00 %
全幅偏移(率)	0.00 %	-3.88 %	-0.03 %	0.00 %		-0.05		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.97	2.99	44.85	2.42	17.87	10.87	0.98	81179.88
1	5.40	3.87	36.39	2.16	17.31	11.49	0.97	77057.94
2	8.26	3.39	57.15	2.55	16.30	11.63	0.98	76828.77
3	8.85	3.49	57.18	2.53	16.38	11.52	0.99	77868.40
4	10.59	2.85	60.79	2.09	17.22	11.20	0.99	79566.32
5	7.50	4.00	52.70	2.45	16.59	11.37	0.99	78907.92
6	9.91	3.68	50.93	2.26	17.18	11.38	1.02	75691.61
7	9.94	3.25	52.29	2.07	17.33	11.45	1.02	77826.84
8	8.69	4.56	45.52	2.12	17.82	10.85	1.02	81571.63
9	10.11	2.95	42.84	2.51	17.35	10.97	1.03	81320.44
10	8.32	3.37	48.57	2.79	16.12	11.57	1.05	77071.08
11	6.08	2.77	50.23	2.32	16.63	11.47	1.04	77581.05
12	2.74	3.03	43.98	2.70	15.71	11.66	1.02	77205.29
13	6.56	3.23	53.88	2.92	15.64	11.76	1.03	76087.07
14	6.98	3.37	53.93	1.76	17.05	11.47	1.03	77567.49
15	7.10	5.52	49.16	2.18	17.23	11.26	1.02	78921.81
16	9.15	3.12	44.47	4.11	15.12	11.78	1.02	76456.56
17	6.51	1.25	50.38	2.51	16.16	11.80	1.03	75475.30
18	1.37	4.89	46.44	2.53	15.98	12.10	1.04	73007.38
19	2.66	5.83	47.49	3.26	16.24	11.75	1.04	76087.37
20	2.82	4.72	47.24	1.82	18.25	11.37	1.02	76923.27
21	7.34	4.11	45.26	2.57	17.31	11.24	1.03	78908.74
22	6.00	3.84	45.83	2.05	17.97	11.22	1.03	77989.27
23	3.84	3.58	46.75	2.35	16.88	11.54	1.04	76968.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.82	3.65	48.93	2.46	16.82	11.45	1.02	77669.60
最大值	10.59	5.83	60.79	4.11	18.25	12.10	1.06	81571.63
發生時間	4	19	4	16	20	18		8
最小值	1.37	1.25	36.39	1.76	15.12	10.85	0.97	73007.38
發生時間	18	17	1	14	16	8		18
零點偏移(率)	-0.09 %	-0.04 %	-0.01 %	-0.02 %		-0.05		-0.10 %
全幅偏移(率)	0.14 %	-0.30 %	0.66 %	-0.16 %		-0.26		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.10	5.03	49.76	0.48	16.81	11.17	0.98	76299.89
1	2.29	5.55	44.90	0.34	19.61	10.17	0.99	82729.62
2	5.83	5.25	48.25	0.54	16.90	10.94	0.98	80184.50
3	1.70	4.92	50.22	0.44	16.69	10.99	1.00	78985.23
4	8.43	4.57	46.98	0.69	17.01	10.74	0.99	80872.34
5	9.96	5.12	49.10	1.03	15.92	11.13	0.99	79332.05
6	5.36	4.74	51.73	0.55	17.56	10.74	0.99	81164.91
7	9.02	4.82	55.44	0.78	17.77	10.46	0.99	83854.73
8	7.53	4.27	52.41	0.68	17.73	10.48	0.99	82395.54
9	5.48	4.36	46.62	0.68	17.16	10.42	1.00	82219.35
10	7.26	4.67	53.28	0.74	16.55	10.96	1.00	78509.87
11	7.51	4.15	58.28	0.55	18.21	10.49	1.03	81676.01
12	3.20	4.02	50.97	0.52	16.52	10.86	0.99	79991.64
13	6.98	5.11	57.78	1.31	15.54	11.05	0.99	77871.77
14	4.86	10.11	51.19	0.93	16.08	10.85	0.99	80030.33
15	6.12	2.48	56.97	1.13	16.15	10.88	1.00	79844.39
16	7.42	1.38	55.23	1.01	16.66	10.84	1.02	80204.80
17	5.94	1.34	64.07	0.83	15.71	11.47	1.02	74888.68
18	6.69	2.38	61.49	0.68	16.96	11.01	0.99	77311.13
19	8.91	6.12	50.64	0.69	17.61	10.84	0.97	78914.05
20	8.87	7.13	50.83	0.58	19.29	10.14	0.98	82631.83
21	6.20	9.50	48.35	0.50	19.21	10.27	0.99	81430.35
22	4.63	4.28	28.31	0.42	19.50	9.42	0.98	78177.93
23	4.04	4.26	36.30	0.92	18.89	9.73	0.96	79652.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.14	4.82	50.80	0.71	17.33	10.67	0.99	79965.54
最大值	9.96	10.11	64.07	1.31	19.61	11.47	1.04	83854.73
發生時間	5	14	17	13	1	17		7
最小值	1.70	1.34	28.31	0.34	15.54	9.42	0.94	74888.68
發生時間	3	17	22	1	13	22		17
零點偏移(率)	0.52 %	-0.04 %	-0.05 %	0.00 %		-0.05		-0.10 %
全幅偏移(率)	0.02 %	-0.98 %	1.73 %	-3.58 %		-0.07		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								