

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.53	12.03	51.09	2.35	19.17	11.02	1.29	82025.53
1	7.64	12.43	51.81	2.38	18.16	11.69	1.29	76840.52
2	9.74	12.81	51.12	2.63	17.07	12.08	1.29	74015.67
3	8.97	12.16	48.85	2.76	18.55	11.16	1.28	81017.15
4	8.10	12.05	45.36	2.93	19.05	10.94	1.25	83117.70
5	7.17	12.26	59.20	3.16	17.16	11.61	1.27	89466.21
6	9.37	11.86	47.30	3.23	17.93	11.19	1.26	81945.23
7	10.45	12.01	51.89	2.71	18.42	11.01	1.26	82775.56
8	8.79	12.09	53.50	2.67	17.05	11.44	1.26	79746.10
9	8.39	11.71	58.33	2.81	17.87	11.09	1.27	82853.21
10	9.13	12.27	51.99	2.70	17.13	11.53	1.30	80210.57
11	4.19	12.08	52.83	3.08	16.52	11.55	1.30	80121.55
12	6.73	12.01	52.00	1.45	16.09	11.72	1.30	79006.15
13	7.74	12.23	55.20	1.11	17.20	11.73	1.29	75910.83
14	9.75	11.72	61.34	2.60	17.11	11.27	1.29	80969.40
15	8.72	12.01	62.71	1.73	16.54	11.65	1.29	78127.86
16	9.38	11.65	41.75	2.04	17.13	11.25	1.29	82013.98
17	9.49	12.00	50.90	2.44	15.42	11.62	1.29	79333.93
18	9.40	12.15	50.97	1.27	17.57	11.64	1.29	78773.00
19	9.47	12.14	53.20	1.50	16.79	11.67	1.30	79436.44
20	9.09	13.18	62.89	0.94	17.50	12.35	1.29	72693.35
21	9.06	11.63	54.29	1.20	19.11	10.98	1.27	83167.66
22	9.15	12.14	59.38	1.06	18.66	11.42	1.27	79643.19
23	8.28	11.95	38.13	1.93	18.49	11.26	1.26	81035.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.61	12.11	52.75	2.19	17.57	11.45	1.28	80176.91
最大值	10.45	13.18	62.89	3.23	19.17	12.35	1.32	89466.21
發生時間	7	20	20	6	0	20		5
最小值	4.19	11.63	38.13	0.94	15.42	10.94	1.25	72693.35
發生時間	11	21	23	20	17	4		20
零點偏移(率)	0.00 %	-0.01 %	-0.03 %	-0.01 %		-0.07	-0.01	0.30 %
全幅偏移(率)	0.96 %	0.57 %	0.96 %	1.44 %		-0.19	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.50	13.02	48.79	1.32	17.29	11.15	1.00	70058.05
1	11.36	12.54	52.78	1.30	19.55	10.56	1.01	81164.81
2	8.83	12.16	49.20	1.95	18.97	10.37	1.02	79933.96
3	9.40	12.49	48.03	2.69	17.95	10.42	1.02	80229.91
4	10.26	13.23	51.44	1.27	18.36	10.36	1.02	79781.96
5	9.00	12.93	49.02	1.53	18.64	10.23	1.02	80807.37
6	8.64	11.70	51.97	1.35	19.10	10.44	1.02	84313.29
7	9.48	11.88	50.79	1.45	18.78	10.27	1.02	81299.55
8	10.49	12.06	46.96	2.03	17.54	10.54	1.02	78580.86
9	10.15	12.03	49.58	1.64	17.38	10.56	1.02	78988.90
10	11.22	12.36	55.09	1.59	17.25	10.87	1.02	77519.51
11	7.56	12.27	54.61	1.51	16.92	10.87	1.03	78556.56
12	10.91	12.54	53.56	1.35	15.83	10.87	1.04	77495.41
13	5.84	11.87	44.22	1.23	15.53	10.63	1.03	75868.38
14	12.03	11.77	51.42	1.19	17.04	10.58	1.03	77149.23
15	6.62	11.68	45.81	1.02	17.07	10.47	1.02	78629.98
16	9.10	11.92	36.03	1.93	16.11	10.00	1.02	76059.01
17	8.79	11.96	61.48	1.08	18.67	10.46	1.01	75408.84
18	12.12	12.01	58.74	1.55	19.64	9.95	0.99	83134.24
19	6.98	13.10	38.62	2.13	17.25	9.77	1.00	79409.74
20	9.62	12.01	44.40	1.95	18.37	9.60	1.02	80739.58
21	9.01	11.42	51.51	1.25	18.72	9.81	1.00	81592.68
22	9.50	12.18	58.06	0.90	18.37	10.15	0.99	79596.78
23	9.58	12.51	46.12	1.26	18.46	10.13	0.98	80967.22
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.33	12.24	49.93	1.52	17.87	10.38	1.01	79053.58
最大值	12.12	13.23	61.48	2.69	19.64	11.15	1.05	84313.29
發生時間	18	4	17	3	18	0		6
最小值	5.84	11.42	36.03	0.90	15.53	9.60	0.97	70058.05
發生時間	13	21	16	22	13	20		0
零點偏移(率)	-0.07 %	-0.02 %	-0.06 %	-0.01 %		-0.10	-0.01	0.10 %
全幅偏移(率)	-1.75 %	1.78 %	0.60 %	0.40 %		-0.19	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.62	11.70	57.10	1.89	18.50	10.00	1.41	74562.91
1	9.24	12.34	52.50	2.20	20.35	9.47	1.43	78701.63
2	8.17	11.54	56.88	1.92	17.85	10.13	1.43	74272.18
3	11.26	12.34	50.81	2.30	20.16	9.46	1.40	77121.08
4	8.14	11.74	54.61	1.84	19.56	9.57	1.40	75405.40
5	9.23	11.38	61.09	2.02	19.32	9.69	1.41	76072.48
6	8.06	11.99	61.27	1.94	18.35	10.31	1.41	71595.56
7	6.86	11.14	50.17	1.40	18.99	9.75	1.41	75331.48
8	7.21	12.12	45.32	1.46	19.35	8.89	1.41	74831.01
9	9.69	11.56	52.53	1.70	18.62	9.51	1.40	71686.17
10	11.19	11.34	55.27	2.05	18.91	9.26	1.43	75185.78
11	7.60	12.00	53.96	1.83	19.51	9.28	1.42	73069.85
12	10.06	12.25	39.40	1.42	17.36	9.49	1.40	73222.07
13	7.33	12.84	45.20	1.67	16.25	9.64	1.36	69711.02
14	9.92	11.07	48.56	2.06	17.47	9.06	1.37	72664.18
15	9.51	11.06	50.24	1.83	17.28	9.58	1.38	70309.74
16	11.81	11.44	64.06	1.43	17.29	9.95	1.40	76380.68
17	6.79	11.02	49.58	1.33	16.30	9.83	1.39	76382.48
18	10.46	11.66	44.00	3.29	17.25	9.72	1.41	75599.90
19	7.22	10.78	43.90	1.19	17.84	9.39	1.38	74817.49
20	9.76	10.96	47.53	1.38	18.07	9.50	1.39	77218.41
21	8.42	11.12	44.80	1.35	17.78	9.69	1.39	77764.52
22	8.95	12.30	56.18	1.28	16.73	10.46	1.41	74300.58
23	10.78	12.19	58.76	1.82	18.16	10.03	1.40	77652.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.09	11.66	51.82	1.78	18.22	9.65	1.40	74744.14
最大值	11.81	12.84	64.06	3.29	20.35	10.46	1.43	78701.63
發生時間	16	13	16	18	1	22		1
最小值	6.79	10.78	39.40	1.19	16.25	8.89	1.36	69711.02
發生時間	17	19	12	19	13	8		13
零點偏移(率)	-0.11 %	-0.04 %	-0.03 %	0.00 %		0.04	-0.01	0.00 %
全幅偏移(率)	-0.21 %	0.51 %	1.47 %	1.17 %		-0.04	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								