

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.96	8.63	46.08	0.44	18.82	11.02	1.00	84575.71
1	0.14	9.27	64.29	0.49	20.09	11.73	1.02	77748.60
2	1.06	5.24	53.39	0.36	19.29	11.92	1.05	76909.59
3	1.60	9.14	57.19	0.40	19.04	12.10	1.01	75813.95
4	4.17	8.03	49.78	0.73	19.60	10.76	0.99	86583.10
5	10.15	5.60	59.66	1.17	17.44	11.82	1.01	82858.70
6	9.49	4.73	51.12	0.92	17.81	11.53	1.02	81633.01
7	4.59	5.22	60.81	0.53	17.86	12.09	1.02	76898.20
8	7.82	5.35	53.35	0.51	18.84	11.45	1.02	81585.63
9	9.11	5.00	61.40	0.43	19.46	10.87	0.99	85673.03
10	9.39	5.10	50.65	0.84	18.01	11.36	0.99	83228.59
11	8.49	4.92	57.66	0.48	17.91	11.62	0.99	80615.20
12	9.05	5.58	47.95	0.87	17.08	11.76	0.99	80222.66
13	9.12	6.04	46.50	1.01	17.36	11.60	1.01	81450.40
14	7.43	3.83	59.10	1.48	16.85	12.60	1.02	73436.90
15	8.39	2.46	48.75	1.96	17.20	11.64	1.01	81895.95
16	8.99	6.15	53.57	1.48	16.41	11.61	0.99	82895.32
17	8.82	5.68	54.23	1.35	16.79	11.52	1.01	82976.03
18	9.32	6.69	51.03	1.29	17.13	11.51	1.02	82752.32
19	2.00	8.56	54.54	0.66	15.71	13.15	1.02	69636.93
20	3.14	6.04	47.09	0.26	17.90	11.41	1.02	82981.58
21	7.77	6.19	41.07	0.41	18.36	10.84	1.00	87547.24
22	10.44	6.00	45.32	0.85	18.21	10.69	1.00	88601.04
23	10.15	7.14	62.23	0.89	18.22	11.29	1.02	83941.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.82	6.11	53.20	0.83	17.97	11.58	1.01	81352.54
最大值	10.44	9.27	64.29	1.96	20.09	13.15	1.27	88601.04
發生時間	22	1	1	15	1	19		22
最小值	0.14	2.46	41.07	0.26	15.71	10.69	0.97	69636.93
發生時間	1	15	21	20	19	22		19
零點偏移(率)	-0.10 %	-0.08 %	-0.03 %	0.00 %		-0.08		0.30 %
全幅偏移(率)	0.00 %	0.15 %	-0.65 %	0.38 %		-0.09		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.88	7.17	48.85	1.66	18.84	10.53	1.03	81904.22
1	1.63	8.01	54.23	1.36	20.42	10.29	1.02	82236.59
2	2.42	6.92	54.44	1.12	18.60	11.05	1.02	78847.70
3	1.91	12.83	62.25	2.39	16.10	13.33	1.10	62420.82
4	1.57	4.39	57.44	1.51	16.95	12.45	1.06	68412.02
5	2.16	3.76	40.62	1.49	19.15	10.86	1.02	79002.17
6	3.14	6.00	42.24	2.18	17.11	10.87	0.99	79436.54
7	9.92	4.70	48.96	2.24	17.03	11.27	0.99	78376.09
8	8.12	3.81	43.18	1.42	18.46	10.75	1.00	80979.47
9	5.17	3.86	40.54	1.43	17.94	11.11	1.02	78163.27
10	6.38	5.81	40.40	1.74	18.18	10.58	1.02	81913.40
11	2.13	4.13	46.63	1.86	17.04	11.03	1.01	77889.54
12	5.69	3.97	53.22	2.33	16.64	11.28	1.00	75682.08
13	9.30	3.88	51.79	2.82	16.13	11.35	0.99	76190.17
14	4.20	3.49	54.77	2.25	16.57	11.31	1.00	78111.36
15	3.17	3.69	51.44	2.45	15.79	11.29	0.98	78979.52
16	0.92	2.93	65.66	2.45	14.08	11.46	0.99	79331.73
17	0.14	2.73	62.37	1.61	15.48	11.45	1.00	77686.18
18	3.97	3.17	56.67	1.78	16.88	11.02	1.02	79874.16
19	6.84	5.20	55.05	3.57	14.34	11.33	1.02	79338.80
20	3.22	3.45	59.17	2.36	15.43	11.41	1.02	78097.91
21	9.35	2.55	60.63	1.82	17.10	10.95	1.02	80711.85
22	7.97	4.54	51.02	1.55	17.62	11.10	1.02	78393.46
23	9.01	5.01	44.88	1.60	18.15	10.92	0.99	79370.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.80	4.83	51.94	1.96	17.08	11.21	1.01	77972.92
最大值	9.92	12.83	65.66	3.57	20.42	13.33	1.22	82236.59
發生時間	7	3	16	19	1	3		1
最小值	0.14	2.55	40.40	1.12	14.08	10.29	0.97	62420.82
發生時間	17	21	10	2	16	1		3
零點偏移(率)	-0.13 %	-0.07 %	-0.02 %	-0.01 %		-0.04		-0.10 %
全幅偏移(率)	-0.31 %	0.17 %	0.23 %	0.59 %		-0.12		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.39	2.00	49.26	0.17	19.53	10.23	1.02	81230.91
1	1.42	3.60	49.60	0.25	19.57	10.47	1.02	79476.02
2	1.39	6.76	62.25	0.18	18.69	10.30	1.02	81742.51
3	1.71	9.28	63.11	0.35	16.82	12.40	1.10	67409.71
4	1.40	3.70	47.25	0.29	18.54	10.29	1.02	81253.54
5	1.38	3.47	46.93	0.25	17.73	10.36	1.01	81564.81
6	2.52	3.77	47.93	0.76	16.55	10.66	1.04	81022.29
7	5.25	4.61	52.57	0.39	18.42	10.39	1.03	80079.01
8	5.22	4.66	53.93	0.44	19.20	10.68	1.00	80848.71
9	4.13	4.41	45.99	0.48	17.27	11.33	0.99	78998.39
10	2.62	4.48	49.12	0.34	17.01	11.39	0.99	78054.54
11	5.90	4.25	45.04	0.99	16.23	11.37	1.02	79157.83
12	3.90	4.35	49.19	0.80	15.77	11.65	1.04	77187.13
13	2.40	4.03	49.19	0.72	16.03	11.55	1.02	78238.63
14	5.93	4.19	48.70	1.09	15.48	11.64	0.99	77814.04
15	6.18	4.21	50.63	1.05	15.77	11.62	1.03	78314.17
16	8.35	3.88	46.88	1.18	15.26	11.41	1.00	80467.60
17	3.87	3.61	53.77	0.97	15.90	11.41	0.99	79298.93
18	1.48	3.61	50.23	0.38	16.74	10.66	0.99	81802.85
19	2.36	3.42	49.28	0.44	15.83	10.96	0.99	79133.61
20	1.07	6.28	44.34	0.27	18.31	9.79	0.99	86430.03
21	9.73	5.07	44.31	0.48	18.61	9.67	0.99	86460.02
22	6.82	2.26	48.42	0.51	17.86	10.25	0.99	82900.75
23	6.81	9.44	55.13	0.30	18.52	10.52	1.02	80166.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.88	4.56	50.13	0.55	17.32	10.88	1.01	79960.51
最大值	9.73	9.44	63.11	1.18	19.57	12.40	1.52	86460.02
發生時間	21	23	3	16	1	3		21
最小值	1.07	2.00	44.31	0.17	15.26	9.67	0.98	67409.71
發生時間	20	0	21	0	16	21		3
零點偏移(率)	-0.09 %	-0.04 %	-0.02 %	0.00 %		-0.12		0.20 %
全幅偏移(率)	0.02 %	0.28 %	-0.41 %	0.60 %		-0.14		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								